

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: Feb 2026

System Name:	Peel Country Store		ID#: 41	94255	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.092				0.092
2		0.101					0.101
3		0.096					0.096
4		0.102					0.102
5		0.075					0.075
6			0.080				0.080
7			0.090				0.090
8				0.243			0.243
9		0.147					0.147
10		0.240					0.240
11		0.240 0.235			0.140		0.235
12		0	0.160				0.160
13				0.140			0.140
14			0.170				0.170
15			0.210				0.210
16			0.121				0.121
17			0.159				0.159
18			0.110				0.110
19			0.104				0.104
20			0.144				0.144
21			0.234				0.234
22			0.245				0.245
23		0.086				0.110	0.086
24		0.125				0.275	0.275
25		0.107				0.102	0.107
26		0.091				0.090	0.091
27			0.081				0.081
28				0.074			0.074
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU? All 4-hour turbidity readings \leq 1 NTU? All turbidity reading < IFE 2 triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No <input checked="" type="radio"/> Yes / <input type="radio"/> No <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No
		All Cl2 residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: <u>Jeremy Schwartz</u> SIGNATURE: <u>[Signature]</u> PHONE #: <u>503-310-7680</u>	DATE: <u>3-9-26</u> CERT #: <u>09180</u>

¹ Including continuous NTU data. If applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effic. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Peel Country Store	ID#: 41	94255	Month/Year: Feb 2026	WTP -: A	Disinfection Giardia Log Inactiv: 1
---------------------------------	---------	-------	----------------------	----------	-------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]	
1	2.0	50	100	11	6.8	41	Yes	25	
2	1.9	↓	95	10	6.9	41	Yes	↓	
3	1.8		90	10	6.9	41	Yes		
4	2.3		115	10	6.9	43	Yes		
5	1.8		90	10	6.9	41	Yes		
6	2.2		110	10	6.9	42	Yes		
7	1.9		95	11	6.8	41	Yes		
8	1.1		55	12	6.9	38	Yes		
9	1.6		80	12	6.7	40	Yes		
10	1.9		95	11	6.9	41	Yes		
11	2.1		105	11	6.8	42	Yes		
12	2.4		120	9	6.8	40	Yes		
13	2.6		130	11	6.8	44	Yes		
14	2.1		105	10	6.9	42	Yes		
15	2.1		105	10	6.8	42	Yes		
16	2.2		110	11	6.9	42	Yes		
17	2.4		120	10	6.8	43	Yes		
18	2.3		115	10	6.9	43	Yes		
19	2.2		110	10	6.9	42	Yes		
20	1.6		80	9	7.0	53	Yes		
21	2.0		100	11	6.6	41	Yes		
22	1.7		85	11	6.6	41	Yes		
23	1.5		75	12	6.7	40	Yes		
24	1.1		55	12	6.7	38	Yes		
25	1.5		75	12	6.8	40	Yes		
26	1.6		80	12	6.7	40	Yes		
27	2.1		105	11	6.6	42	Yes		
28	1.7		85	12	6.6	41	Yes		
29									
30									
31									

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.