

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: March 2026

System Name:	Peel Country Store		ID#: 41	94255	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.175				0.175
2		0.107				0.105	0.107
3			0.065				0.065
4		0.063					0.063
5			0.079				0.079
6			0.078				0.078
7			0.080				0.080
8				0.072			0.072
9		0.104					0.104
10			0.097				0.097
11			0.098				0.098
12			0.078				0.078
13			0.080				0.080
14		0.078					0.078
15			0.078				0.078
16		0.092					0.092
17			0.092				0.092
18			0.105				0.105
19			0.103				0.103
20			0.088				0.088
21			0.095				0.095
22				0.085			0.085
23		0.099					0.099
24			0.067				0.067
25			0.250				0.250
26			0.075				0.075
27			0.061				0.061
28			0.112				0.112
29				0.090			0.090
30		0.120					0.120
31			0.125				0.125

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity reading < IFE 2 triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: <u>Jeremy Schwab</u>
	SIGNATURE: <u>[Signature]</u> DATE: <u>4-7-26</u>
	PHONE #: <u>541-2603-3106</u> CERT #: <u>09180</u>

¹ Including continuous NTU data. If applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	Peel Country Store	ID#: 41	94255	Month/Year: March 2026	WTP -: A	Disinfection Giardia Log Inactiv: 1
--------------	--------------------	---------	-------	-------------------------------	----------	-------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	1.8	50	90	12	6.5	34	Yes	25
2	1.6		80	12	6.7	40	Yes	
3	1.7		85	12	6.7	41	Yes	
4	1.7		85	12	6.8	41	Yes	
5	1.6		80	12	6.8	40	Yes	
6	1.6		80	12	6.8	40	Yes	
7	1.8		90	12	6.8	41	Yes	
8	2.1		105	12	6.8	42	Yes	
9	1.6		80	12	6.8	40	Yes	
10	1.9		95	11	6.8	41	Yes	
11	2.1		105	11	6.8	42	Yes	
12	1.9		95	12	6.8	41	Yes	
13	1.8		90	12	6.8	41	Yes	
14	1.9		95	13	6.8	41	Yes	
15	2.0		100	11	6.7	41	Yes	
16	1.8		90	12	6.8	41	Yes	
17	1.8		90	12	6.8	41	Yes	
18	1.8		90	12	6.8	41	Yes	
19	2.0		100	12	6.8	41	Yes	
20	1.8		90	12	6.8	41	Yes	
21	1.7		85	13	6.7	41	Yes	
22	2.0		100	12	6.8	41	Yes	
23	2.2		110	11	6.8	42	Yes	
24	1.8		90	13	6.8	41	Yes	
25	1.9		95	13	6.8	41	Yes	
26	2.2		110	13	6.8	42	Yes	
27	2.8		140	11	6.5	89	Yes	
28	2.7		120	11	6.8	73	Yes	
29	2.0		100	13	7.0	41	Yes	
30	2.0		100	12	7.2	50	Yes	
31	2.0	↓	100	12	7.2	50	Yes	↓

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.