

## OHA - Drinking Water Services - Surface Water Quality Data Form

County:

COOS

## Cartridge or Bag Filtration

Month/Year:

Feb-22

| System Name: Sleepy Hollow RV Park |                   |                  | ID#: 41 94283 | WTP ID: TP- A              |                               |                                               |
|------------------------------------|-------------------|------------------|---------------|----------------------------|-------------------------------|-----------------------------------------------|
| Day                                | PSI Before Filter | PSI After Filter | PSID          | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day <sup>1</sup> [NTU] |
| 1                                  | 0.00              | 0.00             | 0.00          | 25.00                      | Miss                          |                                               |
| 2                                  | 0.00              | 0.00             | 0.00          | 25.00                      | Miss                          |                                               |
| 3                                  | 0.00              | 0.00             | 0.00          | 25.00                      | Miss                          |                                               |
| 4                                  | 0.00              | 0.00             | 0.00          | 25.00                      | Miss                          |                                               |
| 5                                  | 0.00              | 0.00             | 0.00          | 25.00                      | Miss                          |                                               |
| 6                                  | 0.00              | 0.00             | 0.00          | 25.00                      | Miss                          | Note: Training By OEC and Equipment           |
| 7                                  | 0.00              | 0.00             | 0.00          | 25.00                      | Miss                          | Supplied to Sleepy Hollow on 2-10-22.         |
| 8                                  | 0.00              | 0.00             | 0.00          | 25.00                      | Miss                          | Inadequate equipment and or training          |
| 9                                  | 0.00              | 0.00             | 0.00          | 25.00                      | Miss                          | is cause for these missed readings            |
| 10                                 | 18.00             | 10.00            | 8.00          | 25.00                      | 0.09                          | and have been corrected.                      |
| 11                                 | 19.00             | 11.00            | 8.00          | 25.00                      | 0.27                          |                                               |
| 12                                 | 21.00             | 10.00            | 11.00         | 25.00                      | 0.21                          |                                               |
| 13                                 | 23.00             | 9.00             | 14.00         | 25.00                      | 0.15                          |                                               |
| 14                                 | 24.00             | 10.00            | 14.00         | 25.00                      | 0.26                          |                                               |
| 15                                 | 16.00             | 14.00            | 2.00          | 25.00                      | 0.19                          |                                               |
| 16                                 | 15.00             | 12.00            | 3.00          | 25.00                      | 0.41                          |                                               |
| 17                                 | 16.00             | 12.00            | 4.00          | 25.00                      | 0.40                          |                                               |
| 18                                 | 16.00             | 12.00            | 4.00          | 25.00                      | 0.26                          |                                               |
| 19                                 | 16.00             | 12.00            | 4.00          | 25.00                      | 0.25                          |                                               |
| 20                                 | 16.00             | 12.00            | 4.00          | 25.00                      | 0.34                          |                                               |
| 21                                 | 16.00             | 12.00            | 4.00          | 25.00                      | 0.26                          |                                               |
| 22                                 | 14.00             | 11.00            | 3.00          | 25.00                      | 0.36                          |                                               |
| 23                                 | 16.00             | 11.00            | 5.00          | 25.00                      | 0.20                          |                                               |
| 24                                 | 16.00             | 11.00            | 5.00          | 25.00                      | 0.15                          |                                               |
| 25                                 | 16.00             | 11.00            | 5.00          | 25.00                      | 0.19                          |                                               |
| 26                                 | 17.00             | 10.00            | 7.00          | 25.00                      | 0.11                          |                                               |
| 27                                 | 19.00             | 8.00             | 11.00         | 25.00                      | 0.26                          |                                               |
| 28                                 | 23.00             | 7.00             | 16.00         | 25.00                      | 0.15                          |                                               |
| 29                                 |                   |                  |               | 25.00                      |                               |                                               |
| 30                                 |                   |                  |               | 25.00                      |                               |                                               |
| 31                                 |                   |                  |               | 25.00                      |                               |                                               |

| Cartridge & Bag Filtration                    |                                           | Monthly Summary (Answer Yes or No)        |                                                  |
|-----------------------------------------------|-------------------------------------------|-------------------------------------------|--------------------------------------------------|
| 95% of daily turbidity readings $\leq$ 1 NTU? | Yes / <input checked="" type="radio"/> No | CT's met everyday? (see back)             | All Cl2 residual at entry point $\geq$ 0.2 mg/l? |
| All daily turbidity readings $\leq$ 5 NTU?    | Yes / <input checked="" type="radio"/> No | Yes / <input checked="" type="radio"/> No | Yes / <input checked="" type="radio"/> No        |

Notes: PSI = pounds per square inch  
PSID = pounds per square inch difference (before filter - after filter)  
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID

|                          |                         |
|--------------------------|-------------------------|
| PRINTED NAME: John Woody | DATE: 3-10-22           |
| SIGNATURE: John Woody    | PHONE #: (541) 643-6137 |
| ICERT #: 7232            |                         |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

## OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

|              |                       |         |       |             |        |                                         |   |
|--------------|-----------------------|---------|-------|-------------|--------|-----------------------------------------|---|
| System Name: | Sleepy Hollow RV Park | ID#: 41 | 94283 | Month/Year: | Feb-22 | Disinfection<br>Glarvia Log<br>Inactiv: | 1 |
|--------------|-----------------------|---------|-------|-------------|--------|-----------------------------------------|---|

| Date / Time | Minimum Cl <sub>2</sub><br>Residual at 1st<br>User ( C ) <sup>2</sup> | Contact Time<br>(T) | Actual CT | Temp  | pH   | Required CT | CT Met? <sup>2</sup> | Peak<br>Hourly<br>Demand<br>Flow |
|-------------|-----------------------------------------------------------------------|---------------------|-----------|-------|------|-------------|----------------------|----------------------------------|
|             | [ppm or mg/L]                                                         | [minutes]           | C X T     | [° C] |      | formula     | Yes / No             | [GPM]                            |
| 1           | 1.2                                                                   | 28                  | 33.6      | 9.1   | 6.60 | 36.4        | NO                   | 10                               |
| 2           | 1.5                                                                   | 28                  | 42.0      | 10.8  | 6.70 | 34.9        | YES                  | 10                               |
| 3           | 2.2                                                                   | 28                  | 61.6      | 10.8  | 6.50 | 35.2        | YES                  | 10                               |
| 4           | 1.9                                                                   | 28                  | 53.2      | 12.7  | 6.40 | 28.2        | YES                  | 10                               |
| 5           | 0.04                                                                  | 28                  | 1.1       | 11.8  | 6.20 | 23.8        | NO                   | 10                               |
| 6           | 0.04                                                                  | 28                  | 1.1       | 10.5  | 6.80 | 31.4        | NO                   | 10                               |
| 7           | 0.63                                                                  | 28                  | 17.6      | 7.0   | 6.90 | 43.5        | NO                   | 10                               |
| 8           | POL                                                                   | 28                  | #VALUE!   | POL   | POL  | #VALUE!     | #VALUE!              | 10                               |
| 9           | 0.47                                                                  | 28                  | 13.2      | 7.0   | 6.80 | 41.3        | NO                   | 10                               |
| 10          | 0.39                                                                  | 28                  | 10.9      | 15.4  | 6.90 | 23.8        | NO                   | 10                               |
| 11          | 0.38                                                                  | 28                  | 10.6      | 16.0  | 6.90 | 22.9        | NO                   | 10                               |
| 12          | 2.9                                                                   | 28                  | 81.2      | 15.3  | 6.60 | 28.6        | YES                  | 10                               |
| 13          | 1.6                                                                   | 28                  | 44.8      | 16.8  | 6.80 | 24.0        | YES                  | 10                               |
| 14          | 1.2                                                                   | 28                  | 33.6      | 6.8   | 6.80 | 45.4        | NO                   | 10                               |
| 15          | 1.08                                                                  | 28                  | 30.2      | 17.8  | 6.80 | 21.1        | YES                  | 10                               |
| 16          | 1.9                                                                   | 28                  | 53.2      | 14.9  | 6.80 | 28.2        | YES                  | 10                               |
| 17          | 1.8                                                                   | 28                  | 50.4      | 15.7  | 6.80 | 26.4        | YES                  | 10                               |
| 18          | 1.7                                                                   | 28                  | 47.6      | 10.0  | 6.70 | 37.6        | YES                  | 10                               |
| 19          | 1.8                                                                   | 28                  | 50.4      | 16.6  | 6.60 | 23.1        | YES                  | 10                               |
| 20          | 2.4                                                                   | 28                  | 67.2      | 13.9  | 6.80 | 31.9        | YES                  | 10                               |
| 21          | 1.6                                                                   | 28                  | 44.8      | 13.6  | 6.60 | 27.6        | YES                  | 10                               |
| 22          | 1.7                                                                   | 28                  | 47.6      | 14.9  | 6.90 | 28.6        | YES                  | 10                               |
| 23          | 1.6                                                                   | 28                  | 44.8      | 12.8  | 6.80 | 31.4        | YES                  | 10                               |
| 24          | 1.4                                                                   | 28                  | 39.2      | 13.0  | 6.80 | 30.3        | YES                  | 10                               |
| 25          | 1.6                                                                   | 28                  | 44.8      | 12.3  | 6.80 | 33.2        | YES                  | 10                               |
| 26          | 2                                                                     | 28                  | 56.0      | 14.3  | 6.80 | 29.7        | YES                  | 10                               |
| 27          | 2                                                                     | 28                  | 56.0      | 14.5  | 6.80 | 29.3        | YES                  | 10                               |
| 28          | 2.2                                                                   | 28                  | 61.6      | 10.9  | 6.90 | 40.2        | YES                  | 10                               |
| 29          |                                                                       |                     |           |       |      |             |                      | 70                               |
| 30          |                                                                       |                     |           |       |      |             |                      | 70                               |
| 31          |                                                                       |                     |           |       |      |             |                      |                                  |

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dws.dms@oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350