

OHA - Drinking Water Services - Surface Water Quality Data Form

County: COOS

Cartridge or Bag Filtration

Month/Year: May-22

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	35.00	7.00	28.00	25.00	0.69	
2	36.00	5.00	31.00	25.00	0.71	
3	34.00	6.00	28.00	25.00	0.79	
4	42.00	0.00	42.00	25.00	0.80	
5	67.00	3.00	64.00	25.00	2.35	
6	18.00	8.00	10.00	25.00	2.35	
7	25.00	9.00	16.00	25.00	2.38	
8	off	off	#VALUE!	25.00	off	
9	17.00	11.00	6.00	25.00	0.71	
10	53.00	2.00	51.00	25.00	0.14	
11	61.00	0.00	61.00	25.00	7.61	
12	20.00	7.00	13.00	25.00	4.21	
13	off	off	#VALUE!	25.00	off	
14	40.00	5.00	35.00	25.00	4.07	
15	off	off	#VALUE!	25.00	7.42	
16	62.00	0.00	62.00	25.00	4.14	
17	64.00	0.00	64.00	25.00	5.76	
18	19.00	13.00	6.00	25.00	0.79	
19	18.00	13.00	5.00	25.00	0.83	
20	32.00	9.00	23.00	25.00	1.06	
21	60.00	5.00	55.00	25.00	2.85	
22	59.00	0.00	59.00	25.00	2.96	
23	64.00	0.00	64.00	25.00	0.83	
24	68.00	0.00	68.00	25.00	1.15	
25	74.00	5.00	69.00	25.00	2.74	
26	76.00	0.00	76.00	25.00	2.12	
27	80.00	0.00	80.00	25.00	1.71	
28	17.00	14.00	3.00	25.00	2.58	
29	33.00	9.00	24.00	25.00	1.09	
30	62.00	0.00	62.00	25.00	1.16	
31	68.00	0.00	68.00	25.00	2.08	

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
		Yes / No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.		
PRINTED NAME: John Woody		
SIGNATURE: <i>John Woody</i>		DATE: 6-10-22
PHONE #: (541) 643-6137		CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Sleepy Hollow RV Park	ID#: 41 94283	Month/Year: May-22	Disinfection <i>Giardia</i> Log Inactiv: 1
------------------------------------	---------------	--------------------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2	28	56.0	13.1	7.20	37.3	YES	40
2	2.1	28	58.8	13.7	7.19	36.1	YES	40
3	1.9	28	53.2	15.5	7.06	29.9	YES	40
4	2	28	56.0	12.4	7.23	40.0	YES	40
5	1.8	28	50.4	12.4	7.28	39.8	YES	40
6	2.3	28	64.4	13.2	7.27	39.3	YES	40
7	2.5	28	70.0	12.3	7.32	43.9	YES	40
8	2.9	28	81.2	10.8	7.23	49.2	YES	40
9	2.3	28	64.4	9.7	7.36	51.8	YES	40
10	2	28	56.0	9.8	7.24	47.6	YES	40
11	2.5	28	70.0	10.4	7.32	49.8	YES	40
12	1.7	28	47.6	10.6	7.38	45.8	YES	40
13	2.4	28	67.2	11.7	7.21	43.5	YES	40
14	2.5	28	70.0	13.2	7.35	41.4	YES	40
15	2	28	56.0	14.1	7.36	37.0	YES	40
16	2.3	28	64.4	14.1	7.29	37.3	YES	40
17	2.2	28	61.6	13.2	7.21	38.1	YES	40
18	2.5	28	70.0	12.3	7.28	43.3	YES	40
19	1.9	28	53.2	14.0	7.37	37.0	YES	40
20	2.5	28	70.0	14.0	6.71	31.0	YES	40
21	1.8	28	50.4	13.2	7.20	36.2	YES	40
22	1.6	28	44.8	13.1	7.26	36.4	YES	40
23	1.9	28	53.2	14.4	7.17	33.5	YES	40
24	2	28	56.0	14.9	7.15	32.5	YES	40
25	2.3	28	64.4	16.3	7.13	30.4	YES	40
26	2	28	56.0	15.8	7.18	30.9	YES	40
27	2	28	56.0	15.6	7.19	31.5	YES	40
28	1.8	28	50.4	15.0	7.23	32.5	YES	40
29	2	28	56.0	13.3	7.29	38.1	YES	40
30	1.7	28	47.6	16.7	7.31	29.5	YES	40
31	1.6	28	44.8	19.1	7.29	24.7	YES	40

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised July 2018