

OHA - Drinking Water Services - Surface Water Quality Data Form



County: COOS

Month/Year: Jul-22

Cartridge or Bag Filtration

System Name:	Sleepy Hollow RV Park		ID#:	41 94283	WTP ID:	TP-	A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	79.00	0.00	79.00	25.00	0.75		
2	80.00	0.00	80.00	25.00	0.79		
3	73.00	0.00	73.00	25.00	0.85		
4	55.00	0.00	55.00	25.00	0.69		
5	58.00	0.00	58.00	25.00	0.58		
6	63.00	0.00	63.00	25.00	0.66		
7	65.00	5.00	60.00	25.00	0.68		
8	67.00	5.00	62.00	25.00	0.70		
9	73.00	5.00	68.00	25.00	0.69		
10	77.00	5.00	72.00	25.00	0.68		
11	15.00	15.00	0.00	25.00	Broken	Bulb On Order	
12	66.00	0.00	66.00	25.00	Broken		
13	75.00	0.00	75.00	25.00	Broken		
14	80.00	0.00	80.00	25.00	Broken		
15	83.00	0.00	83.00	25.00	Broken		
16	65.00	5.00	60.00	25.00	Broken		
17	70.00	0.00	70.00	25.00	Broken		
18	74.00	0.00	74.00	25.00	Broken		
19	76.00	0.00	76.00	25.00	Broken		
20	25.00	9.00	16.00	25.00	0.46	Received Loaner Turbidimeter	
21	52.00	5.00	47.00	25.00	0.53		
22	70.00	0.00	70.00	25.00	0.29		
23	76.00	0.00	76.00	25.00	0.38		
24	16.00	11.00	5.00	25.00	0.29		
25	58.00	0.00	58.00	25.00	0.27		
26	74.00	0.00	74.00	25.00	0.36		
27	18.00	10.00	8.00	25.00	0.31		
28	41.00	6.00	35.00	25.00	0.33		
29	56.00	0.00	56.00	25.00	0.27		
30	69.00	0.00	69.00	25.00	0.33		
31	76.00	0.00	76.00	25.00	0.19		

Cartridge & Bag Filtration 95% of daily turbidity readings ≤ 1 NTU? Yes / <input checked="" type="radio"/> No All daily turbidity readings ≤ 5 NTU? Yes / <input checked="" type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes / <input checked="" type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / <input checked="" type="radio"/> No	
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.		PRINTED NAME: Jonathan Woody SIGNATURE: <i>Jonathan Woody</i> DATE: 8-9-22 PHONE #: (541) 643-6137 CERT #: 7232	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

note: Turbidimeter bulb failed on new meter on 7-11-22. OEC Delivered Loaner meter on 8-20-22. New Bulb ordered and installed 8-2-22

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Sleepy Hollow RV Park

ID#: 41 94283

Month/Year: Jul-22

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.6	28	44.8	18.5	7.53	28.1	YES	40
2	1.7	28	47.6	18.1	7.47	28.6	YES	40
3	1.6	28	44.8	17.7	7.54	29.8	YES	40
4	1.6	28	44.8	17.7	7.52	29.5	YES	40
5	1.6	28	44.8	18.3	7.52	28.4	YES	40
6	2	28	56.0	18.3	7.50	29.5	YES	40
7	1.6	28	44.8	18.4	7.44	27.4	YES	40
8	2.2	28	61.6	19.4	7.49	27.9	YES	40
9	2.5	28	70.0	19.6	7.37	27.3	YES	40
10	1.7	28	47.6	19.7	7.50	25.9	YES	40
11	2.5	28	70.0	21.8	7.60	25.6	YES	40
12	1.7	28	47.6	20.3	7.66	26.4	YES	40
13	1.6	28	44.8	19.9	7.61	26.4	YES	40
14	1.6	28	44.8	19.0	7.58	27.7	YES	40
15	2	28	56.0	18.6	7.55	29.4	YES	40
16	2.5	28	70.0	19.9	7.55	28.6	YES	40
17	2.5	28	70.0	19.2	7.63	30.8	YES	40
18	2.5	28	70.0	18.4	7.57	31.8	YES	40
19	2.2	28	61.6	18.3	7.58	31.1	YES	40
20	2.2	28	61.6	18.8	7.56	29.8	YES	40
21	1.6	28	44.8	18.8	7.55	27.8	YES	40
22	2.1	28	58.8	19.4	7.56	28.3	YES	40
23	2	28	56.0	18.9	7.64	29.8	YES	40
24	2.5	28	70.0	19.8	7.69	30.3	YES	40
25	2.5	28	70.0	19.5	7.65	30.5	YES	40
26	2.5	28	70.0	20.5	7.63	28.3	YES	40
27	2	28	56.0	21.2	7.62	25.4	YES	40
28	1.7	28	47.6	20.1	7.59	26.1	YES	40
29	1.6	28	44.8	21.1	7.55	23.8	YES	40
30	2	28	56.0	21.0	7.59	25.4	YES	40
31	2.5	28	70.0	21.1	7.60	26.9	YES	40

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised July 2018