

OHA - Drinking Water Services - Surface Water Quality Data Form

County: COOS

Cartridge or Bag Filtration

Month/Year: Aug-22

System Name: Sleepy Hollow RV Park ID#: 41 94283 WTP ID: TP- A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	17.00	11.00	6.00	25.00	0.44	0.44
2	15.00	6.00	9.00	25.00	0.18	0.18
3	64.00	0.00	64.00	25.00	0.19	0.19
4	70.00	0.00	70.00	25.00	0.22	0.22
5	73.00	0.00	73.00	25.00	0.29	0.29
6	75.00	0.00	75.00	25.00	0.19	0.19
7	75.00	0.00	75.00	25.00	0.15	0.15
8	74.00	0.00	74.00	25.00	0.44	0.44
9	75.00	0.00	75.00	25.00	0.65	0.65
10	75.00	0.00	75.00	25.00	0.30	0.30
11	14.00	11.00	3.00	25.00	0.11	0.11
12	16.00	10.00	6.00	25.00	0.49	0.49
13	25.00	8.00	17.00	25.00	0.38	0.38
14	33.00	6.00	27.00	25.00	0.17	0.17
15	45.00	2.00	43.00	25.00	0.31	0.31
16	50.00	0.00	50.00	25.00	0.26	0.26
17	51.00	0.00	51.00	25.00	0.13	0.13
18	52.00	0.00	52.00	25.00	0.18	0.18
19	52.00	0.00	52.00	25.00	0.13	0.13
20	52.00	0.00	52.00	25.00	0.10	0.10
21	52.00	0.00	52.00	25.00	0.20	0.20
22	52.00	0.00	52.00	25.00	0.17	0.17
23	53.00	0.00	53.00	25.00	0.10	0.10
24	53.00	0.00	53.00	25.00	0.10	0.10
25	53.00	0.00	53.00	25.00	0.23	0.23
26	55.00	0.00	55.00	25.00	0.15	0.15
27	56.00	0.00	56.00	25.00	0.10	0.10
28	14.00	10.00	4.00	25.00	0.29	0.29
29	25.00	5.00	20.00	25.00	0.20	0.20
30	22.00	8.00	14.00	25.00	0.17	0.17
31	32.00	3.00	29.00	25.00	0.20	0.20

**Cartridge & Bag Filtration**

95% of daily turbidity readings ≤ 1 NTU?

Yes  No

All daily turbidity readings ≤ 5 NTU?

Yes  No

**Monthly Summary (Answer Yes or No)**

CT's met everyday? (see back)

Yes  No

All Cl<sub>2</sub> residual at entry point ≥ 0.2 mg/l?

Yes  No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.

PRINTED NAME: Jonathan Woody

SIGNATURE: *Jonathan Woody*

DATE: 9/9/22

PHONE #: (541) 643-6137

CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: <b>Sleepy Hollow RV Park</b>	ID#: <b>41 94283</b>	Month/Year: <b>Aug-22</b>	Disinfection <i>Giardia</i> Log Inactiv: <b>1</b>
---	----------------------	---------------------------	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.1	28	58.8	20.2	7.58	27.1	YES	40
2	1.6	28	44.8	19.9	7.59	26.2	YES	40
3	1.7	28	47.6	20.0	7.56	26.0	YES	40
4	1.6	28	44.8	19.2	7.57	27.2	YES	40
5	1.6	28	44.8	19.4	7.56	26.8	YES	40
6	2.5	28	70.0	19.4	7.48	28.8	YES	40
7	2.5	28	70.0	19.6	7.58	29.5	YES	40
8	2.5	28	70.0	19.7	7.47	28.1	YES	40
9	2.5	28	70.0	18.8	7.53	28.6	YES	40
10	2.5	28	70.0	19.6	7.47	28.3	YES	40
11	1.8	28	50.4	19.0	7.19	24.5	YES	40
12	1.9	28	53.2	19.0	7.19	24.8	YES	40
13	1.4	28	39.2	19.0	7.19	23.4	YES	40
14	1.8	28	50.4	19.0	7.19	24.5	YES	40
15	2	28	56.0	19.0	7.19	25.1	YES	40
16	2	28	56.0	19.0	7.19	25.1	YES	40
17	1.8	28	50.4	19.0	7.19	24.5	YES	40
18	1.6	28	44.8	19.0	7.19	23.9	YES	40
19	1.8	28	50.4	20.9	7.53	24.5	YES	40
20	2.4	28	67.2	20.7	7.24	23.9	YES	40
21	2.5	28	70.0	20.2	7.09	23.6	YES	40
22	2.5	28	70.0	20.3	7.73	29.7	YES	40
23	2.5	28	70.0	21.3	7.50	25.5	YES	40
24	2.5	28	70.0	20.2	7.49	27.4	YES	40
25	2.5	28	70.0	20.6	7.00	22.2	YES	40
26	2.5	28	70.0	20.3	7.00	22.7	YES	40
27	2	28	56.0	20.0	7.20	23.5	YES	40
28	1.7	28	47.6	19.6	7.20	23.4	YES	40
29	2	28	56.0	18.3	7.20	26.4	YES	40
30	2	28	56.0	19.2	7.20	24.8	YES	40
31	1.6	28	44.8	18.8	7.20	24.4	YES	40

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350