

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Coos

Cartridge or Bag Filtration

Month/Year: Oct-23

System Name: SleepyHollow RV ID#: 41 94283 WTP ID: TP- A

| Day | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day ¹ [NTU] |
|-----|-------------------|------------------|-------|----------------------------|-------------------------------|-----------------------------------------------|
| 1 | 52.00 | 50.00 | 2.00 | 25.00 | 0.28 | |
| 2 | 52.00 | 50.00 | 2.00 | 25.00 | 0.14 | |
| 3 | 52.00 | 50.00 | 2.00 | 25.00 | 0.13 | |
| 4 | 52.00 | 49.00 | 3.00 | 25.00 | 0.11 | |
| 5 | 52.00 | 48.00 | 4.00 | 25.00 | 0.12 | |
| 6 | 52.00 | 48.00 | 4.00 | 25.00 | 0.14 | |
| 7 | 53.00 | 48.00 | 5.00 | 25.00 | 0.15 | |
| 8 | 53.00 | 48.00 | 5.00 | 25.00 | 0.17 | |
| 9 | 54.00 | 48.00 | 6.00 | 25.00 | 0.16 | |
| 10 | 55.00 | 48.00 | 7.00 | 25.00 | 0.18 | |
| 11 | 55.00 | 48.00 | 7.00 | 25.00 | 0.25 | |
| 12 | 55.00 | 48.00 | 7.00 | 25.00 | 0.38 | |
| 13 | 55.00 | 48.00 | 7.00 | 25.00 | 0.25 | |
| 14 | 55.00 | 45.00 | 10.00 | 25.00 | 0.28 | |
| 15 | 55.00 | 45.00 | 10.00 | 25.00 | 0.18 | |
| 16 | 52.00 | 45.00 | 7.00 | 25.00 | 0.12 | |
| 17 | 52.00 | 45.00 | 7.00 | 25.00 | 0.31 | |
| 18 | 54.00 | 45.00 | 9.00 | 25.00 | 0.14 | |
| 19 | 54.00 | 44.00 | 10.00 | 25.00 | 0.18 | |
| 20 | 54.00 | 44.00 | 10.00 | 25.00 | 0.20 | |
| 21 | 53.00 | 45.00 | 8.00 | 25.00 | 0.13 | |
| 22 | 53.00 | 44.00 | 9.00 | 25.00 | 0.14 | |
| 23 | 53.00 | 44.00 | 9.00 | 25.00 | 0.14 | |
| 24 | 53.00 | 43.00 | 10.00 | 25.00 | 0.18 | |
| 25 | 53.00 | 43.00 | 10.00 | 25.00 | 0.07 | |
| 26 | 53.00 | 43.00 | 10.00 | 25.00 | 0.10 | |
| 27 | 53.00 | 43.00 | 10.00 | 25.00 | 0.11 | |
| 28 | 54.00 | 43.00 | 11.00 | 25.00 | 0.16 | |
| 29 | 54.00 | 43.00 | 11.00 | 25.00 | 0.16 | |
| 30 | 54.00 | 43.00 | 11.00 | 25.00 | 0.15 | |
| 31 | 54.00 | 43.00 | 11.00 | 25.00 | 0.17 | |

| Monthly Summary (Answer Yes or No) | |
|--------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------|
| 95% of daily turbidity readings ≤ 1 NTU? Yes / No | CT's met everyday? (see back) Yes / No |
| All daily turbidity readings ≤ 5 NTU? Yes / No | All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No |

| | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------|
| Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID. | PRINTED NAME: <i>Jonathan Woody</i> |
| | SIGNATURE: <i>Jonathan Woody</i> DATE: 11-10-23 |
| | PHONE #: (541) 643-6137 CERT #: 7232 |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Sleepy Hollow RV ID#: 41 94283 Month/Year: Oct-23

Disinfection
Giardia Log
Inactiv: 1

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ² | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ² | Peak Hourly Demand Flow |
|-------------|-----------------------------------------------------------------|------------------|-----------|-------|------|-------------|----------------------|-------------------------|
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 1.31 | 47.4 | 62.1 | 17.7 | 7.09 | 24.4 | YES | 3 |
| 2 | 0.96 | 47.4 | 45.5 | 17.9 | 7.09 | 23.1 | YES | 3 |
| 3 | 1.31 | 47.4 | 62.1 | 17.7 | 7.09 | 24.4 | YES | 3 |
| 4 | 0.92 | 47.4 | 43.6 | 17.6 | 7.10 | 23.5 | YES | 3 |
| 5 | 0.73 | 47.4 | 34.6 | 18.2 | 7.09 | 22.0 | YES | 3 |
| 6 | 1.21 | 47.4 | 57.4 | 18.2 | 7.11 | 23.5 | YES | 3 |
| 7 | 1.53 | 47.4 | 72.5 | 17.9 | 7.11 | 24.8 | YES | 3 |
| 8 | 1.77 | 47.4 | 83.9 | 17.7 | 7.14 | 26.2 | YES | 3 |
| 9 | 1.41 | 47.4 | 66.8 | 16.1 | 7.13 | 27.8 | YES | 3 |
| 10 | 1.28 | 47.4 | 60.7 | 15.3 | 7.14 | 29.0 | YES | 3 |
| 11 | 1.01 | 47.4 | 47.9 | 14.2 | 7.21 | 31.1 | YES | 3 |
| 12 | 0.98 | 47.4 | 46.5 | 13.8 | 7.30 | 32.9 | YES | 3 |
| 13 | 1.28 | 47.4 | 60.7 | 14.2 | 7.14 | 31.2 | YES | 3 |
| 14 | 1.42 | 47.4 | 67.3 | 14.7 | 7.04 | 29.6 | YES | 3 |
| 15 | 1.61 | 47.4 | 76.3 | 14.8 | 7.03 | 29.9 | YES | 3 |
| 16 | 1.98 | 47.4 | 93.9 | 15.0 | 7.33 | 34.4 | YES | 3 |
| 17 | 1.73 | 47.4 | 82.0 | 15.6 | 7.34 | 32.3 | YES | 3 |
| 18 | 1.88 | 47.4 | 89.1 | 16.7 | 7.15 | 28.4 | YES | 3 |
| 19 | 1.57 | 47.4 | 74.4 | 16.5 | 7.14 | 27.7 | YES | 3 |
| 20 | 2.01 | 47.4 | 95.3 | 16.4 | 7.12 | 29.1 | YES | 3 |
| 21 | 1.72 | 47.4 | 81.5 | 16.9 | 7.37 | 29.9 | YES | 3 |
| 22 | 1.68 | 47.4 | 79.6 | 16.2 | 6.98 | 27.0 | YES | 3 |
| 23 | 1.58 | 47.4 | 74.9 | 14.0 | 7.64 | 39.4 | YES | 3 |
| 24 | 1.72 | 47.4 | 81.5 | 12.9 | 7.34 | 38.6 | YES | 3 |
| 25 | 1.81 | 47.4 | 85.8 | 12.2 | 7.25 | 39.9 | YES | 3 |
| 26 | 1.8 | 47.4 | 85.3 | 12.4 | 7.25 | 39.4 | YES | 3 |
| 27 | 0.94 | 47.4 | 44.6 | 11.6 | 7.21 | 37.2 | YES | 3 |
| 28 | 1.68 | 47.4 | 79.6 | 12.2 | 7.01 | 36.2 | YES | 3 |
| 29 | 1.88 | 47.4 | 89.1 | 12.4 | 7.50 | 43.3 | YES | 3 |
| 30 | 1.9 | 47.4 | 90.1 | 12.8 | 7.20 | 37.6 | YES | 3 |
| 31 | 1.89 | 47.4 | 89.6 | 12.6 | 6.92 | 34.3 | YES | 3 |

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised July 2018