

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 9/2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	off	off	.085	off	off	.098	.098
2	off	off	.062	off	.060	off	.062
3	off	off	.055	off	off	off	.055
4	.056	off	.062	off	off	off	.062
5	off	.049	off	off	off	.043	.049
6	off	off	.040	off	off	off	.040
7	off	off	.035	off	off	.048	.048
8	off	off	.053	off	off	.060	.060
9	off	off	.058	off	off	.058	.058
10	off	off	.052	off	off	.068	.068
11	off	off	.090	off	off	off	.090
12	off	off	.039	off	off	off	.039
13	.050	off	.060	off	off	.090	.090
14	off	off	.053	off	off	.042	.053
15	off	off	.044	.045	off	off	.045
16	off	.050	.051	off	off	.040	.051
17	off	off	.040	off	off	.045	.045
18	off	off	off	.035	off	off	.035
19	off	off	.049	off	off	off	.049
20	.039	off	.055	off	off	.040	.055
21	off	off	.080	off	off	.054	.080
22	off	off	.035	.053	off	.038	.053
23	off	off	.035	off	.060	off	.060
24	off	off	.034	off	.042	off	.042
25	off	off	.036	off	off	off	.036
26	off	.038	.042	off	off	off	.042
27	off	.048	.044	off	off	.038	.048
28	off	off	.047	.048	off	off	.048
29	off	.055	.080	off	off	.045	.080
30	off	off	.048	off	off	.052	.052
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No ²		Notes:	
PRINTED NAME: Robert Fowler		DATE: 10-1-21	
SIGNATURE: <i>Robert Fowler</i>		CERT #: T-08679	
PHONE #: (541) 679-2549		D-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indivd. Filter Effic. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program -- Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:- WTP-A Month/Year: 9/2021

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1 8:00 AM	1.43	224	320	22.2	6.49	8	Yes	6.7
2 8:00 AM	1.14	224	255	21.8	6.45	8	Yes	6.7
3 8:00 AM	0.82	224	183	21.4	6.46	8	Yes	6.7
4 8:00 AM	1.04	224	232	21.0	6.50	8	Yes	6.7
5 8:00 AM	1.15	224	257	21.8	6.52	8	Yes	6.7
6 8:00 AM	1.25	224	280	21.8	6.52	8	Yes	6.7
7 8:00 AM	1.28	224	286	22.1	6.54	8	Yes	6.7
8 8:00 AM	1.61	224	360	22.3	6.53	8	Yes	6.7
9 8:00 AM	1.68	224	376	22.6	6.54	8	Yes	6.7
10 8:00 AM	1.52	224	340	23.1	6.52	8	Yes	6.7
11 8:00 AM	1.33	224	297	22.3	6.48	8	Yes	6.7
12 8:00 AM	1.11	224	248	22.2	6.46	8	Yes	6.7
13 8:00 AM	.93	224	208	22.4	6.49	8	Yes	6.7
14 8:00 AM	.92	224	206	21.3	6.45	8	Yes	6.7
15 8:00 AM	1.14	224	255	22.2	6.49	8	Yes	6.7
16 8:00 AM	1.43	224	320	21.6	6.48	8	Yes	6.7
17 8:00 AM	1.52	224	340	21.8	6.49	8	Yes	6.7
18 8:00 AM	1.46	224	327	21.7	6.48	8	Yes	6.7
19 8:00 AM	1.32	224	297	21.7	6.49	8	Yes	6.7
20 8:00 AM	1.21	224	271	21.5	6.46	8	Yes	6.7
21 8:00 AM	1.14	224	255	21.6	6.47	8	Yes	6.7
22 8:00 AM	1.10	224	246	20.8	6.37	8	Yes	6.7
23 8:00 AM	1.05	224	235	20.4	6.36	8	Yes	6.7
24 8:00 AM	1.04	224	232	20.6	6.39	8	Yes	6.7
25 8:00 AM	1.23	224	275	20.4	6.38	8	Yes	6.7
26 8:00 AM	1.24	224	277	20.7	6.37	8	Yes	6.7
27 8:00 AM	1.48	224	331	21.1	6.43	8	Yes	6.7
28 8:00 AM	1.53	224	342	20.9	6.40	8	Yes	6.7
29 8:00 AM	1.46	224	327	19.4	6.40	11	Yes	6.7
30 8:00 AM	1.30	224	291	20.3	6.37	8	Yes	6.7
31 /								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.