

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 2/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.100	OFF	.071	off	off	off	.100
2	.068	off	.053	off	off	.048	.068
3	off	off	.050	off	off	off	.050
4	.048	OFF	.044	off	off	off	.048
5	.045	off	.040	off	OFF	OFF	.045
6	OFF	.042	.029	off	off	off	.042
7	off	.041	off	.038	off	off	.041
8	.037	off	.036	OFF	OFF	.035	.037
9	OFF	OFF	.036	.145	off	off	.145
10	.082	off	.059	off	off	off	.082
11	.064	off	.056	off	off	.060	.064
12	off	off	.056	OFF	OFF	OFF	.056
13	OFF	.052	.040	off	off	off	.052
14	off	.052	off	.042	OFF	OFF	.052
15	.058	OFF	off	.056	off	off	.058
16	.056	off	off	.054	OFF	OFF	.056
17	.052	OFF	.061	OFF	OFF	OFF	.061
18	.070	OFF	.068	off	off	off	.070
19	.072	off	OFF	.178	off	OFF	.178
20	OFF	OFF	.088	off	off	off	.088
21	.072	off	.077	OFF	OFF	off	.077
22	.084	OFF	.093	off	off	.060	.093
23	off	off	.059	off	.062	off	.062
24	.072	off	.074	off	.058	off	.074
25	off	.076	OFF	.067	off	.054	.076
26	off	off	.056	OFF	OFF	OFF	.056
27	OFF	.052	.175	off	off	off	.175
28	off	off	.106	OFF	OFF	.080	.106
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ²		Notes:	
PRINTED NAME: Robert Frazier		SIGNATURE: <i>Robert Frazier</i>	
PHONE #: (541) 679-2549		DATE: 3-1-22	
		CERT #: T-08679 D-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 2/2022

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[° C]		Use tables	Yes / No	[GPM]
1 18:00 AM	1.60	224	358	11.7	7.11	20	Yes	6.7
2 18:00 AM	1.42	224	225	11.4	7.12	19	Yes	6.7
3 18:00 AM	1.38	224	309	11.7	7.13	19	Yes	6.7
4 18:00 AM	1.35	224	302	11.9	7.12	19	Yes	6.7
5 18:00 AM	1.31	224	293	12.0	7.14	19	Yes	6.7
6 18:00 AM	1.33	224	297	12.5	7.12	19	Yes	6.7
7 18:00 AM	1.28	224	286	12.8	7.13	19	Yes	6.7
8 18:00 AM	1.34	224	300	13.0	7.16	19	Yes	6.7
9 18:00 AM	1.30	224	291	12.9	7.11	19	Yes	6.7
10 18:00 AM	1.35	224	302	12.2	7.17	19	Yes	6.7
11 18:00 AM	1.28	224	286	12.2	7.19	19	Yes	6.7
12 18:00 AM	1.21	224	271	12.5	7.19	19	Yes	6.7
13 18:00 AM	1.19	224	266	12.6	7.22	23	Yes	6.7
14 18:00 AM	1.11	224	248	13.4	7.16	19	Yes	6.7
15 18:00 AM	1.31	224	293	13.5	7.27	23	Yes	6.7
16 18:00 AM	1.47	224	329	11.7	7.16	19	Yes	6.7
17 18:00 AM	1.47	224	329	13.5	7.17	19	Yes	6.7
18 18:00 AM	1.44	224	322	13.5	7.17	19	Yes	6.7
19 18:00 AM	1.27	224	284	13.5	7.17	19	Yes	6.7
20 18:00 AM	1.56	224	349	13.5	7.17	19	Yes	6.7
21 18:00 AM	1.60	224	358	13.2	7.18	20	Yes	6.7
22 18:00 AM	1.34	224	300	13.2	7.16	19	Yes	6.7
23 18:00 AM	1.15	224	257	12.7	7.17	19	Yes	6.7
24 18:00 AM	1.19	224	266	11.8	7.12	19	Yes	6.7
25 18:00 AM	1.44	224	322	11.4	7.12	19	Yes	6.7
26 18:00 AM	1.56	224	349	11.2	7.06	19	Yes	6.7
27 18:00 AM	1.45	224	324	12.0	7.01	19	Yes	6.7
28 18:00 AM	1.36	224	304	12.2	6.97	16	Yes	6.7
29 /								
30 /								
31 /								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.