

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 4/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	OFF	OFF	.062	off	off	off	.062
2	OFF	.068	off	.049	OFF	OFF	.068
3	.071	OFF	.058	off	off	off	.071
4	off	off	.051	off	off	off	.051
5	off	off	.051	.055	OFF	OFF	.055
6	OFF	OFF	.063	.084	off	off	.084
7	off	off	.098	off	off	off	.098
8	off	.055	.195	OFF	OFF	OFF	.195
9	OFF	OFF	.046	OFF	OFF	OFF	.046
10	OFF	OFF	.079	off	off	off	.079
11	OFF	OFF	.069	OFF	OFF	OFF	.069
12	OFF	OFF	.082	OFF	OFF	OFF	.082
13	OFF	OFF	.058	.053	OFF	OFF	.058
14	OFF	OFF	.051	OFF	OFF	OFF	.051
15	OFF	OFF	.052	off	off	off	.052
16	.180	off	.054	OFF	OFF	OFF	.180
17	OFF	OFF	.048	off	off	off	.048
18	off	off	.046	OFF	OFF	OFF	.046
19	OFF	.048	off	.039	OFF	OFF	.048
20	OFF	OFF	.185	OFF	OFF	OFF	.185
21	OFF	OFF	.106	OFF	OFF	OFF	.106
22	OFF	.108	off	.087	off	OFF	.108
23	OFF	OFF	.066	OFF	OFF	OFF	.066
24	OFF	OFF	.061	off	off	off	.061
25	off	off	.061	.054	OFF	OFF	.061
26	OFF	OFF	.046	OFF	OFF	OFF	.046
27	OFF	.045	OFF	.038	OFF	OFF	.045
28	OFF	OFF	.037	OFF	OFF	OFF	.037
29	OFF	OFF	.037	OFF	OFF	OFF	.037
30	OFF	OFF	.185	OFF	OFF	OFF	.185
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:	PRINTED NAME: Robert Fowler		
	SIGNATURE: <i>Robert Fowler</i>	DATE: 5-2-22	
	PHONE #: (541) 679-2549	CERT #: T-08679 D-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 4/2022

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ^a	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1 8:00am	1.21	224	271	17.2	6.99	13	Yes	6.7
2 8:00am	1.19	224	266	17.3	6.95	13	Yes	6.7
3 8:00am	1.30	224	291	17.2	6.98	13	Yes	6.7
4 8:00am	1.38	224	309	17.3	6.98	13	Yes	6.7
5 8:00am	1.28	224	286	17.2	6.98	13	Yes	6.7
6 8:00am	1.33	224	297	16.9	7.00	13	Yes	6.7
7 8:00am	1.33	224	297	17.4	7.04	13	Yes	6.7
8 8:00am	1.36	224	304	17.4	7.00	13	Yes	6.7
9 8:00am	1.40	224	313	16.9	6.95	13	Yes	6.7
10 8:00am	1.32	224	295	16.8	6.99	13	Yes	6.7
11 8:00am	1.21	224	271	16.8	6.92	13	Yes	6.7
12 8:00am	1.16	224	259	16.5	6.94	13	Yes	6.7
13 8:00am	1.16	224	259	16.6	6.95	13	Yes	6.7
14 8:00am	1.27	224	284	16.7	6.95	13	Yes	6.7
15 8:00am	1.25	224	280	16.4	7.01	13	Yes	6.7
16 8:00am	1.23	224	275	16.4	7.04	13	Yes	6.7
17 8:00am	1.25	224	280	16.3	7.06	13	Yes	6.7
18 8:00am	1.23	224	275	16.3	7.11	13	Yes	6.7
19 8:00am	1.28	224	273	16.4	7.10	13	Yes	6.7
20 8:00am	1.29	224	288	16.2	7.08	13	Yes	6.7
21 8:00am	1.43	224	320	15.9	6.95	13	Yes	6.7
22 8:00am	1.46	224	327	16.2	7.59	16	Yes	6.7
23 8:00am	1.44	224	322	16.1	7.59	16	Yes	6.7
24 8:00am	1.40	224	313	16.5	7.56	16	Yes	6.7
25 8:00am	1.31	224	293	16.4	7.55	16	Yes	6.7
26 8:00am	1.39	224	311	16.5	7.54	16	Yes	6.7
27 8:00am	1.40	224	313	16.8	7.53	16	Yes	6.7
28 8:00am	1.44	224	322	16.9	7.53	16	Yes	6.7
29 8:00am	1.46	224	327	17.0	7.52	16	Yes	6.7
30 8:00am	1.48	224	331	17.2	7.51	16	Yes	6.7
31 /								

^a If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.