

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 6/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.052	off	off	off	.052
2	.042	off	.032	off	off	off	.042
3	.038	off	.040	off	off	off	.040
4	off	off	.034	off	off	off	.034
5	off	off	.039	off	off	off	.039
6	off	off	.032	off	off	off	.032
7	off	off	.074	off	off	.052	.074
8	off	off	.037	off	off	off	.037
9	.040	off	.034	off	off	off	.040
10	.038	off	.035	off	off	off	.038
11	.032	off	.099	off	off	off	.099
12	off	off	.050	off	off	off	.050
13	off	off	.048	off	.174	off	.174
14	off	off	.059	off	off	off	.059
15	off	.125	off	.116	off	off	.125
16	off	off	.061	off	off	off	.061
17	.058	off	off	.050	off	off	.058
18	off	off	.066	off	off	off	.066
19	off	off	.040	off	off	off	.040
20	off	off	.042	off	off	off	.042
21	.052	off	off	off	.045	off	.052
22	off	off	.041	off	off	off	.041
23	.050	off	.045	off	off	.049	.050
24	off	off	.046	off	.045	off	.046
25	off	off	.124	off	off	.047	.124
26	off	off	.057	off	off	off	.057
27	off	off	.040	off	.068	off	.068
28	.069	off	.057	.044	off	.040	.069
29	off	off	.032	off	off	.034	.034
30	off	off	.036	off	off	off	.036
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Notes:	PRINTED NAME: <u>Robert Fowler</u>		
	SIGNATURE: <u>Robert Fowler</u>	DATE: <u>7-1-22</u>	
	PHONE #: <u>1541 1679-2549</u>	CERT #: <u>T-08679</u> <u>D-08666</u>	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 6/2022

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 18:00 am	.98	224	219	19.1	6.65	13	Yes	6.7
2 18:00 am	1.04	224	232	19.2	6.62	13	Yes	6.7
3 18:00 am	1.07	224	239	19.2	6.62	13	Yes	6.7
4 18:00 am	1.04	224	232	18.9	6.60	13	Yes	6.7
5 18:00 am	1.00	224	204	18.9	6.59	11	Yes	6.7
6 18:00 am	.96	224	215	18.9	6.57	11	Yes	6.7
7 18:00 am	.97	224	217	19.0	6.57	11	Yes	6.7
8 18:00 am	.98	224	219	19.1	6.57	11	Yes	6.7
9 18:00 am	.99	224	221	19.2	6.55	11	Yes	6.7
10 18:00 am	.98	224	219	19.4	6.51	11	Yes	6.7
11 18:00 am	.96	224	215	19.7	6.53	11	Yes	6.7
12 18:00 am	.99	224	221	19.8	6.50	11	Yes	6.7
13 18:00 am	.98	224	219	19.4	6.52	11	Yes	6.7
14 18:00 am	.92	224	206	19.3	6.56	11	Yes	6.7
15 18:00 am	.88	224	197	19.3	6.53	10	Yes	6.7
16 18:00 am	.95	224	212	19.4	6.56	11	Yes	6.7
17 18:00 am	.87	224	194	18.6	6.52	10	Yes	6.7
18 18:00 am	.90	224	201	18.5	6.56	11	Yes	6.7
19 18:00 am	.89	224	199	18.4	6.56	10	Yes	6.7
20 18:00 am	.92	224	206	18.7	6.53	11	Yes	6.7
21 18:00 am	.97	224	217	18.8	6.56	11	Yes	6.7
22 18:00 am	1.07	224	239	19.0	6.53	11	Yes	6.7
23 18:00 am	1.14	224	255	19.5	6.53	11	Yes	6.7
24 18:00 am	1.12	224	250	19.5	6.51	11	Yes	6.7
25 18:00 am	1.15	224	257	20.3	6.51	8	Yes	6.7
26 18:00 am	1.19	224	260	20.9	6.50	8	Yes	6.7
27 18:00 am	1.21	224	271	21.6	6.47	8	Yes	6.7
28 18:00 am	1.18	224	264	22.1	6.41	8	Yes	6.7
29 18:00 am	1.10	224	246	22.2	6.41	8	Yes	6.7
30 18:00 am	1.18	224	264	22.1	6.42	8	Yes	6.7
31 /								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.