

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:WTP-A Month/Year: 9/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	.038	OFF	.040	OFF	.040
2	OFF	OFF	.040	OFF	OFF	.038	.040
3	OFF	OFF	.097	OFF	OFF	OFF	.097
4	OFF	.043	OFF	OFF	OFF	.044	.044
5	OFF	OFF	.044	OFF	OFF	OFF	.044
6	OFF	OFF	.035	OFF	.050	OFF	.050
7	OFF	OFF	.049	OFF	.051	OFF	.051
8	OFF	OFF	.048	OFF	.049	OFF	.049
9	OFF	OFF	.045	OFF	.050	OFF	.050
10	OFF	.051	OFF	.063	OFF	OFF	.063
11	OFF	OFF	.036	OFF	OFF	OFF	.036
12	OFF	OFF	.037	OFF	OFF	.043	.043
13	OFF	OFF	.051	OFF	OFF	.048	.051
14	OFF	OFF	.095	OFF	OFF	.056	.095
15	OFF	OFF	.051	OFF	.048	OFF	.051
16	OFF	OFF	.051	OFF	OFF	OFF	.051
17	OFF	OFF	.052	OFF	OFF	OFF	.052
18	OFF	OFF	.036	OFF	OFF	OFF	.036
19	OFF	OFF	.034	OFF	OFF	OFF	.034
20	OFF	OFF	.036	OFF	OFF	OFF	.036
21	OFF	.040	OFF	.054	OFF	OFF	.054
22	OFF	OFF	.047	OFF	OFF	OFF	.047
23	OFF	OFF	.040	OFF	OFF	OFF	.040
24	OFF	OFF	.030	OFF	OFF	OFF	.030
25	OFF	OFF	.034	OFF	OFF	OFF	.034
26	OFF	OFF	.035	OFF	OFF	OFF	.035
27	OFF	.034	OFF	.052	OFF	OFF	.052
28	OFF	OFF	.036	.095	OFF	OFF	.095
29	OFF	OFF	.044	OFF	OFF	OFF	.044
30	.040	OFF	OFF	.053	OFF	OFF	.053
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="checkbox"/> Yes / No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / No ²			
Notes:	PRINTED NAME: Robert Fowler		
	SIGNATURE: Robert Fowler	DATE: 10-4-22	
	PHONE #: (571) 679-2549	CERT #: T-08679 D-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 9/2022

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 18:00 AM	1.19	224	266	24.5	6.26	8	Yes	6.7
2 18:00 AM	1.26	224	282	24.8	6.29	8	Yes	6.7
3 18:00 AM	1.23	224	275	24.5	6.30	8	Yes	6.7
4 14:00 AM	1.19	224	266	24.5	6.23	8	Yes	6.7
5 18:00 AM	1.11	224	248	24.7	6.22	8	Yes	6.7
6 18:00 AM	1.05	224	235	23.7	6.23	8	Yes	6.7
7 18:00 AM	1.11	224	248	24.6	6.26	8	Yes	6.7
8 18:00 AM	1.26	224	282	24.2	6.24	8	Yes	6.7
9 18:00 AM	1.29	224	288	23.6	6.14	8	Yes	6.7
10 18:00 AM	1.31	224	293	23.2	6.18	8	Yes	6.7
11 18:00 AM	1.23	224	275	24.2	6.22	8	Yes	6.7
12 18:00 AM	1.15	224	257	23.9	6.25	8	Yes	6.7
13 18:00 AM	1.13	224	253	23.0	6.29	8	Yes	6.7
14 18:00 AM	1.22	224	273	23.1	6.32	8	Yes	6.7
15 18:00 AM	1.36	224	304	23.2	6.24	8	Yes	6.7
16 18:00 AM	1.28	224	286	22.4	6.21	8	Yes	6.7
17 18:00 AM	1.18	224	264	21.3	6.27	8	Yes	6.7
18 18:00 AM	1.01	224	226	21.8	6.33	8	Yes	6.7
19 18:00 AM	1.07	224	239	22.0	6.31	8	Yes	6.7
20 18:00 AM	1.04	224	232	22.3	6.29	8	Yes	6.7
21 18:00 AM	1.09	224	244	22.3	6.24	8	Yes	6.7
22 18:00 AM	1.13	224	253	22.2	6.24	8	Yes	6.7
23 18:00 AM	1.17	224	262	22.2	6.23	8	Yes	6.7
24 18:00 AM	1.19	224	266	22.1	6.23	8	Yes	6.7
25 18:00 AM	1.30	224	291.2	22.0	6.31	8	Yes	6.7
26 18:00 AM	1.14	224	255	21.3	6.27	8	Yes	6.7
27 18:00 AM	1.19	224	266	21.3	6.28	8	Yes	6.7
28 18:00 AM	1.23	224	275	21.3	6.25	8	Yes	6.7
29 18:00 AM	1.48	224	331	21.7	6.22	8	Yes	6.7
30 18:00 AM	1.42	224	318	21.8	6.25	8	Yes	6.7
31 /								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.