

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 10/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	.045	off	OFF	.050	.050
2	OFF	OFF	.039	off	OFF	off	.039
3	off	off	.037	OFF	OFF	.040	.040
4	OFF	OFF	.057	OFF	OFF	OFF	.057
5	.048	OFF	OFF	.051	OFF	OFF	.051
6	OFF	OFF	.050	off	OFF	OFF	.050
7	off	.045	OFF	.060	OFF	OFF	.060
8	OFF	OFF	.037	OFF	OFF	OFF	.037
9	OFF	OFF	.041	OFF	OFF	OFF	.041
10	.048	OFF	OFF	.049	OFF	OFF	.049
11	OFF	.044	OFF	.061	OFF	OFF	.061
12	OFF	OFF	.090	OFF	OFF	OFF	.090
13	OFF	OFF	.050	.061	OFF	OFF	.061
14	OFF	OFF	.043	OFF	OFF	OFF	.043
15	OFF	OFF	.037	OFF	OFF	OFF	.037
16	OFF	OFF	.038	off	off	off	.038
17	OFF	OFF	.036	OFF	OFF	.048	.048
18	OFF	OFF	.043	OFF	OFF	OFF	.043
19	.038	OFF	.054	OFF	OFF	OFF	.054
20	.038	OFF	.047	OFF	OFF	OFF	.047
21	.040	OFF	OFF	.047	OFF	OFF	.047
22	OFF	OFF	.036	OFF	OFF	OFF	.036
23	OFF	OFF	.041	off	off	off	.041
24	off	off	.038	OFF	OFF	OFF	.038
25	OFF	.039	.095	OFF	OFF	OFF	.095
26	OFF	OFF	.047	OFF	OFF	OFF	.047
27	OFF	.038	OFF	.045	OFF	OFF	.045
28	OFF	OFF	.039	OFF	OFF	OFF	.039
29	OFF	OFF	.044	.037	OFF	OFF	.044
30	OFF	OFF	.038	off	.034	off	.038
31	OFF	off	off	.036	OFF	OFF	.036

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		Notes:	
PRINTED NAME: Robert Fowler		SIGNATURE: Robert Fowler	
PHONE #: (541) 679-2549		DATE: 11-1-22	
		CERT #: T-08679 D-08666	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 10/2022

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 12:00AM	1.28	224	286	21.6	6.30	8	Yes	6.7
2 12:00AM	1.18	224	264	21.7	6.29	8	Yes	6.7
3 12:00AM	1.26	224	282	21.9	6.27	8	Yes	6.7
4 12:00AM	1.22	224	273	21.8	6.30	8	Yes	6.7
5 12:00AM	1.31	224	293	21.8	6.30	8	Yes	6.7
6 12:00AM	1.32	224	297	21.5	6.35	8	Yes	6.7
7 12:00AM	1.33	224	297	21.6	6.16	8	Yes	6.7
8 12:00AM	1.32	224	295	21.4	6.13	8	Yes	6.7
9 12:00AM	1.26	224	282	21.4	6.15	8	Yes	6.7
10 12:00AM	1.30	224	291	21.2	6.12	8	Yes	6.7
11 12:00AM	1.39	224	311	21.2	6.16	8	Yes	6.7
12 12:00AM	1.32	224	295	21.0	6.22	8	Yes	6.7
13 12:00AM	1.42	224	318	20.8	6.18	8	Yes	6.7
14 12:00AM	1.31	224	293	20.4	6.22	8	Yes	6.7
15 12:00AM	1.27	224	284	20.5	6.12	8	Yes	6.7
16 12:00AM	1.18	224	264	20.9	6.11	8	Yes	6.7
17 12:00AM	1.20	224	268	20.7	6.11	8	Yes	6.7
18 12:00AM	1.24	224	277	20.8	6.17	8	Yes	6.7
19 12:00AM	1.21	224	271	20.7	6.20	8	Yes	6.7
20 12:00AM	1.28	224	286	20.9	6.57	8	Yes	6.7
21 12:00AM	1.28	224	286	20.8	6.53	8	Yes	6.7
22 12:00AM	1.24	224	277	20.7	6.52	8	Yes	6.7
23 12:00AM	1.28	224	286	20.4	6.61	8	Yes	6.7
24 12:00AM	1.23	224	275	20.6	6.58	8	Yes	6.7
25 12:00AM	1.26	224	282	20.6	6.55	8	Yes	6.7
26 12:00AM	1.34	224	300	20.4	6.63	10	Yes	6.7
27 12:00AM	1.29	224	288	19.8	6.64	13	Yes	6.7
28 12:00AM	1.32	224	295	19.6	6.68	13	Yes	6.7
29 12:00AM	1.25	224	280	19.9	6.70	13	Yes	6.7
30 12:00AM	1.22	224	273	19.6	6.67	13	Yes	6.7
31 12:00AM	1.21	224	271	19.9	6.65	13	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.