

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 11/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	OFF	OFF	OFF	.043	OFF	OFF	.043
2	OFF	OFF	.045	OFF	OFF	OFF	.045
3	OFF	OFF	.043	.046	OFF	OFF	.046
4	OFF	OFF	OFF	.045	OFF	OFF	.045
5	OFF	OFF	.043	OFF	OFF	OFF	.043
6	OFF	OFF	.040	OFF	OFF	OFF	.040
7	OFF	OFF	.040	OFF	OFF	OFF	.040
8	OFF	.039	.106	OFF	OFF	OFF	.106
9	OFF	OFF	.077	.044	OFF	OFF	.077
10	OFF	OFF	.076	.058	OFF	OFF	.076
11	OFF	OFF	.083	.048	OFF	OFF	.083
12	OFF	OFF	OFF	.051	OFF	OFF	.051
13	OFF	OFF	.043	OFF	OFF	OFF	.043
14	OFF	OFF	.041	OFF	OFF	.040	.041
15	OFF	.036	OFF	.037	OFF	OFF	.037
16	OFF	OFF	.035	OFF	OFF	OFF	.035
17	OFF	OFF	.033	OFF	OFF	OFF	.033
18	OFF	OFF	.033	.107	OFF	OFF	.107
19	OFF	OFF	.067	OFF	OFF	OFF	.067
20	OFF	OFF	.054	OFF	OFF	OFF	.054
21	OFF	OFF	.054	OFF	OFF	.052	.054
22	OFF	OFF	OFF	.050	OFF	.050	.050
23	OFF	OFF	OFF	.042	OFF	OFF	.042
24	OFF	OFF	.047	OFF	OFF	OFF	.047
25	OFF	OFF	.048	OFF	OFF	OFF	.048
26	OFF	OFF	.050	OFF	OFF	OFF	.050
27	OFF	OFF	.053	OFF	OFF	OFF	.053
28	OFF	OFF	.053	OFF	OFF	OFF	.053
29	OFF	OFF	.058	.079	OFF	OFF	.079
30	OFF	OFF	.051	OFF	OFF	OFF	.051
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / No ²			
Notes:	PRINTED NAME: ROBERT FOWLER		
	SIGNATURE: <i>Robert Fowler</i>	DATE: 12-1-22	
	PHONE #: (541) 679-2549	CERT #: T-08679 D-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 11/2022

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1 8:00AM	1.11	224	248	19.9	6.66	13	Yes	6.7
2 8:00AM	1.02	224	228	19.7	6.61	13	Yes	6.7
3 8:00AM	1.00	224	224	19.5	6.65	13	Yes	6.7
4 8:00AM	.98	224	219	19.5	6.65	13	Yes	6.7
5 8:00AM	.95	224	212	19.4	6.61	13	Yes	6.7
6 8:00AM	.96	224	215	19.3	6.68	13	Yes	6.7
7 8:00AM	1.03	224	230	19.4	6.74	13	Yes	6.7
8 8:00AM	1.01	224	226	19.4	6.64	13	Yes	6.7
9 8:00AM	1.31	224	293	18.7	6.67	13	Yes	6.7
10 8:00AM	1.36	224	304	17.7	6.65	13	Yes	6.7
11 8:00AM	1.27	224	284	17.4	6.70	13	Yes	6.7
12 8:00AM	1.19	224	266	17.1	6.73	13	Yes	6.7
13 8:00AM	1.13	224	253	17.5	6.76	13	Yes	6.7
14 8:00AM	1.17	224	262	17.2	6.79	13	Yes	6.7
15 8:00AM	1.33	224	297	16.6	6.84	13	Yes	6.7
16 8:00AM	1.39	224	311	16.4	6.85	13	Yes	6.7
17 8:00AM	1.36	224	304.6	16.3	6.97	13	Yes	6.7
18 8:00AM	1.26	224	282	16.1	7.02	13	Yes	6.7
19 8:00AM	1.29	224	288	15.2	7.04	13	Yes	6.7
20 8:00AM	1.17	224	262	15.2	7.09	13	Yes	6.7
21 8:00AM	1.23	224	275	15.6	7.17	13	Yes	6.7
22 8:00AM	1.20	224	268	15.5	7.23	15	Yes	6.7
23 8:00AM	1.21	224	271	15.7	7.20	15	Yes	6.7
24 8:00AM	1.22	224	273	15.3	7.21	15	Yes	6.7
25 8:00AM	1.13	224	253	16.0	7.25	15	Yes	6.7
26 8:00AM	1.07	224	239	15.7	7.24	15	Yes	6.7
27 8:00AM	1.06	224	224	16.3	7.25	13	Yes	6.7
28 8:00AM	1.04	224	232	16.9	7.35	15	Yes	6.7
29 8:00AM	1.06	224	237	16.8	7.21	15	Yes	6.7
30 8:00AM	1.16	224	259	16.8	7.35	15	Yes	6.7
31 /								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.