

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 12/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	off	.054	off	off	.054
2	off	off	.058	.125	off	off	.125
3	off	off	.080	off	off	off	.088
4	off	off	.103	off	off	off	.103
5	off	off	off	.084	off	off	.084
6	off	off	.055	off	off	off	.055
7	off	off	off	.045	off	off	.045
8	off	off	.040	off	off	off	.040
9	off	off	.038	off	off	off	.038
10	off	off	off	.048	off	off	.048
11	off	off	.045	off	off	off	.045
12	off	off	.068	off	.045	off	.068
13	off	off	off	.056	off	off	.056
14	off	off	.047	.189	off	off	.189
15	off	off	.100	off	off	off	.100
16	off	off	.072	.055	off	off	.072
17	off	off	.061	off	off	off	.061
18	off	off	.055	off	off	off	.055
19	off	off	.050	off	off	off	.050
20	off	off	.048	.031	off	off	.048
21	off	off	.046	.155	off	off	.155
22	off	off	off	.085	.042	off	.085
23	off	off	.070	.035	off	off	.070
24	off	off	.068	off	off	off	.068
25	off	off	.067	off	off	off	.067
26	off	off	.066	off	off	off	.066
27	off	off	.063	.050	off	off	.063
28	off	off	.058	.052	off	off	.058
29	off	off	.063	.045	off	off	.063
30	off	off	.066	.046	off	off	.066
31	off	off	.064	off	off	off	.064

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:	PRINTED NAME: Robert Fowler		
	SIGNATURE: Robt Fowler	DATE: 1-3-23	
	PHONE #: (541) 679-2549	CERT #: T-08679 D-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indivd. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 12/2002

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00am	1.18	224	264	16.6	7.31	15	Yes	6.7
2 8:00am	1.24	224	277	16.1	7.26	15	Yes	6.7
3 8:00am	1.31	224	293	15.3	7.28	15	Yes	6.7
4 8:00am	1.29	224	288	15.0	7.34	15	Yes	6.7
5 8:00am	1.21	224	271	14.9	7.41	23	Yes	6.7
6 8:00am	1.17	224	262	14.7	7.38	22	Yes	6.7
7 8:00am	1.11	224	248	14.5	7.42	22	Yes	6.7
8 8:00am	1.08	224	241	14.8	7.40	22	Yes	6.7
9 8:00am	1.11	224	248	14.7	7.38	22	Yes	6.7
10 8:00am	1.12	224	250	14.9	7.45	22	Yes	6.7
11 8:00am	1.13	224	253	14.9	7.41	22	Yes	6.7
12 8:00am	1.13	224	253	15.1	7.35	15	Yes	6.7
13 8:00am	1.21	224	271	15.0	7.35	15	Yes	6.7
14 8:00am	1.15	224	257	14.9	7.30	22	Yes	6.7
15 8:00am	1.28	224	286	14.2	7.25	23	Yes	6.7
16 8:00am	1.28	224	286	13.8	7.28	23	Yes	6.7
17 8:00am	1.17	224	262	13.5	7.34	23	Yes	6.7
18 8:00am	1.11	224	248	13.8	7.33	23	Yes	6.7
19 8:00am	1.15	224	257	13.9	7.33	23	Yes	6.7
20 8:00am	1.08	224	241	14.1	7.33	22	Yes	6.7
21 8:00am	1.21	224	271	14.4	7.30	23	Yes	6.7
22 8:00am	1.42	224	318	13.9	7.30	23	Yes	6.7
23 8:00am	1.46	224	327	13.4	7.36	23	Yes	6.7
24 8:00am	1.44	224	322	13.3	7.37	23	Yes	6.7
25 8:00am	1.35	224	302	14.2	7.40	23	Yes	6.7
26 8:00am	1.37	224	306	14.7	7.51	23	Yes	6.7
27 8:00am	1.33	224	297	15.1	7.55	16	Yes	6.7
28 8:00am	1.36	224	304	15.5	7.34	16	Yes	6.7
29 8:00am	1.44	224	322	15.5	7.38	16	Yes	6.7
30 8:00am	1.46	224	327	16.0	7.30	16	Yes	6.7
31 8:00am	1.47	224	329	16.1	7.24	16	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.