

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 1/2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.065	off	off	off	.065
2	off	off	.065	.047	off	off	.065
3	off	off	.047	off	off	off	.047
4	off	off	.180	off	off	off	.180
5	off	off	.088	.044	off	off	.088
6	off	off	.073	.044	off	off	.073
7	off	off	off	.061	off	off	.061
8	off	off	.057	off	off	off	.057
9	off	off	off	.070	.042	off	.070
10	off	off	.064	.045	off	off	.064
11	off	off	.060	.050	off	off	.060
12	off	off	off	.054	.038	off	.054
13	off	off	.052	.048	off	off	.052
14	off	off	off	.050	off	off	.050
15	off	off	.049	off	off	off	.049
16	off	off	.050	off	off	off	.050
17	off	.051	off	.049	off	off	.051
18	off	off	.048	.185	off	off	.185
19	off	off	.096	.060	off	off	.096
20	off	off	.066	.038	off	off	.066
21	off	off	.059	off	off	off	.059
22	off	off	.044	off	off	off	.044
23	off	off	.056	off	off	off	.056
24	off	off	.054	.044	off	off	.054
25	off	off	.046	.034	off	off	.046
26	off	off	.044	.038	off	off	.044
27	off	off	.045	.039	off	off	.045
28	off	off	.041	off	off	off	.041
29	off	off	.184	off	off	off	.184
30	.098	off	.078	off	off	.075	.078
31	.068	.065	.059	.052	off	off	.068

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / No ²		
Notes:	PRINTED NAME: Robert Fowler	
	SIGNATURE: Robert Fowler	DATE: 2-1-23
	PHONE #: (531) 679-2549	CERT #: T-08679 D-08666

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 1/2023

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/18/2023	1.36	224	304	16.3	7.21	16	Yes	6.7
2/18/2023	1.30	224	291	16.3	7.31	15	Yes	6.7
3/18/2023	1.25	224	280	16.3	7.27	15	Yes	6.7
4/18/2023	1.21	224	271	16.3	7.23	15	Yes	6.7
5/18/2023	1.32	224	295	15.8	7.07	13	Yes	6.7
6/18/2023	1.32	224	295	15.3	7.03	13	Yes	6.7
7/18/2023	1.25	224	280	15.4	7.10	13	Yes	6.7
8/18/2023	1.03	224	230	15.6	7.15	13	Yes	6.7
9/18/2023	1.20	224	268	15.8	7.18	13	Yes	6.7
10/18/2023	1.26	224	282	15.7	7.18	13	Yes	6.7
11/18/2023	1.23	224	275	15.8	7.09	13	Yes	6.7
12/18/2023	1.21	224	271	15.6	7.09	13	Yes	6.7
13/18/2023	1.19	224	266	16.0	7.08	13	Yes	6.7
14/18/2023	1.18	224	264	15.8	7.14	13	Yes	6.7
15/18/2023	1.11	224	248	16.2	7.08	13	Yes	6.7
16/18/2023	1.13	224	253	16.2	6.98	13	Yes	6.7
17/18/2023	1.08	224	241	16.4	6.95	13	Yes	6.7
18/18/2023	1.09	224	244	16.4	7.09	13	Yes	6.7
19/18/2023	1.23	224	275	15.2	7.03	13	Yes	6.7
20/18/2023	1.21	224	271	14.6	7.00	19	Yes	6.7
21/18/2023	1.16	224	259	14.3	7.02	19	Yes	6.7
22/18/2023	1.18	224	264	14.2	7.09	19	Yes	6.7
23/18/2023	1.15	224	257	14.2	7.07	19	Yes	6.7
24/18/2023	1.28	224	286	14.1	7.10	19	Yes	6.7
25/18/2023	1.37	224	306	14.0	7.10	19	Yes	6.7
26/18/2023	1.31	224	293	13.7	7.18	19	Yes	6.7
27/18/2023	1.31	224	255	13.4	7.22	23	Yes	6.7
28/18/2023	1.26	224	282	13.4	7.23	23	Yes	6.7
29/18/2023	1.18	224	264	13.5	7.27	23	Yes	6.7
30/18/2023	1.29	224	288	12.2	7.24	23	Yes	6.7
31/18/2023	1.48	224	331	7.3	7.53	31	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.