

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 2/2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	.050	OFF	.045	OFF	OFF	.051	.051
2	OFF	OFF	.044	OFF	OFF	.042	.044
3	OFF	OFF	.041	.188	OFF	OFF	.188
4	OFF	OFF	.090	OFF	OFF	OFF	.090
5	OFF	OFF	.084	OFF	OFF	OFF	.084
6	OFF	OFF	.060	OFF	.045	OFF	.060
7	OFF	OFF	.065	.058	OFF	OFF	.065
8	OFF	OFF	.080	.083	OFF	OFF	.083
9	OFF	OFF	.066	.040	OFF	OFF	.066
10	OFF	OFF	.050	.038	OFF	OFF	.050
11	OFF	OFF	OFF	.046	OFF	OFF	.046
12	OFF	.047	OFF	.037	OFF	OFF	.047
13	OFF	OFF	.044	.035	OFF	OFF	.044
14	OFF	OFF	.044	.037	OFF	OFF	.044
15	.045	OFF	.042	.170	OFF	OFF	.170
16	.090	OFF	.066	.054	OFF	OFF	.090
17	OFF	.083	.070	OFF	OFF	OFF	.083
18	OFF	OFF	.060	OFF	OFF	OFF	.060
19	OFF	OFF	.059	OFF	OFF	OFF	.059
20	OFF	OFF	.057	.033	OFF	OFF	.057
21	OFF	OFF	.051	.039	OFF	OFF	.051
22	OFF	OFF	.051	.038	OFF	OFF	.051
23	OFF	.052	.038	.048	OFF	OFF	.052
24	OFF	.058	.046	.184	OFF	OFF	.184
25	OFF	.130	OFF	.082	OFF	OFF	.130
26	OFF	OFF	.068	OFF	OFF	OFF	.068
27	OFF	OFF	.066	OFF	OFF	OFF	.066
28	OFF	OFF	.065	.048	OFF	OFF	.065
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / No	
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / No			
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / No ²			
Notes:	PRINTED NAME: <u>Robert Fowler</u>		
	SIGNATURE: <u>Robert Fowler</u>	DATE: <u>3-1-23</u>	
	PHONE #: <u>(541) 679-2549</u>	CERT #: <u>T-08679</u> <u>D-08666</u>	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 2/2023

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00 AM	1.31	224	293	7.8	7.49	31	Yes	6.7
2 8:00 AM	1.28	224	286	8.1	7.54	31	Yes	6.7
3 8:00 AM	1.28	224	286	8.7	7.48	31	Yes	6.7
4 8:00 AM	1.30	224	291	9.6	7.54	31	Yes	6.7
5 8:00 AM	1.25	224	280	10.0	7.56	23	Yes	6.7
6 8:00 AM	1.30	224	291	10.3	7.57	23	Yes	6.7
7 8:00 AM	1.23	224	275	11.5	7.50	23	Yes	6.7
8 8:00 AM	1.22	224	273	11.7	7.54	23	Yes	6.7
9 8:00 AM	1.18	224	264	12.2	7.59	23	Yes	6.7
10 8:00 AM	1.51	224	338	12.8	7.59	23	Yes	6.7
11 8:00 AM	1.16	224	259	13.4	7.51	23	Yes	6.7
12 8:00 AM	1.10	224	246	13.1	7.51	23	Yes	6.7
13 8 AM	1.17	224	262	14.2	7.47	23	Yes	6.7
14 8:00 AM	1.11	224	248	14.2	7.42	23	Yes	6.7
15 8:00 AM	1.23	224	275	14.0	7.39	23	Yes	6.7
16 8:00 AM	1.37	224	306	12.7	7.37	23	Yes	6.7
17 8:00 AM	1.34	224	300	12.1	7.38	23	Yes	6.7
18 8:00 AM	1.28	224	286	12.7	7.35	23	Yes	6.7
19 8:00 AM	1.31	224	293	13.1	7.36	23	Yes	6.7
20 8:00 AM	1.17	224	262	13.2	7.38	23	Yes	6.7
21 8:00 AM	1.23	224	275	13.9	7.48	23	Yes	6.7
22 8:00 AM	1.24	224	277	13.7	7.47	23	Yes	6.7
23 8:00 AM	1.28	224	286	13.6	7.34	23	Yes	6.7
24 8:00 AM	1.50	224	336	13.2	7.31	23	Yes	6.7
25 8:00 AM	1.48	224	331	12.1	7.32	23	Yes	6.7
26 8:00 AM	1.24	224	277	12.1	7.30	23	Yes	6.7
27 8:00 AM	1.34	224	300	12.6	7.39	23	Yes	6.7
28 8:00 AM	1.09	224	244	12.5	7.34	22	Yes	6.7
29 /								
30 /								
31 /								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.