

**OHA - Drinking Water Program -- Turbidity Monitoring Report Form County: Douglas  
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 6/2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	.037	OFF	OFF	OFF	.037
2	.038	OFF	.130	.064	OFF	OFF	.130
3	OFF	OFF	.064	OFF	OFF	OFF	.064
4	OFF	OFF	.043	OFF	OFF	OFF	.043
5	OFF	OFF	.051	OFF	OFF	.053	.053
6	OFF	OFF	.052	OFF	OFF	.073	.073
7	OFF	OFF	.045	OFF	.062	.084	.084
8	OFF	OFF	.051	.063	OFF	OFF	.063
9	OFF	OFF	.058	.062	OFF	OFF	.062
10	OFF	OFF	.036	.095	OFF	OFF	.095
11	OFF	OFF	.041	OFF	OFF	OFF	.041
12	OFF	OFF	.044	OFF	OFF	OFF	.044
13	.063	OFF	.047	OFF	OFF	.051	.063
14	OFF	OFF	.047	.046	OFF	OFF	.047
15	OFF	.060	.065	.054	OFF	OFF	.065
16	OFF	OFF	.045	OFF	OFF	OFF	.045
17	OFF	.050	OFF	.064	OFF	OFF	.064
18	OFF	OFF	.038	OFF	OFF	OFF	.038
19	OFF	OFF	.049	OFF	OFF	OFF	.049
20	OFF	.045	OFF	.099	OFF	OFF	.099
21	OFF	OFF	.054	OFF	.056	OFF	.056
22	OFF	OFF	.055	.054	OFF	OFF	.055
23	.042	OFF	OFF	.051	OFF	OFF	.051
24	OFF	OFF	.036	OFF	OFF	OFF	.036
25	OFF	OFF	.040	OFF	OFF	OFF	.040
26	OFF	OFF	.037	OFF	OFF	OFF	.037
27	OFF	OFF	.060	.062	OFF	OFF	.062
28	OFF	OFF	.040	OFF	OFF	.048	.048
29	OFF	OFF	.043	.053	OFF	OFF	.053
30	OFF	OFF	.042	.044	OFF	OFF	.044
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
Notes:	PRINTED NAME: Robert Fowler	
	SIGNATURE: <i>Robert Fowler</i>	DATE: 7-5-23
	PHONE #: (541) 679-2549	CERT #: T-08679 D-08666

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 6/2023 Required Log Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00 AM	1.15	224	257	19.5	6.96	13	Yes	6.7
2 8:00 AM	1.16	224	259	19.1	6.90	13	Yes	6.7
3 8:00 AM	1.14	224	255	20.0	6.92	10	Yes	6.7
4 8:00 AM	1.03	224	230	20.1	6.89	9	Yes	6.7
5 8:00 AM	.99	224	221	20.5	6.86	9	Yes	6.7
6 8:00 AM	.99	224	221	20.7	6.76	9	Yes	6.7
7 8:00 AM	1.08	224	241	21.4	6.69	9	Yes	6.7
8 8:00 AM	1.13	224	253	22.0	6.74	9	Yes	6.7
9 8:00 AM	1.10	224	246	21.8	6.85	9	Yes	6.7
10 8:00 AM	.90	224	201	22.1	6.87	9	Yes	6.7
11 8:00 AM	.90	224	201	22.0	6.62	9	Yes	6.7
12 8:00 AM	.93	224	208	22.2	6.66	9	Yes	6.7
13 8:00 AM	.93	224	208	22.5	6.68	9	Yes	6.7
14 8:00 AM	.99	224	221	22.5	6.83	9	Yes	6.7
15 8:00 AM	.97	224	217	21.9	6.65	9	Yes	6.7
16 8:00 AM	.93	224	208	22.3	6.62	9	Yes	6.7
17 8:00 AM	.88	224	197	22.6	6.51	8	Yes	6.7
18 8:00 AM	.85	224	190	21.8	6.52	8	Yes	6.7
19 8:00 AM	.84	224	188	21.0	6.75	9	Yes	6.7
20 8:00 AM	.85	224	190	21.6	6.50	8	Yes	6.7
21 8:00 AM	1.14	224	255	20.7	6.62	9	Yes	6.7
22 8:00 AM	1.00	224	224	20.8	6.58	8	Yes	6.7
23 8:00 AM	.92	224	206	21.6	6.66	9	Yes	6.7
24 8:00 AM	.91	224	203	21.5	6.64	9	Yes	6.7
25 8:00 AM	.75	224	168	21.4	6.61	9	Yes	6.7
26 8:00 AM	.78	224	174	21.3	6.42	8	Yes	6.7
27 8:00 AM	.71	224	159	21.7	6.48	8	Yes	6.7
28 8:00 AM	1.03	224	230	21.9	6.36	8	Yes	6.7
29 8:00 AM	1.30	224	291	22.6	6.40	8	Yes	6.7
30 8:00 AM	1.19	224	266	23.4	6.32	8	Yes	6.7
31 /								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.