

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas  
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-:WTP-A Month/Year: 9/2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	OFF	OFF	.091	OFF	OFF	OFF	.091
2	OFF	.043	OFF	OFF	.044	OFF	.044
3	OFF	OFF	OFF	.047	OFF	OFF	.047
4	OFF	OFF	OFF	.039	OFF	OFF	.039
5	OFF	OFF	.037	OFF	OFF	OFF	.037
6	OFF	OFF	.038	.092	OFF	OFF	.092
7	OFF	OFF	.048	OFF	OFF	OFF	.048
8	OFF	.041	OFF	.054	OFF	OFF	.054
9	OFF	OFF	OFF	.037	OFF	OFF	.037
10	OFF	OFF	.040	OFF	OFF	OFF	.040
11	OFF	OFF	.035	OFF	OFF	OFF	.035
12	OFF	OFF	.049	.048	.050	OFF	.050
13	OFF	OFF	.043	OFF	OFF	OFF	.043
14	OFF	OFF	.039	OFF	OFF	OFF	.039
15	OFF	.045	OFF	.062	OFF	OFF	.062
16	OFF	OFF	.040	OFF	OFF	OFF	.040
17	OFF	OFF	.037	OFF	OFF	OFF	.037
18	OFF	OFF	.036	OFF	.042	OFF	.042
19	OFF	OFF	.052	OFF	OFF	.059	.059
20	OFF	OFF	.098	OFF	OFF	.050	.098
21	OFF	OFF	.047	OFF	OFF	OFF	.047
22	OFF	.052	OFF	.057	OFF	OFF	.057
23	OFF	OFF	.040	OFF	OFF	OFF	.040
24	OFF	OFF	.038	OFF	OFF	OFF	.038
25	OFF	OFF	.035	OFF	OFF	OFF	.035
26	OFF	OFF	.042	.053	OFF	OFF	.053
27	OFF	OFF	.057	OFF	OFF	OFF	.057
28	OFF	.042	OFF	.054	OFF	OFF	.054
29	OFF	OFF	.038	OFF	OFF	OFF	.038
30	OFF	OFF	.041	OFF	OFF	OFF	.041
31							

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:	PRINTED NAME: Robert Fowler		
	SIGNATURE: <i>Robert Fowler</i>	DATE: 10-3-23	
	PHONE #: (541) 679-2549	CERT #: T-08679 D-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program -- Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 9/2023

Required Log Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1 8:00 AM	1.00	224	224	23.1	6.25	8	Yes	6.7
2 8:00 AM	1.19	224	266	23.3	6.23	8	Yes	6.7
3 8:00 AM	.99	224	221	23.4	6.22	8	Yes	6.7
4 8:00 AM	1.02	224	228	23.2	6.22	8	Yes	6.7
5 8:00 AM	.90	224	201	23.3	6.21	8	Yes	6.7
6 8:00 AM	.84	224	188	23.7	6.28	8	Yes	6.7
7 8:00 AM	1.05	224	235	22.9	6.23	8	Yes	6.7
8 8:00 AM	1.03	224	230	23.0	6.22	8	Yes	6.7
9 8:00 AM	.91	224	203	23.1	6.22	8	Yes	6.7
10 8:00 AM	.83	224	185	22.8	6.23	8	Yes	6.7
11 8:00 AM	.83	224	185	22.6	6.24	8	Yes	6.7
12 8:00 AM	.80	224	179	22.4	6.29	8	Yes	6.7
13 8:00 AM	1.09	224	244	23.2	6.20	8	Yes	6.7
14 8:00 AM	1.06	224	237	22.4	6.23	8	Yes	6.7
15 8:00 AM	.95	224	212	20.5	6.95	9	Yes	6.7
16 8:00 AM	.91	224	203	20.9	6.95	9	Yes	6.7
17 8:00 AM	.80	224	179	22.9	6.97	9	Yes	6.7
18 8:00 AM	.85	224	190	22.9	6.94	9	Yes	6.7
19 8:00 AM	.86	224	192	22.4	6.89	9	Yes	6.7
20 8:00 AM	.98	224	219	20.1	6.99	9	Yes	6.7
21 8:00 AM	1.11	224	248	20.5	7.17	11	Yes	6.7
22 8:00 AM	1.03	224	230	21.6	7.01	9	Yes	6.7
23 8:00 AM	.94	224	210	22.3	6.98	9	Yes	6.7
24 8:00 AM	.88	224	197	22.8	6.99	9	Yes	6.7
25 8:00 AM	.83	224	185	22.6	6.99	9	Yes	6.7
26 8:00 AM	.77	224	172	22.6	6.98	9	Yes	6.7
27 8:00 AM	.91	224	203	22.8	7.00	9	Yes	6.7
28 8:00 AM	.96	224	215	20.7	6.98	9	Yes	6.7
29 8:00 AM	.98	224	219	21.8	6.97	9	Yes	6.7
30 8:00 AM	.94	224	210	20.9	6.97	9	Yes	6.7
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.