

**OHA - Drinking Water Program -- Turbidity Monitoring Report Form County: Douglas  
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 10/2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	off	off	.045	off	off	off	.045
2	off	off	.050	off	off	off	.050
3	off	.042	.100	off	off	off	.100
4	.050	off	.053	off	off	off	.053
5	off	.056	.054	off	off	off	.056
6	off	off	.042	off	off	off	.042
7	.043	off	off	.049	off	off	.049
8	off	off	.039	off	off	off	.039
9	off	off	.046	off	off	off	.046
10	off	.040	off	.048	off	off	.048
11	off	off	.038	.046	off	off	.046
12	off	off	.039	.050	off	off	.050
13	off	off	.043	.050	off	off	.050
14	off	off	.042	off	off	off	.042
15	off	off	.038	off	off	off	.038
16	off	off	.036	off	off	off	.036
17	off	.038	.102	.059	off	off	.102
18	off	off	.055	.056	off	off	.056
19	off	off	.053	.063	off	off	.063
20	off	off	.053	.064	off	off	.064
21	off	off	.053	off	off	off	.053
22	off	off	.067	off	off	off	.067
23	off	off	.045	off	off	off	.045
24	off	.050	.052	.056	off	off	.056
25	off	off	.043	.051	off	off	.051
26	off	off	.045	.050	off	off	.050
27	off	off	.041	.049	off	off	.049
28	off	off	off	.135	off	off	.135
29	off	off	.064	off	off	off	.064
30	off	off	.051	off	off	off	.051
31	off	off	.053	.049	off	off	.053

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No <sup>2</sup>			
Notes:	PRINTED NAME: <i>Robert Fowler</i>		
	SIGNATURE: <i>Robert Fowler</i>	DATE: 11-1-23	
	PHONE #: (541) 679-2549	CERT #: T-08679 D-08666	

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C)).

## OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 10/2023

Required Log Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00 AM	.98	224	219	21.6	6.94	9	YES	6.7
2 8:00 AM	.88	224	197	21.8	6.95	9	YES	6.7
3 8:00 AM	.88	224	197	21.2	7.17	11	Yes	6.7
4 8:00 AM	1.11	224	248	20.9	7.01	9	Yes	6.7
5 8:00 AM	1.10	224	246	21.2	6.98	9	Yes	6.7
6 8:00 AM	1.03	224	230	20.9	6.96	9	Yes	6.7
7 8:00 AM	1.02	224	228	21.0	6.97	9	Yes	6.7
8 8:00 AM	.99	224	221	21.6	6.96	9	YES	6.7
9 8:00 AM	.96	224	215	21.8	6.96	9	YES	6.7
10 8:00 AM	1.03	224	230	21.3	7.01	9	Yes	6.7
11 8:00 AM	1.04	224	232	20.6	7.01	9	Yes	6.7
12 8:00 AM	1.04	224	232	20.7	7.01	9	Yes	6.7
13 8:00 AM	.99	224	221	21.0	6.99	9	Yes	6.7
14 8:00 AM	.96	224	215	20.4	7.00	9	Yes	6.7
15 8:00 AM	.90	224	201	21.0	6.97	9	YES	6.7
16 8:00 AM	.82	224	183	21.3	6.97	9	YES	6.7
17 8:00 AM	.95	224	212	21.3	7.14	9	Yes	6.7
18 8:00 AM	1.48	224	331	20.4	7.01	10	Yes	6.7
19 8:00 AM	1.61	224	360	20.5	7.03	10	Yes	6.7
20 8:00 AM	1.60	224	358	21.0	7.01	10	Yes	6.7
21 8:00 AM	1.54	224	344	20.6	7.01	10	Yes	6.7
22 8:00 AM	1.46	224	327	20.8	7.01	10	YES	6.7
23 8:00 AM	1.41	224	315	20.7	7.00	10	YES	6.7
24 8:00 AM	1.23	224	275	20.0	6.99	10	Yes	6.7
25 8:00 AM	1.13	224	253	20.2	6.98	10	Yes	6.7
26 8:00 AM	1.06	224	237	19.4	6.98	13	Yes	6.7
27 8:00 AM	.94	224	210	20.7	7.00	9	Yes	6.7
28 8:00 AM	.85	224	190	20.9	6.99	9	Yes	6.7
29 8:00 AM	.83	224	185	20.3	6.97	9	YES	6.7
30 8:00 AM	.77	224	172	20.5	7.01	9	YES	6.7
31 8:00 AM	.87	224	194	19.0	7.00	12	Yes	6.7

<sup>3</sup>If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.