

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 1/2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	.064	OFF	OFF	OFF	.064
2	OFF	OFF	.065	.045	OFF	OFF	.065
3	OFF	OFF	.058	.045	OFF	OFF	.058
4	OFF	OFF	.056	.047	OFF	OFF	.056
5	OFF	OFF	.054	.041	OFF	OFF	.054
6	OFF	OFF	OFF	.077	OFF	OFF	.077
7	OFF	OFF	.057	OFF	OFF	OFF	.057
8	OFF	OFF	.069	.058	OFF	OFF	.069
9	OFF	OFF	.066	.047	OFF	OFF	.066
10	OFF	OFF	.068	.048	OFF	OFF	.068
11	OFF	OFF	OFF	.068	OFF	OFF	.068
12	OFF	OFF	OFF	.190	OFF	OFF	.190
13	OFF	OFF	OFF	.125	OFF	OFF	.125
14	OFF	OFF	.104	OFF	OFF	OFF	.104
15	OFF	OFF	.094	.050	OFF	OFF	.094
16	OFF	OFF	OFF	.088	.041	OFF	.088
17	OFF	OFF	.060	.049	OFF	OFF	.060
18	OFF	OFF	.061	.040	OFF	OFF	.061
19	OFF	OFF	.058	.036	OFF	OFF	.058
20	OFF	OFF	.049	OFF	OFF	OFF	.049
21	OFF	OFF	.050	OFF	OFF	OFF	.050
22	OFF	OFF	.046	.040	OFF	OFF	.046
23	OFF	OFF	.170	.047	OFF	OFF	.170
24	OFF	OFF	.078	.048	OFF	OFF	.078
25	OFF	OFF	.079	.041	OFF	OFF	.079
26	OFF	OFF	.061	.040	OFF	OFF	.061
27	OFF	OFF	.058	OFF	OFF	OFF	.058
28	OFF	OFF	.054	OFF	OFF	OFF	.054
29	OFF	OFF	.057	OFF	.045	OFF	.057
30	OFF	OFF	.049	.044	OFF	OFF	.049
31	OFF	OFF	.049	.044	OFF	OFF	.049

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		Notes:	
PRINTED NAME: Robert Fowler		SIGNATURE: Robert Fowler	
PHONE #: (541) 1679-2549		DATE: 2-1-24	
		CERT #: T-08679 0-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:- WTP-A Month/Year: 1/2024 Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00am	1.06	224	237	17.3	7.30	15	Yes	6.7
2 8:00am	1.06	224	237	17.5	7.33	15	Yes	6.7
3 8:00am	1.04	224	232	17.3	7.33	15	Yes	6.7
4 8:00am	1.00	224	224	17.2	7.32	15	Yes	6.7
5 8:00am	.97	224	217	16.8	7.30	15	Yes	6.7
6 8:00am	.99	224	221	16.4	7.28	15	Yes	6.7
7 8:00am	.97	224	217	18.1	7.28	15	Yes	6.7
8 8:00am	1.01	224	226	15.9	7.26	15	Yes	6.7
9 8:00am	.96	224	215	17.4	7.39	15	Yes	6.7
10 8:00am	.98	224	219	16.2	7.34	15	Yes	6.7
11 8:00am	.96	224	215	16.6	7.32	15	Yes	6.7
12 8:00am	.95	224	212	16.1	7.31	15	Yes	6.7
13 8:00am	.98	224	219	15.5	7.28	15	Yes	6.7
14 8:00am	1.00	224	224	17.1	7.53	15	Yes	6.7
15 8:00am	.92	224	206	16.0	7.24	15	Yes	6.7
16 8:00am	.75	224	168	15.3	7.25	15	Yes	6.7
17 8:00am	.75	224	168	15.1	7.27	15	Yes	6.7
18 8:00am	.74	224	165	16.1	7.26	15	Yes	6.7
19 8:00am	.86	224	192	15.9	7.25	15	Yes	6.7
20 8:00am	.96	224	215	16.0	7.23	15	Yes	6.7
21 8:00am	1.01	224	226	17.8	7.37	15	Yes	6.7
22 8:00am	1.05	224	235	18.3	7.23	15	Yes	6.7
23 8:00am	1.12	224	250	17.0	7.23	15	Yes	6.7
24 8:00am	1.40	224	313	17.4	7.26	16	Yes	6.7
25 8:00am	1.39	224	311	16.4	7.25	16	Yes	6.7
26 8:00am	1.23	224	275	16.8	7.24	15	Yes	6.7
27 8:00am	1.16	224	259	17.6	7.24	15	Yes	6.7
28 8:00am	1.12	224	250	17.9	7.17	15	Yes	6.7
29 8:00am	1.05	224	235	18.5	7.21	15	Yes	6.7
30 8:00am	1.00	224	224	18.3	7.25	15	Yes	6.7
31 8:00am	.99	224	221	19.4	7.25	15	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.