

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas  
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 1/2024



DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	.046	.033	OFF	OFF	.046
2	OFF	OFF	.041	.036	OFF	OFF	.041
3	OFF	OFF	OFF	.175	OFF	OFF	.175
4	OFF	.057	OFF	OFF	.036	OFF	.057
5	OFF	OFF	.063	OFF	.039	OFF	.063
6	OFF	OFF	.056	.034	OFF	OFF	.056
7	OFF	OFF	.064	.042	OFF	OFF	.064
8	OFF	OFF	.056	.042	OFF	OFF	.056
9	OFF	OFF	.055	.042	OFF	OFF	.055
10	OFF	OFF	.050	OFF	OFF	OFF	.050
11	OFF	OFF	.052	OFF	OFF	OFF	.052
12	OFF	OFF	.050	OFF	.039	OFF	.050
13	OFF	OFF	.045	.034	OFF	OFF	.045
14	OFF	OFF	.046	.034	OFF	OFF	.046
15	OFF	OFF	.044	.039	OFF	OFF	.044
16	OFF	OFF	.043	.038	OFF	OFF	.043
17	OFF	OFF	.173	OFF	OFF	OFF	.173
18	OFF	OFF	.089	OFF	OFF	OFF	.089
19	OFF	OFF	.075	OFF	.039	OFF	.075
20	OFF	OFF	.056	.054	OFF	OFF	.056
21	OFF	OFF	.049	.048	OFF	OFF	.049
22	OFF	OFF	.050	.044	OFF	OFF	.050
23	OFF	OFF	.046	.040	OFF	OFF	.046
24	OFF	OFF	.043	OFF	OFF	OFF	.043
25	OFF	OFF	.044	OFF	OFF	OFF	.044
26	OFF	OFF	.045	.041	OFF	.043	.045
27	OFF	OFF	.042	.169	OFF	OFF	.169
28	OFF	OFF	.081	.044	OFF	OFF	.081
29	OFF	OFF	.083	.057	OFF	OFF	.083
30							
31							

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes / No <sup>2</sup>			
Notes:	PRINTED NAME: <i>Robert Fowler</i>		
	SIGNATURE: <i>Robert Fowler</i>	DATE: <i>3-1-24</i>	
	PHONE #: <i>(571) 679-2549</i>	CERT #: <i>T-08679 D-08666</i>	

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)).

## OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 2/2024

Required Log Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00AM	.97	224	217	18.7	7.22	15	Yes	6.7
2 8:00AM	.99	224	221	18.7	7.20	15	Yes	6.7
3 8:00AM	1.01	224	226	17.8	7.19	15	Yes	6.7
4 8:00AM	.96	224	215	18.4	7.19	15	Yes	6.7
5 8:00AM	.91	224	203	17.8	7.17	15	Yes	6.7
6 8:00AM	.95	224	212	17.5	7.24	15	Yes	6.7
7 8:00AM	.94	224	210	16.8	7.21	15	Yes	6.7
8 8:00AM	1.04	224	232	17.5	7.22	15	Yes	6.7
9 8:00AM	1.02	224	228	17.0	7.21	15	Yes	6.7
10 8:00AM	1.01	224	226	16.7	7.21	15	Yes	6.7
11 8:00AM	1.00	224	224	17.7	7.18	15	Yes	6.7
12 8:00AM	.96	224	215	18.4	7.17	15	Yes	6.7
13 8:00AM	.91	224	203	19.3	7.26	15	Yes	6.7
14 8:00AM	.88	224	179	18.8	7.20	15	Yes	6.7
15 8:00AM	.86	224	192	17.3	7.22	15	Yes	6.7
16 8:00AM	.91	224	203	18.3	7.23	15	Yes	6.7
17 8:00AM	.93	224	208	17.7	7.21	15	Yes	6.7
18 8:00AM	1.09	224	244	18.2	7.17	15	Yes	6.7
19 8:00AM	1.17	224	262	18.7	7.19	15	Yes	6.7
20 8:00AM	1.24	224	277	18.1	7.19	15	Yes	6.7
21 8:00AM	1.21	224	271	18.0	7.31	15	Yes	6.7
22 8:00AM	1.19	224	266	17.5	7.30	15	Yes	6.7
23 8:00AM	1.12	224	250	18.2	7.27	15	Yes	6.7
24 8:00AM	1.03	224	230	17.2	7.24	15	Yes	6.7
25 8:00AM	1.02	224	228	18.2	7.24	15	Yes	6.7
26 8:00AM	.89	224	199	19.0	7.24	15	Yes	6.7
27 8:00AM	1.01	224	226	17.1	7.08	15	Yes	6.7
28 8:00AM	1.11	224	248	16.1	7.26	15	Yes	6.7
29 8:00AM	1.12	224	250	16.6	7.25	15	Yes	6.7
30 /								
31 /								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.