

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 3/2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	.078	.046	OFF	OFF	.078
2	OFF	OFF	.071	off	off	off	.071
3	off	off	.074	off	off	off	.074
4	off	off	.078	.056	off	off	.078
5	OFF	OFF	.076	.056	OFF	OFF	.076
6	OFF	OFF	.071	.055	OFF	OFF	.071
7	OFF	OFF	.068	.045	OFF	off	.068
8	off	off	.068	.051	off	off	.068
9	off	off	.056	off	off	off	.056
10	off	off	off	.145	off	off	.145
11	off	off	.081	.075	OFF	OFF	.081
12	OFF	OFF	.080	.061	OFF	OFF	.080
13	OFF	OFF	.068	.060	OFF	OFF	.068
14	OFF	OFF	.066	.055	OFF	OFF	.066
15	OFF	OFF	.061	.044	OFF	OFF	.061
16	OFF	OFF	.070	off	off	off	.070
17	off	off	.056	off	off	off	.056
18	off	off	.045	.040	off	off	.045
19	off	off	.042	.037	OFF	OFF	.042
20	OFF	OFF	.040	.034	OFF	OFF	.040
21	OFF	OFF	.043	.034	OFF	OFF	.043
22	OFF	OFF	.038	.031	OFF	OFF	.038
23	OFF	OFF	.155	off	off	off	.155
24	off	off	.061	off	off	off	.061
25	off	off	.062	.045	off	off	.062
26	OFF	OFF	.062	.047	OFF	OFF	.062
27	OFF	OFF	.054	.040	off	off	.054
28	off	off	.061	.053	OFF	OFF	.061
29	OFF	OFF	.053	.038	OFF	OFF	.053
30	OFF	OFF	.046	off	off	off	.046
31	off	off	.054	off	off	off	.054

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	Notes:		
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	PRINTED NAME: <u>Robert Fowler</u>		
	SIGNATURE: <u>Robert Fowler</u>	DATE: <u>4-2-24</u>	
	PHONE #: <u>(531) 1679-2529</u>	CERT #: <u>T-08679</u> <u>D-08666</u>	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program -- Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 3/2024 Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1 8:00 AM	1.17	224	262	16.7	7.26	15	Yes	6.7
2 8:00 AM	1.08	224	241	15.3	7.26	15	Yes	6.7
3 8:00 AM	1.11	224	248	17.2	7.25	15	Yes	6.7
4 8:00 AM	1.10	224	246	15.7	7.20	15	Yes	6.7
5 8:00 AM	1.03	224	230	16.5	7.29	15	Yes	6.7
6 8:00 AM	1.05	224	235	16.7	7.26	15	Yes	6.7
7 8:00 AM	1.04	224	232	15.3	7.29	15	Yes	6.7
8 8:00 AM	1.06	224	237	16.1	7.28	15	Yes	6.7
9 8:00 AM	1.04	224	232	16.6	7.29	15	Yes	6.7
10 8:00 AM	1.05	224	235	20.1	7.28	11	Yes	6.7
11 8:00 AM	1.12	224	250	16.8	7.22	15	Yes	6.7
12 8:00 AM	1.17	224	262	15.5	7.27	15	Yes	6.7
13 8:00 AM	1.28	224	286	16.2	7.31	15	Yes	6.7
14 8:00 AM	1.42	224	318	16.0	7.31	16	Yes	6.7
15 8:00 AM	1.51	224	338	16.6	7.31	16	Yes	6.7
16 8:00 AM	1.42	224	318	16.0	7.28	16	Yes	6.7
17 8:00 AM	1.39	224	311	18.2	7.22	16	Yes	6.7
18 8:00 AM	1.28	224	286	18.8	7.24	15	Yes	6.7
19 8:00 AM	1.20	224	268	18.8	7.22	15	Yes	6.7
20 8:00 AM	.99	224	221	18.9	7.28	15	Yes	6.7
21 8:00 AM	.95	224	212	18.8	7.27	15	Yes	6.7
22 8:00 AM	.95	224	212	19.2	7.26	15	Yes	6.7
23 8:00 AM	.94	224	210	19.1	7.24	15	Yes	6.7
24 8:00 AM	.96	224	215	18.9	7.19	15	Yes	6.7
25 8:00 AM	1.00	224	224	20.0	7.24	11	Yes	6.7
26 8:00 AM	.98	224	219	19.1	7.29	15	Yes	6.7
27 8:00 AM	.99	224	221	19.8	7.26	15	Yes	6.7
28 8:00 AM	1.00	224	224	19.4	7.24	15	Yes	6.7
29 8:00 AM	.97	224	217	17.4	7.22	15	Yes	6.7
30 8:00 AM	.97	224	217	18.4	7.22	15	Yes	6.7
31 8:00 AM	.97	224	217	19.4	7.17	15	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.