

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-:WTP-A Month/Year: 4/2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.057	.035	OFF	OFF	.057
2	OFF	OFF	.048	.038	OFF	OFF	.048
3	OFF	OFF	.046	.033	OFF	OFF	.046
4	OFF	OFF	.045	.033	OFF	OFF	.045
5	OFF	OFF	.043	.037	OFF	OFF	.043
6	OFF	OFF	.170	off	off	off	.170
7	off	off	.068	off	off	off	.068
8	off	off	.070	.040	OFF	OFF	.070
9	OFF	OFF	.063	.044	OFF	OFF	.063
10	OFF	OFF	.070	.049	OFF	OFF	.070
11	OFF	OFF	.055	.048	OFF	OFF	.055
12	OFF	OFF	.055	.040	OFF	OFF	.055
13	OFF	OFF	.054	off	off	off	.054
14	off	off	.052	off	off	off	.052
15	off	off	.052	.046	OFF	OFF	.052
16	OFF	OFF	.044	.048	off	off	.048
17	off	off	.066	.045	OFF	OFF	.066
18	OFF	OFF	.049	.041	OFF	OFF	.049
19	OFF	OFF	.047	.160	OFF	OFF	.160
20	OFF	OFF	.066	off	off	off	.066
21	off	off	.055	off	off	off	.055
22	off	off	.052	.050	off	off	.052
23	off	off	.047	.043	OFF	OFF	.047
24	OFF	OFF	.051	.039	OFF	OFF	.051
25	OFF	OFF	.042	.041	OFF	OFF	.042
26	OFF	OFF	.041	.037	OFF	OFF	.041
27	OFF	OFF	.040	off	off	off	.040
28	off	off	.040	OFF	OFF	OFF	.040
29	OFF	OFF	.052	.053	OFF	OFF	.053
30	OFF	OFF	.047	.040	OFF	OFF	.047
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:	PRINTED NAME: Robert Fowler		
	SIGNATURE: <i>Robert Fowler</i>	DATE: 5-1-24	
	PHONE #: (521) 679-2549	CERT #: T-08679 D-08666	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²IFE = Indivd. Filter Eff. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 4/2024

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1 8:00am	.90	224	201	19.7	7.17	15	Yes	6.7
2 8:00am	.85	224	190	19.6	7.28	15	Yes	6.7
3 8:00am	.88	224	197	20.3	7.25	11	Yes	6.7
4 8:00am	.88	224	197	20.1	7.23	11	Yes	6.7
5 8:00am	.91	224	203	19.9	7.24	15	Yes	6.7
6 8:00am	.96	224	215	19.9	7.23	15	Yes	6.7
7 8:00am	1.02	224	228	19.5	7.17	15	Yes	6.7
8 8:00am	1.05	224	235	19.3	7.18	15	Yes	6.7
9 8:00am	1.05	224	235	19.8	7.30	15	Yes	6.7
10 8:00am	1.07	224	239	19.6	7.24	15	Yes	6.7
11 8:00am	1.10	224	246	19.6	7.28	15	Yes	6.7
12 8:00am	1.09	224	244	19.3	7.43	15	Yes	6.7
13 8:00am	1.09	224	244	19.6	7.42	15	Yes	6.7
14 8:00am	1.10	224	246	19.2	7.37	15	Yes	6.7
15 8:00am	1.03	224	230	19.0	7.38	15	Yes	6.7
16 8:00am	.93	224	208	19.5	7.45	15	Yes	6.7
17 8:00am	.89	224	199	18.0	7.40	15	Yes	6.7
18 8:00am	.90	224	201	17.9	7.36	15	Yes	6.7
19 8:00am	.90	224	201	19.0	7.39	15	Yes	6.7
20 8:00am	1.19	224	266	19.0	7.35	15	Yes	6.7
21 8:00am	.99	224	221	18.3	7.34	15	Yes	6.7
22 8:00am	1.01	224	226	17.9	7.30	15	Yes	6.7
23 8:00am	1.01	224	226	18.2	7.32	15	Yes	6.7
24 8:00am	1.01	224	226	19.1	7.28	15	Yes	6.7
25 8:00am	1.00	224	224	19.1	7.29	15	Yes	6.7
26 8:00am	1.01	224	226	19.2	7.27	15	Yes	6.7
27 8:00am	.96	224	215	18.9	7.26	15	Yes	6.7
28 8:00am	.98	224	219	19.4	7.19	15	Yes	6.7
29 8:00am	1.01	224	226	19.2	7.25	15	Yes	6.7
30 8:00am	.90	224	201	19.4	7.29	15	Yes	6.7
31 /								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.