

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 6/2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.045	off	off	off	.045
2	off	off	.044	off	off	off	.044
3	off	off	.042	.048	off	off	.048
4	off	off	.045	.096	off	off	.096
5	off	off	.053	.055	off	off	.055
6	off	off	.047	.048	off	off	.048
7	off	off	.056	.050	off	off	.056
8	off	off	.051	off	off	off	.051
9	off	off	.048	off	off	off	.048
10	off	off	.042	.048	off	off	.048
11	off	off	.058	.054	off	off	.058
12	off	off	.040	.040	off	off	.040
13	off	off	.039	.042	off	off	.042
14	off	off	.039	.040	off	off	.040
15	off	off	.041	off	off	off	.041
16	off	off	.047	off	off	off	.047
17	.047	off	.047	.047	off	off	.047
18	off	off	.038	.042	off	off	.042
19	off	off	.037	.043	off	off	.043
20	off	off	.037	.099	off	off	.099
21	off	off	.041	.045	off	off	.045
22	off	off	.038	off	off	off	.038
23	off	off	.038	.050	off	off	.050
24	off	off	.036	.042	off	off	.042
25	off	off	.038	.038	off	off	.038
26	off	off	.038	.045	off	off	.045
27	off	off	.041	.040	off	off	.041
28	off	off	.039	.040	off	off	.040
29	off	off	.038	off	off	off	.038
30	off	off	off	.040	off	off	.040
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / No ²			
Notes:	PRINTED NAME: Robert Fowler		
	SIGNATURE: Robert Fowler	DATE: 7-2-24	
	PHONE #: (571) 1679-2549	CERT #: T-08679 D-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 6/2024

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 18:00A	1.03	224	230	19.1	7.11	13	Yes	6.7
2 18:00A	1.04	224	232	19.9	7.06	13	Yes	6.7
3 18:00A	.98	224	219	19.8	7.06	13	Yes	6.7
4 18:00A	.81	224	181	20.1	7.11	9	Yes	6.7
5 18:00A	.84	224	188	20.4	7.12	9	Yes	6.7
6 18:00A	.81	224	181	20.3	7.08	9	Yes	6.7
7 18:00A	.77	224	172	20.6	7.07	9	Yes	6.7
8 18:00A	.71	224	159	21.5	7.07	9	Yes	6.7
9 18:00A	.78	224	174	21.1	7.02	9	Yes	6.7
10 18:00A	.72	224	161	21.3	7.01	9	Yes	6.7
11 18:00A	.85	224	190	21.4	7.09	9	Yes	6.7
12 18:00A	1.04	224	232	21.1	7.10	9	Yes	6.7
13 18:00A	1.18	224	264	21.4	7.09	10	Yes	6.7
14 18:00A	1.18	224	264	20.8	7.07	10	Yes	6.7
15 18:00A	1.11	224	248	20.0	7.07	10	Yes	6.7
16 18:00A	1.06	224	237	17.9	7.01	13	Yes	6.7
17 18:00A	.90	224	201	17.5	7.02	13	Yes	6.7
18 18:00A	.83	224	185	18.4	7.10	12	Yes	6.7
19 18:00A	.81	224	181	19.6	7.11	12	Yes	6.7
20 18:00A	.81	224	181	20.5	7.11	9	Yes	6.7
21 18:00A	.95	224	212	21.1	7.10	9	Yes	6.7
22 18:00A	.89	224	199	21.3	7.08	9	Yes	6.7
23 18:00A	.83	224	185	22.2	7.04	9	Yes	6.7
24 18:00A	.92	224	206	20.8	7.06	9	Yes	6.7
25 18:00A	.85	224	190	21.4	7.14	9	Yes	6.7
26 18:00A	.84	224	188	22.5	7.13	9	Yes	6.7
27 18:00A	.84	224	188	21.7	7.10	9	Yes	6.7
28 18:00A	.83	224	185	21.2	7.11	9	Yes	6.7
29 18:00A	.80	224	179	21.8	7.10	9	Yes	6.7
30 18:00A	.77	224	172	21.3	7.09	9	Yes	6.7
31 /								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.