

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 7/2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	off	off	.037	.041	off	off	.041
2	off	off	.039	.048	off	off	.048
3	off	off	.075	.071	off	off	.075
4	off	off	.065	off	off	off	.065
5	off	off	.045	off	off	off	.045
6	off	off	.039	off	off	off	.039
7	off	off	.040	off	off	off	.040
8	off	off	.038	.054	off	off	.054
9	off	off	.040	.059	off	.048	.059
10	off	off	.047	.055	off	.050	.055
11	off	off	.062	.041	off	off	.062
12	.044	off	.058	.095	off	off	.095
13	off	off	.042	off	off	off	.042
14	off	off	.042	off	off	off	.042
15	off	off	.041	.056	off	off	.056
16	off	off	.071	.060	off	off	.071
17	off	.060	off	.056	off	off	.060
18	off	.059	off	.055	off	.068	.068
19	off	off	off	.051	off	off	.051
20	off	off	.044	off	off	off	.044
21	off	off	.045	off	off	off	.045
22	off	off	.041	.097	off	off	.097
23	off	.052	off	.056	off	off	.056
24	off	off	.051	off	.051	off	.051
25	off	off	.044	.053	off	off	.053
26	off	off	.065	.065	off	off	.065
27	off	off	.044	off	off	off	.044
28	off	off	.040	off	off	off	.040
29	off	off	.042	.052	off	off	.052
30	off	off	.044	off	.056	off	.056
31	off	off	off	.051	.090	off	.090

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		Notes:	
PRINTED NAME: Robert Fowler		SIGNATURE: Robert Fowler	
PHONE #: (541) 679-2549		DATE: 8-1-24	
		CERT #: 7-08679 0-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 7/2024 Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1 18:00 AM	.83	224	185	21.4	7.07	9	Yes	6.7
2 18:00 AM	.80	224	179	22.6	7.12	9	Yes	6.7
3 18:00 AM	.90	224	201	22.5	7.11	9	Yes	6.7
4 18:00 AM	1.02	224	228	23.1	7.08	9	Yes	6.7
5 18:00 AM	1.00	224	224	23.8	7.10	9	Yes	6.7
6 18:00 AM	.75	224	168	24.3	7.11	9	Yes	6.7
7 18:00 AM	.64	224	143	25.1	7.10	6	YES	6.7
8 18:00 AM	.68	224	152	24.8	7.07	9	Yes	6.7
9 18:00 AM	.76	224	170	25.9	7.14	6	Yes	6.7
10 18:00 AM	.99	224	221	25.6	7.12	6	Yes	6.7
11 18:00 AM	1.07	224	239	26.5	7.06	6	Yes	6.7
12 18:00 AM	1.99	224	221	26.8	7.06	6	Yes	6.7
13 18:00 AM	1.07	224	239	26.4	7.10	6	YES	6.7
14 18:00 AM	.80	224	179	26.5	7.05	6	Yes	6.7
15 18:00 AM	.74	224	165	26.5	7.01	6	Yes	6.7
16 18:00 AM	.72	224	161	26.8	6.98	6	YES	6.7
17 18:00 AM	.94	224	210	26.1	7.11	6	Yes	6.7
18 18:00 AM	.83	224	185	26.1	7.07	6	Yes	6.7
19 18:00 AM	.80	224	179	26.4	7.19	7	Yes	6.7
20 18:00 AM	.71	224	159	26.3	7.17	7	Yes	6.7
21 18:00 AM	.62	224	138	26.5	7.15	7	Yes	6.7
22 18:00 AM	.65	224	145	26.2	7.18	7	Yes	6.7
23 18:00 AM	1.00	224	224	25.7	7.16	8	Yes	6.7
24 18:00 AM	.93	224	208	25.8	7.16	7	Yes	6.7
25 18:00 AM	.88	224	197	25.8	7.16	7	Yes	6.7
26 18:00 AM	.87	224	194	25.2	7.07	6	Yes	6.7
27 18:00 AM	.75	224	168	24.4	7.15	11	Yes	6.7
28 18:00 AM	.67	224	150	24.3	7.14	11	YES	6.7
29 18:00 AM	.73	224	163	24.6	7.09	9	YES	6.7
30 18:00 AM	.69	224	154	25.1	7.13	7	Yes	6.7
31 18:00 AM	.80	224	179	25.1	7.10	7	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.