

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-:WTP-A Month/Year: 10/2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	.043	.056	OFF	OFF	.056
2	OFF	OFF	.043	.050	OFF	OFF	.050
3	OFF	OFF	.045	.049	OFF	OFF	.049
4	OFF	OFF	.043	.044	OFF	OFF	.044
5	OFF	OFF	.045	off	off	off	.045
6	off	off	.043	off	off	off	.043
7	OFF	OFF	OFF	.046	OFF	OFF	.046
8	OFF	OFF	.045	.053	OFF	OFF	.053
9	OFF	OFF	.049	.054	OFF	OFF	.054
10	OFF	OFF	.046	.054	OFF	OFF	.054
11	OFF	OFF	.104	.069	OFF	OFF	.104
12	OFF	OFF	.055	off	off	off	.055
13	off	off	.049	off	off	off	.049
14	off	off	.046	.049	OFF	OFF	.049
15	OFF	OFF	.049	.056	OFF	OFF	.056
16	OFF	OFF	.051	.059	OFF	OFF	.059
17	OFF	OFF	.066	.061	OFF	OFF	.066
18	OFF	OFF	.051	.054	OFF	OFF	.054
19	OFF	OFF	.056	off	off	off	.056
20	off	off	.052	off	off	off	.052
21	off	off	.051	.062	OFF	OFF	.062
22	OFF	OFF	.049	.061	OFF	OFF	.061
23	OFF	OFF	.051	.060	OFF	OFF	.060
24	OFF	OFF	.050	.064	OFF	.080	.080
25	OFF	.073	.125	.081	OFF	OFF	.125
26	OFF	OFF	.084	.051	off	off	.084
27	off	off	.064	off	off	off	.064
28	off	off	.065	.062	OFF	OFF	.065
29	OFF	OFF	.077	.082	OFF	OFF	.082
30	OFF	OFF	.060	.057	OFF	OFF	.060
31	OFF	OFF	.054	.055	OFF	OFF	.055

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
All turbidity readings $<$ IFC ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
Notes:	PRINTED NAME: Robert Fowler	
	SIGNATURE: Robert Fowler	DATE: 11-1-24
	PHONE #: (541) 1679-2549	CERT #: T-08679 D-08666

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program -- Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP.: WTP-A Month/Year: 10/2024 Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/8:00Am	.75	224	168	22.8	6.71	9	Yes	6.7
2/8:00Am	.90	224	201	23.0	6.87	9	Yes	6.7
3/8:00Am	.98	224	219	22.6	6.89	9	Yes	6.7
4/8:00Am	1.05	224	235	22.6	6.87	9	Yes	6.7
5/8:00Am	.93	224	208	22.0	6.74	9	Yes	6.7
6/8:00Am	1.02	224	228	22.1	6.74	9	Yes	6.7
7/8:00Am	.75	224	212	22.3	6.78	9	Yes	6.7
8/8:00Am	.84	224	188	22.3	6.76	9	Yes	6.7
9/8:00Am	.79	224	176	22.3	6.83	9	Yes	6.7
10/8:00Am	.88	224	197	22.1	6.83	9	Yes	6.7
11/8:00Am	.92	224	206	21.9	6.79	9	Yes	6.7
12/8:00Am	1.36	224	304	21.7	6.79	10	Yes	6.7
13/8:00Am	1.24	224	277	21.7	6.69	10	Yes	6.7
14/8:00Am	1.15	224	257	21.8	6.71	10	Yes	6.7
15/8:00Am	1.00	224	224	21.7	6.74	9	Yes	6.7
16/8:00Am	1.01	224	226	21.7	6.76	9	Yes	6.7
17/8:00Am	1.15	224	257	21.6	6.84	9	Yes	6.7
18/8:00Am	1.11	224	248	21.2	6.79	9	Yes	6.7
19/8:00Am	1.02	224	228	20.9	6.80	9	Yes	6.7
20/8:00Am	.93	224	208	21.2	6.81	9	Yes	6.7
21/8:00Am	1.00	224	224	21.3	6.83	9	Yes	6.7
22/8:00Am	.85	224	190	21.0	6.80	9	Yes	6.7
23/8:00Am	.80	224	179	20.8	6.88	9	Yes	6.7
24/8:00Am	.84	224	188	20.4	6.85	9	Yes	6.7
25/8:00Am	1.15	224	257	19.5	6.92	13	Yes	6.7
26/8:00Am	1.17	224	262	19.2	6.99	13	Yes	6.7
27/8:00Am	1.07	224	239	19.4	6.94	13	Yes	6.7
28/8:00Am	.92	224	206	19.2	7.04	13	Yes	6.7
29/8:00Am	.78	224	174	19.0	7.01	12	Yes	6.7
30/8:00Am	.75	224	168	19.2	7.10	12	Yes	6.7
31/8:00Am	.85	224	190	19.2	7.10	12	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.