

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 11/2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	off	off	.055	.050	off	off	.055
2	off	off	.059	off	off	off	.059
3	off	off	.110	.064	off	off	.110
4	off	off	off	.092	off	off	.092
5	off	off	.058	.120	off	off	.120
6	off	off	.114	.090	off	off	.114
7	off	off	off	.099	off	off	.099
8	off	off	.101	.083	off	off	.101
9	off	off	.101	off	off	off	.101
10	off	off	.104	off	off	off	.104
11	off	off	.080	.065	off	off	.080
12	off	off	.050	.053	off	off	.053
13	off	off	.069	.075	off	off	.075
14	off	off	.083	.101	off	off	.101
15	off	off	.079	.068	off	off	.079
16	off	off	off	.120	off	off	.120
17	off	off	off	.119	off	off	.119
18	off	off	.176	off	.132	off	.176
19	off	off	.107	.081	off	off	.107
20	off	off	.083	.071	off	off	.083
21	off	off	.077	.061	off	off	.077
22	off	off	.083	.092	off	off	.092
23	off	off	.100	off	off	off	.100
24	off	off	.094	off	off	off	.094
25	off	off	.111	.095	off	off	.111
26	off	off	.061	.047	off	off	.061
27	off	off	.065	.160	off	off	.160
28	off	off	.091	off	off	off	.091
29	off	off	.129	off	off	off	.129
30	off	off	.132	off	off	off	.132
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / No ²			
Notes:	PRINTED NAME: Robert Fowler		
	SIGNATURE: Robert Fowler	DATE: 12-4-24	
	PHONE #: (541) 679-2549	CERT #: 0-08666 T-08679	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program -- Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 11/2004

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1 18:00 AM	.76	224	170	19.3	7.17	12	Yes	6.7
2 18:00 AM	.74	224	165	19.3	7.13	12	YES	6.7
3 18:00 AM	.72	224	161	19.3	7.13	12	YES	6.7
4 18:00 AM	.67	224	150	19.5	7.19	12	Yes	6.7
5 18:00 AM	.74	224	165	19.3	7.15	12	Yes	6.7
6 18:00 AM	.88	224	197	18.7	7.09	12	Yes	6.7
7 18:00 AM	.89	224	199	18.0	7.13	12	Yes	6.7
8 18:00 AM	.81	224	181	18.0	7.07	12	Yes	6.7
9 18:00 AM	.78	224	174	17.9	7.04	12	Yes	6.7
10 18:00 AM	.71	224	159	18.3	7.00	12	YES	6.7
11 18:00 AM	.59	224	132	18.5	7.02	12	YES	6.7
12 18:00 AM	.66	224	147	18.8	7.02	12	Yes	6.7
13 18:00 AM	.97	224	217	18.2	7.02	13	Yes	6.7
14 18:00 AM	1.05	224	235	17.7	7.03	13	Yes	6.7
15 18:00 AM	1.02	224	228	17.4	6.99	13	Yes	6.7
16 18:00 AM	.92	224	206	17.2	6.99	13	Yes	6.7
17 18:00 AM	.83	224	185	17.4	6.98	12	Yes	6.7
18 18:00 AM	.79	224	176	17.6	6.98	12	Yes	6.7
19 18:00 AM	.78	224	174	17.2	6.99	12	Yes	6.7
20 18:00 AM	.81	224	181	17.4	7.01	12	Yes	6.7
21 18:00 AM	.80	224	179	17.2	7.00	12	Yes	6.7
22 18:00 AM	.89	224	199	17.1	7.00	12	Yes	6.7
23 18:00 AM	.85	224	190	16.9	6.94	12	Yes	6.7
24 18:00 AM	.98	224	219	17.0	7.00	13	Yes	6.7
25 18:00 AM	.87	224	194	17.7	6.96	12	Yes	6.7
26 18:00 AM	.99	224	221	17.5	6.94	13	Yes	6.7
27 18:00 AM	.90	224	201	17.6	6.99	12	Yes	6.7
28 18:00 AM	1.28	224	286	16.5	6.86	11	YES	6.7
29 18:00 AM	.92	224	206	16.5	6.86	11	YES	6.7
30 18:00 AM	1.09	224	244	16.7	6.86	11	YES	6.7
31 /								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.