

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 12/2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	off	off	.066	off	off	off	.066
2	off	off	.059	.047	off	off	.059
3	off	off	.057	.048	off	off	.057
4	off	off	.049	.047	off	off	.049
5	off	off	.049	.041	off	off	.049
6	off	off	.046	.038	.044	.043	.046
7	off	off	off	.038	off	off	.038
8	off	off	.044	off	off	off	.044
9	off	off	.044	.039	off	off	.044
10	off	off	.040	.039	off	off	.040
11	off	off	.105	.054	off	off	.105
12	off	off	.066	.048	off	off	.066
13	off	off	.056	.036	off	off	.056
14	off	off	off	.065	off	off	.065
15	off	off	.053	off	off	off	.053
16	off	off	.062	.060	off	off	.062
17	off	off	.090	.061	off	off	.090
18	off	off	.092	.068	off	off	.092
19	off	off	.072	.053	off	off	.072
20	off	off	.065	.050	off	off	.065
21	off	off	.059	off	off	off	.059
22	off	off	.056	off	off	off	.056
23	off	off	.054	.041	off	off	.054
24	off	off	.050	off	off	off	.050
25	off	off	.051	off	off	off	.051
26	off	off	.170	.057	off	off	.170
27	off	off	.107	.76	off	off	.107
28	off	off	.108	off	off	off	.108
29	off	off	.092	off	off	off	.092
30	off	off	.083	.059	off	off	.083
31	off	off	.070	off	off	off	.070

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
All turbidity readings $<$ IFC ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
Notes:	PRINTED NAME: <u>ROBERT FOWLER</u>	
	SIGNATURE: <u>Robert Fowler</u>	DATE: <u>1-2-25</u>
	PHONE #: <u>(541) 679-2549</u>	CERT #: <u>T-08679</u> <u>D-08666</u>

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 12/2024

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 18:00 AM	1.06	224	237	16.5	6.82	13	Yes	6.7
2 18:00 AM	1.03	224	230	16.9	6.87	13	Yes	6.7
3 18:00 AM	.92	224	206	16.9	6.95	12	Yes	6.7
4 18:00 AM	.95	224	212	17.0	6.95	12	Yes	6.7
5 18:00 AM	1.10	224	246	16.8	6.96	13	Yes	6.7
6 18:00 AM	1.15	224	257	16.6	6.95	13	Yes	6.7
7 18:00 AM	1.44	224	322	14.5	6.98	19	Yes	6.7
8 18:00 AM	1.40	224	313	15.1	7.12	13	Yes	6.7
9 18:00 AM	1.40	224	313	15.5	7.12	13	Yes	6.7
10 18:00 AM	1.33	224	297	14.9	6.99	19	Yes	6.7
11 18:00 AM	1.19	224	266	15.1	7.08	13	Yes	6.7
12 18:00 AM	1.01	224	226	15.0	7.06	13	Yes	6.7
13 18:00 AM	1.01	224	226	14.8	7.08	19	Yes	6.7
14 18:00 AM	.97	224	217	14.9	7.01	19	Yes	6.7
15 18:00 AM	1.01	224	226	15.0	7.08	13	Yes	6.7
16 18:00 AM	.90	224	201	15.3	6.94	13	Yes	6.7
17 18:00 AM	.96	224	215	15.6	7.01	13	Yes	6.7
18 18:00 AM	.86	224	192	16.0	7.03	12	Yes	6.7
19 18:00 AM	.87	224	194	16.3	7.06	12	Yes	6.7
20 18:00 AM	.82	224	183	16.2	7.09	12	Yes	6.7
21 18:00 AM	.84	224	188	15.6	7.17	15	Yes	6.7
22 18:00 AM	.75	224	168	16.5	7.17	15	Yes	6.7
23 18:00 AM	.77	224	172	16.6	7.20	15	Yes	6.7
24 18:00 AM	.73	224	163	16.9	7.03	12	Yes	6.7
25 18:00 AM	.68	224	152	16.9	7.13	12	Yes	6.7
26 18:00 AM	.74	224	165	17.7	7.13	12	Yes	6.7
27 18:00 AM	1.22	224	273	17.7	7.20	15	Yes	6.7
28 18:00 AM	1.32	224	295	17.4	7.25	15	Yes	6.7
29 18:00 AM	1.38	224	309	17.5	7.18	15	Yes	6.7
30 18:00 AM	1.42	224	318	17.4	6.96	13	Yes	6.7
31 18:00 AM	1.12	224	250	17.0	6.98	13	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.