

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas  
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 1/2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	OFF	OFF	OFF	.081	OFF	OFF	.081
2	OFF	OFF	.063	.042	OFF	OFF	.063
3	OFF	OFF	.057	.045	OFF	OFF	.057
4	OFF	OFF	.054	OFF	.078	OFF	.078
5	OFF	OFF	.040	OFF	OFF	OFF	.040
6	OFF	OFF	.046	.040	OFF	OFF	.046
7	OFF	OFF	.148	.065	OFF	OFF	.148
8	OFF	OFF	.077	.051	OFF	OFF	.077
9	OFF	OFF	.065	.050	OFF	OFF	.065
10	OFF	OFF	.062	.052	OFF	OFF	.062
11	OFF	OFF	.059	OFF	OFF	OFF	.059
12	OFF	OFF	.054	OFF	OFF	OFF	.054
13	OFF	OFF	.051	.053	OFF	OFF	.053
14	OFF	OFF	.060	.052	OFF	OFF	.060
15	OFF	OFF	.054	.044	OFF	OFF	.054
16	OFF	OFF	.049	.036	OFF	OFF	.049
17	OFF	OFF	.048	.038	OFF	OFF	.048
18	OFF	OFF	.047	OFF	OFF	OFF	.047
19	OFF	OFF	.043	OFF	OFF	OFF	.043
20	OFF	OFF	.042	.041	OFF	OFF	.042
21	OFF	OFF	OFF	.044	OFF	OFF	.044
22	OFF	OFF	.156	.079	OFF	OFF	.156
23	OFF	OFF	.095	.055	OFF	OFF	.095
24	OFF	OFF	.078	.051	OFF	OFF	.078
25	OFF	OFF	.069	OFF	OFF	OFF	.069
26	OFF	OFF	.065	.052	OFF	OFF	.065
27	OFF	OFF	.061	.062	OFF	.062	.062
28	OFF	.055	.052	.053	OFF	OFF	.055
29	OFF	.049	.037	.046	OFF	OFF	.049
30	.047	OFF	.043	.160	OFF	OFF	.160
31	OFF	.089	.048	OFF	.066	OFF	.089

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
All turbidity readings < IFC <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:	PRINTED NAME: <u>Robert Fowler</u>		
	SIGNATURE: <u>Robert Fowler</u>	DATE: <u>2-4-25</u>	
	PHONE #: <u>(571) 1679-2549</u>	CERT #: <u>T-08679</u> <u>D-08666</u>	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indivd. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 1/2025

Required Log Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1 8:00 AM	1.00	224	224	17.4	7.05	13	Yes	6.7
2 8:00 AM	.89	224	199	17.9	6.97	12	Yes	6.7
3 8:00 AM	.78	224	174	18.1	6.98	12	Yes	6.7
4 8:00 AM	.68	224	152	18.1	7.02	12	Yes	6.7
5 8:00 AM	.95	224	212	17.4	6.89	13	Yes	6.7
6 8:00 AM	.93	224	208	17.0	6.88	13	Yes	6.7
7 8:00 AM	1.20	224	268	17.0	6.87	13	Yes	6.7
8 8:00 AM	1.60	224	358	16.4	6.89	13	Yes	6.7
9 8:00 AM	1.62	224	362	15.8	6.91	13	Yes	6.7
10 8:00 AM	1.52	224	340	15.8	6.88	13	Yes	6.7
11 8:00 AM	1.30	224	291	15.6	6.86	13	Yes	6.7
12 8:00 AM	1.15	224	257	15.9	6.77	13	Yes	6.7
13 8:00 AM	1.06	224	237	16.5	6.80	13	Yes	6.7
14 8:00 AM	.85	224	190	16.4	6.76	12	Yes	6.7
15 8:00 AM	.68	224	152	16.5	6.84	12	Yes	6.7
16 8:00 AM	.83	224	185	15.5	6.89	12	Yes	6.7
17 8:00 AM	.99	224	221	14.9	6.88	19	Yes	6.7
18 8:00 AM	1.12	224	250	14.5	6.84	19	Yes	6.7
19 8:00 AM	1.20	224	268	14.6	6.86	19	Yes	6.7
20 8:00 AM	1.40	224	313	14.7	6.79	19	Yes	6.7
21 8:00 AM	1.12	224	250	14.5	6.90	19	Yes	6.7
22 8:00 AM	1.10	224	246	14.5	6.94	19	Yes	6.7
23 8:00 AM	1.36	224	304	13.9	7.00	19	Yes	6.7
24 8:00 AM	1.43	224	320	13.3	6.94	19	Yes	6.7
25 8:00 AM	1.40	224	313	12.8	6.87	19	Yes	6.7
26 8:00 AM	1.57	224	351	12.7	6.99	19	Yes	6.7
27 8:00 AM	1.46	224	327	12.5	6.93	19	Yes	6.7
28 8:00 AM	1.15	224	257	10.2	6.93	19	Yes	6.7
29 8:00 AM	1.13	224	253	10.0	7.03	19	Yes	6.7
30 8:00 AM	1.16	224	257	9.5	6.98	25	Yes	6.7
31 8:00 AM	1.30	224	291	9.3	6.97	25	Yes	6.7

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.