

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 2/2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	off	off	off	.068	off	off	.068
2	off	off	.076	off	off	off	.076
3	off	off	.082	.068	off	off	.082
4	off	off	.071	off	.065	off	.071
5	off	off	.071	off	.066	off	.071
6	off	off	.062	off	.048	off	.062
7	off	off	.053	off	.042	off	.053
8	off	off	.053	off	off	off	.053
9	off	off	.058	off	off	off	.058
10	off	off	.057	off	.053	off	.057
11	off	off	.185	off	.104	off	.185
12	off	off	.094	off	.077	off	.094
13	off	off	.073	off	.070	off	.073
14	off	off	.066	off	.047	off	.066
15	off	off	.059	off	off	off	.059
16	off	off	.056	off	off	off	.056
17	off	off	.055	off	.049	off	.055
18	off	off	.055	off	.052	off	.055
19	off	off	.059	off	.055	off	.059
20	off	off	.058	off	.054	off	.058
21	off	off	.053	off	.049	off	.053
22	off	off	.050	.170	off	off	.170
23	off	off	.128	off	off	off	.128
24	off	off	off	.098	.057	off	.098
25	off	off	.076	off	.066	off	.076
26	off	off	.073	off	.059	off	.073
27	off	off	.073	off	.067	off	.073
28	off	off	.090	off	.039	off	.090
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / No ²			
Notes:	PRINTED NAME: Robert Fowler		
	SIGNATURE: <i>Robert Fowler</i>	DATE: 3-4-25	
	PHONE #: (541) 1679-2549	CERT #: T-08679 D-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indivd. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 2/2025

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
11 8:00am	1.14	224	255	10.1	6.96	19	Yes	6.7
21 8:00am	1.39	224	311	10.5	6.94	19	Yes	6.7
31 8:00am	1.10	224	246	10.7	6.97	19	Yes	6.7
41 8:00am	.80	224	179	11.2	6.96	18	Yes	6.7
51 8:00am	.66	224	147	11.1	6.98	18	Yes	6.7
61 8:00am	.76	224	170	11.0	7.02	18	Yes	6.7
71 8:00am	1.13	224	253	10.1	7.19	19	Yes	6.7
81 8:00am	1.09	224	244	11.2	7.03	19	Yes	6.7
91 8:00am	1.20	224	268	11.6	7.08	19	Yes	6.7
101 8:00am	1.15	224	257	11.8	7.13	19	Yes	6.7
111 8:00am	1.00	224	224	11.8	6.94	19	Yes	6.7
121 8:00am	1.18	224	264	11.1	6.92	19	Yes	6.7
131 8:00am	1.16	224	266	10.8	7.02	19	Yes	6.7
141 8:00am	1.22	224	273	11.3	7.01	19	Yes	6.7
151 8:00am	1.09	224	244	11.4	7.00	19	Yes	6.7
161 8:00am	1.04	224	232	12.4	7.06	19	Yes	6.7
171 8:00am	1.08	224	241	12.9	7.18	19	Yes	6.7
181 8:00am	.97	224	217	13.5	7.00	19	Yes	6.7
191 8:00am	.94	224	210	13.6	7.02	19	Yes	6.7
201 8:00am	.94	224	210	13.8	7.20	22	Yes	6.7
211 8:00am	.94	224	210	14.0	7.18	22	Yes	6.7
221 8:00am	.92	224	206	14.4	7.22	22	Yes	6.7
231 8:00am	.96	224	215	15.0	7.20	15	Yes	6.7
241 8:00am	1.05	224	235	14.9	7.18	22	Yes	6.7
251 8:00am	.93	224	208	15.3	7.11	15	Yes	6.7
261 8:00am	.85	224	190	15.6	7.19	15	Yes	6.7
271 8:00am	.86	224	192	15.3	7.17	15	Yes	6.7
281 8:00am	.87	224	194	16.0	7.13	15	Yes	6.7
29 /								
30 /								
31 /								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.