

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 3/2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.053	off	off	off	.053
2	off	.048	off	off	off	off	.048
3	off	off	.045	.040	off	off	.045
4	off	off	.044	off	.042	off	.044
5	off	off	.044	off	.042	off	.044
6	off	off	.042	.180	.064	off	.180
7	off	off	.083	.066	off	off	.083
8	off	off	.069	off	off	off	.069
9	off	off	.064	off	off	off	.064
10	off	off	.071	.046	off	off	.071
11	off	off	.061	off	.054	off	.061
12	off	off	.054	off	.048	off	.054
13	off	off	.052	off	.050	off	.052
14	off	off	.059	off	.051	off	.059
15	off	off	.072	off	.060	off	.072
16	off	off	.077	off	.089	off	.077
17	off	off	.103	off	.258	off	.258
18	off	off	.120	off	.069	off	.120
19	off	off	.075	.267	off	off	.267
20	off	off	.155	off	.072	off	.155
21	off	off	.068	off	.048	off	.068
22	off	off	.058	off	.045	off	.058
23	off	off	.052	off	off	off	.052
24	off	off	.057	off	.047	off	.057
25	off	off	.061	off	.050	off	.061
26	off	off	.053	off	.046	off	.053
27	off	off	.048	off	.047	off	.048
28	off	off	.047	.198	off	off	.198
29	off	off	off	.106	off	off	.106
30	off	off	.075	off	off	off	.075
31	off	off	.074	.059	off	off	.074

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? <u>Yes</u> / No	CT's met everyday? (see back) <u>Yes</u> / No	All Cl ₂ residuals at entry point $\geq$ 0.2 mg/l? <u>Yes</u> / No	
All the 4-hour turbidity readings $\leq$ 1 NTU? <u>Yes</u> / No			
All turbidity readings < IFE ² triggers? <u>Yes</u> / No ²			
Notes:		PRINTED NAME: <u>Robert Fowler</u>	
		SIGNATURE: <u>Robert Fowler</u>	DATE: <u>4-1-25</u>
		PHONE #: <u>(541) 679-2549</u>	CERT #: <u>T-08679</u> <u>D-08666</u>

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.² IFE = Indivd. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 3/2025

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ¹	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00 AM	.90	224	201	16.3	7.20	15	Yes	6.7
2 8:00 AM	.90	224	201	16.5	7.16	15	Yes	6.7
3 8:00 AM	.83	224	185	16.6	7.20	15	Yes	6.7
4 8:00 AM	.80	224	179	16.9	7.07	12	Yes	6.7
5 8:00 AM	.88	224	197	16.9	7.03	12	Yes	6.7
6 8:00 AM	.92	224	206	16.8	7.02	12	Yes	6.7
7 8:00 AM	1.25	224	280	16.2	7.11	15	Yes	6.7
8 8:00 AM	1.40	224	313	16.1	7.06	13	Yes	6.7
9 8:00 AM	1.16	224	259	16.6	7.17	13	Yes	6.7
10 8:00 AM	1.21	224	271	16.6	6.92	13	Yes	6.7
11 8:00 AM	1.03	224	230	17.1	6.93	13	Yes	6.7
12 8:00 AM	.86	224	192	17.3	6.98	12	Yes	6.7
13 8:00 AM	.89	224	199	17.0	6.93	12	Yes	6.7
14 8:00 AM	.81	224	181	17.1	7.01	12	Yes	6.7
15 8:00 AM	.80	224	179	17.1	6.93	12	Yes	6.7
16 8:00 AM	.77	224	172	17.3	6.87	12	Yes	6.7
17 8:00 AM	.88	224	197	17.1	6.99	12	Yes	6.7
18 8:00 AM	.74	224	165	17.2	7.04	12	Yes	6.7
19 8:00 AM	.79	224	176	17.3	6.92	12	Yes	6.7
20 8:00 AM	.82	224	183	16.3	6.91	12	Yes	6.7
21 8:00 AM	.91	224	203	15.6	6.95	12	Yes	6.7
22 8:00 AM	.87	224	194	15.4	6.84	12	Yes	6.7
23 8:00 AM	.94	224	210	16.1	6.82	12	Yes	6.7
24 8:00 AM	.98	224	219	16.8	6.86	13	Yes	6.7
25 8:00 AM	.69	224	154	17.5	6.84	12	Yes	6.7
26 8:00 AM	.97	224	217	17.8	7.02	13	Yes	6.7
27 8:00 AM	1.06	224	237	18.2	7.00	13	Yes	6.7
28 8:00 AM	1.00	224	224	17.6	6.85	13	Yes	6.7
29 8:00 AM	1.01	224	226	17.2	6.90	13	Yes	6.7
30 8:00 AM	1.03	224	230	17.6	6.91	13	Yes	6.7
31 8:00 AM	1.01	224	226	17.7	6.99	13	Yes	6.7

¹ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf