

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 4/2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	OFF	OFF	.068	OFF	.057	OFF	.068
2	OFF	OFF	.063	OFF	.053	OFF	.063
3	OFF	OFF	.064	OFF	.053	OFF	.064
4	OFF	OFF	.061	OFF	.052	OFF	.061
5	OFF	OFF	.062	.056	OFF	OFF	.062
6	OFF	OFF	.064	OFF	OFF	OFF	.064
7	OFF	OFF	.063	OFF	.056	OFF	.063
8	OFF	OFF	.057	OFF	.053	OFF	.057
9	OFF	OFF	.185	OFF	.082	OFF	.185
10	OFF	OFF	.104	OFF	.082	OFF	.104
11	OFF	OFF	.097	OFF	.071	OFF	.097
12	OFF	OFF	.080	OFF	OFF	OFF	.080
13	OFF	OFF	.071	OFF	OFF	OFF	.071
14	OFF	OFF	.069	OFF	.060	OFF	.069
15	OFF	OFF	.064	OFF	.058	OFF	.064
16	OFF	OFF	.058	.056	.053	.059	.059
17	OFF	OFF	.060	OFF	.062	.061	.062
18	.060	.058	.056	OFF	.057	OFF	.060
19	.058	OFF	.155	OFF	OFF	OFF	.155
20	OFF	OFF	.083	OFF	OFF	OFF	.083
21	OFF	OFF	.072	OFF	.075	OFF	.075
22	OFF	OFF	.117	.086	.061	OFF	.117
23	OFF	OFF	.068	OFF	.065	OFF	.068
24	OFF	OFF	.066	OFF	.051	OFF	.066
25	OFF	OFF	.052	OFF	.045	OFF	.052
26	OFF	OFF	.042	OFF	OFF	OFF	.042
27	OFF	OFF	.039	OFF	OFF	OFF	.039
28	OFF	OFF	.039	OFF	.040	OFF	.040
29	OFF	OFF	.039	OFF	.043	OFF	.043
30	OFF	OFF	.044	OFF	.045	OFF	.045
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes / ☐ No	CT's met everyday? (see back) ☒ Yes / ☐ No	All Cl ₂ residuals at entry point $\geq$ 0.2 mg/l? ☒ Yes / ☐ No	
All the 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No			
All turbidity readings $<$ 1 FC ² triggers? ☒ Yes / ☐ No			
Notes:		PRINTED NAME: Robert Fowler	
		SIGNATURE: <i>Robert Fowler</i>	DATE: 5-1-25
		PHONE #: (541) 1679-2549	CERT #: T-08679 D-08666

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 4/2005

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ¹	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 18:00AM	.92	224	206	17.9	6.84	13	Yes	6.7
2 18:00AM	.86	224	192	17.8	6.86	12	Yes	6.7
3 18:00AM	.90	224	201	17.6	6.75	11	Yes	6.7
4 18:00AM	.92	224	206	17.9	6.78	11	Yes	6.7
5 18:00AM	.92	224	206	18.2	6.96	13	Yes	6.7
6 18:00AM	.94	224	210	19.1	6.91	13	Yes	6.7
7 18:00AM	1.06	224	237	19.2	6.92	13	Yes	6.7
8 18:00AM	.83	224	185	19.4	6.89	12	Yes	6.7
9 18:00AM	.82	224	183	19.3	6.85	12	Yes	6.7
10 18:00AM	.98	224	219	19.3	6.87	13	Yes	6.7
11 18:00AM	1.00	224	224	19.0	6.85	13	Yes	6.7
12 18:00AM	.96	224	215	18.9	6.82	13	Yes	6.7
13 18:00AM	.95	224	212	19.0	6.85	13	Yes	6.7
14 18:00AM	1.02	224	228	19.3	6.85	13	Yes	6.7
15 18:00AM	.83	224	185	19.7	6.92	12	Yes	6.7
16 18:00AM	.87	224	194	19.6	6.97	12	Yes	6.7
17 18:00AM	1.23	224	275	18.8	6.80	13	Yes	6.7
18 18:00AM	1.19	224	266	17.2	6.75	13	Yes	6.7
19 18:00AM	1.03	224	230	17.4	6.79	13	Yes	6.7
20 18:00AM	1.00	224	224	17.8	6.78	13	Yes	6.7
21 18:00AM	1.02	224	228	18.2	6.77	13	Yes	6.7
22 18:00AM	.89	224	199	18.2	6.81	12	Yes	6.7
23 18:00AM	.85	224	190	18.5	6.79	12	Yes	6.7
24 18:00AM	.90	224	201	18.8	6.81	13	Yes	6.7
25 18:00AM	.86	224	192	19.0	7.38	15	Yes	6.7
26 18:00AM	.84	224	188	19.1	7.36	15	Yes	6.7
27 18:00AM	.84	224	188	19.3	7.32	15	Yes	6.7
28 18:00AM	.89	224	199	19.6	7.36	15	Yes	6.7
29 18:00AM	.78	224	174	19.6	7.33	15	Yes	6.7
30 18:00AM	.82	224	183	19.6	7.29	15	Yes	6.7
31 /								

¹ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf