

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 7/2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	OFF	OFF	.059	OFF	.061	OFF	.061
2	OFF	OFF	.075	OFF	.083	OFF	.083
3	OFF	OFF	.063	.073	.077	OFF	.077
4	OFF	OFF	.052	off	.056	OFF	.056
5	OFF	OFF	.055	OFF	.055	OFF	.055
6	OFF	OFF	.048	OFF	off	off	.048
7	off	off	.045	off	.048	OFF	.048
8	OFF	.046	.048	.094	OFF	OFF	.094
9	OFF	OFF	.052	OFF	.051	.054	.054
10	OFF	OFF	.048	OFF	.048	OFF	.048
11	OFF	OFF	.050	OFF	.046	OFF	.050
12	OFF	OFF	.044	off	off	off	.044
13	off	off	.040	off	off	off	.040
14	off	off	.044	off	.047	OFF	.047
15	OFF	OFF	.046	OFF	.053	OFF	.053
16	.052	OFF	.051	OFF	.048	OFF	.052
17	.052	OFF	.054	.053	.110	OFF	.110
18	.059	.053	.063	OFF	.049	.059	.063
19	OFF	.053	.050	off	off	off	.053
20	off	off	.044	off	off	off	.044
21	off	off	.047	.052	OFF	OFF	.052
22	OFF	OFF	.045	OFF	.051	OFF	.051
23	OFF	OFF	.047	OFF	.065	OFF	.065
24	OFF	.064	OFF	.094	OFF	OFF	.094
25	.079	OFF	.073	OFF	.070	OFF	.079
26	off	off	.062	off	off	off	.062
27	off	off	.068	off	off	off	.068
28	off	off	.071	off	.071	OFF	.071
29	OFF	OFF	.074	OFF	.067	.096	.096
30	OFF	.074	.070	OFF	.070	OFF	.074
31	.078	OFF	.066	.065	.073	OFF	.078

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes / No	CT's met everyday? (see back) ☒ Yes / No	All Cl ₂ residuals at entry point $\geq$ 0.2 mg/l? ☒ Yes / No	
All the 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes / No			
All turbidity readings < IFC ² triggers? ☒ Yes / No ²			
Notes:		PRINTED NAME: Robert Fowler	
		SIGNATURE: Robert Fowler	DATE: 8-1-25
		PHONE #: (541) 1679-2549	CERT #: T-08679 D-08606

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
IFE = Indiv. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 7/2025

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00 AM	.77	224	172	24.1	7.00	9	Yes	6.7
2 8:00 AM	.71	224	159	24.4	6.98	9	Yes	6.7
3 8:00 AM	.70	224	156	24.5	6.96	9	Yes	6.7
4 8:00 AM	.69	224	154	23.9	6.95	9	Yes	6.7
5 8:00 AM	.71	224	159	23.3	6.96	9	Yes	6.7
6 8:00 AM	.68	224	152	23.6	6.94	9	Yes	6.7
7 8:20 AM	.68	224	152	24.1	6.94	9	Yes	6.7
8 8:00 AM	.89	224	199	24.5	6.93	9	Yes	6.7
9 8:00 AM	1.19	224	266	24.9	6.88	10	Yes	6.7
10 8:00 AM	1.15	224	257	25.4	6.92	6	Yes	6.7
11 8:00 AM	.85	224	190	25.3	6.91	6	Yes	6.7
12 8:00 AM	.77	224	172	25.7	6.88	6	Yes	6.7
13 8:20 AM	.64	224	143	26.3	6.88	6	Yes	6.7
14 8:00 AM	.78	224	174	26.8	6.86	6	Yes	6.7
15 8:00 AM	1.01	224	226	26.5	6.87	6	Yes	6.7
16 8:00 AM	.99	224	221	27.0	6.78	6	Yes	6.7
17 8:00 AM	1.02	224	228	27.3	6.74	6	Yes	6.7
18 8:00 AM	1.22	224	273	27.1	6.90	6	Yes	6.7
19 8:00 AM	1.22	224	273	27.1	6.77	6	Yes	6.7
20 8:00 AM	.97	224	217	26.6	6.53	5	Yes	6.7
21 8:00 AM	.80	224	179	26.1	6.61	6	Yes	6.7
22 8:00 AM	.70	224	156	25.3	6.80	6	Yes	6.7
23 8:00 AM	.71	224	159	25.9	6.85	6	Yes	6.7
24 8:00 AM	.79	224	176	26.3	6.79	6	Yes	6.7
25 8:00 AM	1.03	224	230	26.3	6.75	6	Yes	6.7
26 8:00 AM	.85	224	190	25.6	6.79	6	Yes	6.7
27 8:00 AM	.66	224	147	25.7	6.79	6	Yes	6.7
28 8:00 AM	.57	224	127	25.7	6.81	6	Yes	6.7
29 8:00 AM	.64	224	143	26.0	6.79	6	Yes	6.7
30 8:00 AM	1.18	224	264	26.0	6.78	6	Yes	6.7
31 8:00 AM	1.11	224	248	26.0	6.82	6	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf