

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 8/2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	.095	OFF	.063	OFF	.095
2	OFF	OFF	.053	OFF	OFF	OFF	.053
3	OFF	OFF	.053	off	off	off	.053
4	off	off	.048	.060	OFF	OFF	.060
5	OFF	OFF	.073	.068	OFF	OFF	.073
6	OFF	OFF	.063	OFF	.057	OFF	.063
7	OFF	OFF	.061	.060	OFF	OFF	.061
8	OFF	OFF	.074	OFF	.063	off	.074
9	off	off	.050	off	off	off	.050
10	off	off	.048	off	off	off	.048
11	off	off	.054	off	.061	off	.061
12	off	off	.064	off	.064	.074	.074
13	off	off	.062	.062	off	off	.062
14	off	off	.072	off	off	off	.072
15	.059	off	.077	off	.075	off	.077
16	off	off	.044	off	off	off	.044
17	off	off	off	.057	off	off	.057
18	off	off	.047	.058	off	off	.058
19	off	off	.095	OFF	.067	OFF	.095
20	OFF	OFF	OFF	.072	.065	OFF	.072
21	OFF	OFF	.051	OFF	.065	OFF	.065
22	OFF	.070	.060	OFF	OFF	OFF	.070
23	OFF	OFF	.051	off	off	off	.051
24	off	off	.048	off	off	off	.048
25	off	off	.063	off	.064	OFF	.064
26	OFF	OFF	.064	OFF	.070	OFF	.070
27	OFF	OFF	.063	OFF	.066	OFF	.066
28	OFF	OFF	.070	OFF	.070	OFF	.070
29	OFF	OFF	.056	OFF	.062	OFF	.062
30	OFF	OFF	.071	.095	OFF	OFF	.095
31	OFF	.057	OFF	OFF	OFF	.068	.068

Conventional or Direct Filtration 95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes / ☐ No All the 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No All turbidity readings < IFE ² triggers? ☒ Yes / ☐ No ²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / ☐ No All Cl ₂ residuals at entry point $\geq$ 0.2 mg/l? ☒ Yes / ☐ No	
Notes:		PRINTED NAME: Robert Fowler	
		SIGNATURE: Robert Fowler	DATE: 7-2-25
		PHONE #: (541) 1679-2549	CERT #: T-08679 D-08666

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
 IFE = Indiv. Filter Eff. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 8/2025

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00 AM	.92	224	206	26.3	6.76	6	Yes	6.7
2 8:00 AM	.81	224	181	26.0	6.78	6	Yes	6.7
3 8:00 AM	.69	224	154	25.6	6.77	6	Yes	6.7
4 8:00 AM	.63	224	141	25.1	6.62	6	Yes	6.7
5 8:00 AM	.77	224	172	24.8	6.71	9	Yes	6.7
6 8:00 AM	.82	224	183	25.5	6.72	6	Yes	6.7
7 8:00 AM	.78	224	174	25.5	6.65	6	Yes	6.7
8 8:00 AM	.80	224	179	24.8	6.74	9	Yes	6.7
9 8:00 AM	.67	224	150	24.5	6.66	9	Yes	6.7
10 8:00 AM	.76	224	170	25.3	6.68	6	Yes	6.7
11 8:00 AM	.56	224	125	26.0	6.60	6	Yes	6.7
12 8:00 AM	.72	224	161	26.2	6.62	6	Yes	6.7
13 8:00 AM	1.22	224	273	26.5	6.64	6	Yes	6.7
14 8:00 AM	.98	224	219	26.6	6.54	5	Yes	6.7
15 8:00 AM	.57	224	127	26.3	6.85	6	Yes	6.7
16 8:00 AM	1.96	224	439	26.5	6.58	6	Yes	6.7
17 8:00 AM	1.89	224	423	25.3	6.57	6	Yes	6.7
18 8:00 AM	1.84	224	412	25.1	6.60	7	Yes	6.7
19 8:00 AM	1.13	224	253	24.7	6.43	8	Yes	6.7
20 8:00 AM	.64	224	143	24.4	6.67	9	Yes	6.7
21 8:00 AM	.78	224	174	24.6	6.58	8	Yes	6.7
22 8:00 AM	.75	224	168	24.5	6.70	9	Yes	6.7
23 8:00 AM	.71	224	159	25.5	6.66	6	Yes	6.7
24 8:00 AM	.78	224	174	26.4	6.56	5	Yes	6.7
25 8:00 AM	.62	224	138	26.3	6.54	5	Yes	6.7
26 8:00 AM	.78	224	174	26.6	6.66	6	Yes	6.7
27 8:00 AM	.84	224	188	26.9	6.45	5	Yes	6.7
28 8:00 AM	.74	224	165	26.6	6.44	5	Yes	6.7
29 8:00 AM	.70	224	156	26.7	6.52	5	Yes	6.7
30 8:00 AM	.61	224	136	25.5	6.57	5	Yes	6.7
31 8:00 AM	.94	224	210	25.6	6.50	5	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf