

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 9/2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	off	off	.051	off	off	off	.051
2	off	off	.045	off	.062	off	.062
3	off	off	.049	off	.058	off	.058
4	off	off	.045	off	.059	off	.059
5	off	off	.054	off	.064	off	.064
6	off	off	.045	off	off	off	.045
7	off	off	.047	off	off	off	.047
8	off	off	.045	off	.053	off	.053
9	off	off	off	.065	.062	off	.065
10	off	off	.047	off	.057	off	.057
11	off	off	.043	off	.055	off	.055
12	off	off	.046	off	.057	off	.057
13	off	off	.095	off	off	off	.095
14	off	off	.048	off	off	off	.048
15	off	off	.042	.045	off	off	.045
16	off	off	.043	off	.050	off	.050
17	off	off	.041	.053	off	off	.053
18	off	off	.040	.052	off	off	.052
19	off	off	.044	off	.047	off	.047
20	off	off	.045	off	off	off	.045
21	off	off	.047	off	off	off	.047
22	off	off	.047	off	.048	off	.048
23	off	off	off	.060	.061	off	.061
24	off	off	.048	off	.053	off	.053
25	off	off	.047	off	.053	off	.053
26	off	off	.051	off	.050	off	.051
27	off	off	.094	off	off	off	.094
28	off	off	.046	off	off	off	.046
29	off	off	.043	off	.049	off	.049
30	off	off	.044	off	.052	off	.052
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes / ☐ No	CT's met everyday? (see back) ☒ Yes / ☐ No	All Cl ₂ residuals at entry point $\geq$ 0.2 mg/l? ☒ Yes / ☐ No	
All the 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No			
All turbidity readings < IFE ² triggers? ☒ Yes / ☐ No			
Notes:		PRINTED NAME: Robert Fowler	
		SIGNATURE: Robert Fowler	DATE: 10-2-25
		PHONE #: 541 1679-2549	CERT #: T-08679 D-08666

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program -- Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 9/2025

Required Log
Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 18:00 AM	.82	224	183	25.0	6.54	5	Yes	6.7
2 18:00 AM	.71	224	159	25.1	6.58	5	Yes	6.7
3 18:00 AM	.74	224	165	25.5	6.51	5	Yes	6.7
4 18:00 AM	.73	224	163	25.3	6.57	5	Yes	6.7
5 18:00 AM	.86	224	192	25.8	6.53	5	Yes	6.7
6 18:00 AM	.80	224	179	25.2	6.53	5	Yes	6.7
7 18:00 AM	.76	224	170	25.2	6.65	5	Yes	6.7
8 18:00 AM	.65	224	145	25.1	6.52	5	Yes	6.7
9 18:00 AM	.62	224	138	24.6	6.52	8	Yes	6.7
10 18:00 AM	.67	224	150	24.4	6.69	9	Yes	6.7
11 18:00 AM	.66	224	147	24.4	6.74	9	Yes	6.7
12 18:00 AM	.67	224	150	24.3	6.77	9	Yes	6.7
13 18:00 AM	.58	224	174	23.4	6.50	8	Yes	6.7
14 18:00 AM	.81	224	181	23.4	6.71	9	Yes	6.7
15 18:00 AM	.69	224	154	22.3	6.51	8	Yes	6.7
16 18:00 AM	.72	224	161	22.3	6.61	9	Yes	6.7
17 18:00 AM	.61	224	136	23.2	6.50	8	Yes	6.7
18 18:00 AM	.88	224	197	23.1	6.57	8	Yes	6.7
19 18:00 AM	1.09	224	244	22.6	6.54	8	Yes	6.7
20 18:00 AM	1.11	224	248	22.6	6.54	8	Yes	6.7
21 18:00 AM	1.03	224	230	22.4	6.71	9	Yes	6.7
22 18:00 AM	1.02	224	228	21.1	6.53	8	Yes	6.7
23 18:00 AM	.97	224	217	20.9	6.54	8	Yes	6.7
24 18:00 AM	.92	224	206	21.6	6.61	9	Yes	6.7
25 18:00 AM	.84	224	188	21.6	6.59	8	Yes	6.7
26 18:00 AM	.85	224	190	20.9	6.56	8	Yes	6.7
27 18:00 AM	.82	224	183	20.6	6.76	9	Yes	6.7
28 18:00 AM	.94	224	210	21.3	6.61	9	Yes	6.7
29 18:00 AM	1.34	224	300	21.2	6.68	10	Yes	6.7
30 18:00 AM	1.34	224	300	20.4	6.71	10	Yes	6.7
31 /								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf