

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 10/2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.047	off	.047	off	.047
2	off	off	.044	off	.045	off	.045
3	off	off	.047	off	.044	off	.047
4	off	off	.050	off	off	off	.050
5	off	off	.045	off	off	off	.045
6	off	off	.043	off	.049	off	.049
7	off	off	.049	off	off	off	.049
8	off	off	.042	off	off	off	.042
9	off	off	.045	.052	off	off	.052
10	off	off	.050	off	off	off	.050
11	off	off	.047	off	off	off	.047
12	off	off	.048	off	off	off	.048
13	off	off	.048	off	.054	off	.054
14	off	off	.061	off	off	off	.061
15	.059	off	.054	off	off	off	.059
16	off	off	.095	off	off	off	.095
17	off	off	.051	off	off	off	.051
18	off	off	.048	off	.047	off	.048
19	off	off	.051	off	off	off	.051
20	off	off	.050	off	off	off	.050
21	off	off	.051	off	off	off	.051
22	off	off	.079	off	off	off	.079
23	off	off	.053	off	off	off	.053
24	off	off	.055	off	off	off	.055
25	off	off	.055	off	off	off	.055
26	off	off	.069	off	off	off	.069
27	off	off	.063	off	off	off	.063
28	off	off	.066	off	off	off	.066
29	off	off	.066	off	off	off	.066
30	off	off	.120	off	off	off	.120
31	off	off	.094	.155	off	off	.155

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <u>Yes</u> / No	CT's met everyday? (see back) <u>Yes</u> / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <u>Yes</u> / No	
All the 4-hour turbidity readings ≤ 1 NTU? <u>Yes</u> / No			
All turbidity readings < IFC ² triggers? <u>Yes</u> / No ²			
Notes:	PRINTED NAME: <u>Robert Fowler</u>		
	SIGNATURE: <u>Robert Fowler</u>	DATE: <u>11-4-25</u>	
	PHONE #: <u>(541) 679-2549</u>	CERT #: <u>T-08679</u> <u>D-08666</u>	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
² IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP.: WTP-A Month/Year: 10/2025

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 18:00 AM	1.02	224	228	20.7	6.51	8	Yes	6.7
2 18:00 AM	.87	224	194	20.6	6.55	8	Yes	6.7
3 18:00 AM	.74	224	165	20.6	6.57	8	Yes	6.7
4 18:00 AM	.67	224	150	20.8	6.65	9	Yes	6.7
5 18:00 AM	.59	224	132	20.6	6.60	9	Yes	6.7
6 18:00 AM	.87	224	194	20.7	6.68	9	Yes	6.7
7 18:00 AM	.71	224	159	20.7	6.51	8	Yes	6.7
8 18:00 AM	.71	224	159	20.6	6.52	8	Yes	6.7
9 18:00 AM	.74	224	165	20.4	6.54	8	Yes	6.7
10 18:00 AM	.78	224	174	20.5	6.47	8	Yes	6.7
11 18:00 AM	.73	224	163	20.4	6.71	9	Yes	6.7
12 18:00 AM	.73	224	163	20.5	6.47	8	Yes	6.7
13 18:00 AM	.62	224	138	20.7	6.70	9	Yes	6.7
14 18:00 AM	.63	224	141	20.9	6.62	9	Yes	6.7
15 18:00 AM	1.00	224	224	20.5	6.61	9	Yes	6.7
16 18:00 AM	1.09	224	244	20.3	6.53	8	Yes	6.7
17 18:00 AM	.92	224	206	19.8	6.62	13	Yes	6.7
18 18:00 AM	.81	224	181	19.8	6.63	12	Yes	6.7
19 18:00 AM	.75	224	168	20.0	6.59	8	Yes	6.7
20 18:00 AM	.78	224	174	20.0	6.61	9	Yes	6.7
21 18:00 AM	.64	224	143	20.0	6.53	8	Yes	6.7
22 18:00 AM	.65	224	145	20.1	6.51	8	Yes	6.7
23 18:00 AM	.95	224	212	20.2	6.72	9	Yes	6.7
24 18:00 AM	1.07	224	239	20.1	6.72	9	Yes	6.7
25 18:00 AM	1.02	224	228	19.8	6.72	13	Yes	6.7
26 18:00 AM	1.16	224	259	19.9	6.75	13	Yes	6.7
27 18:00 AM	1.16	224	259	19.9	6.76	13	Yes	6.7
28 18:00 AM	.84	224	188	20.0	6.74	9	Yes	6.7
29 18:00 AM	.81	224	181	20.5	6.77	9	Yes	6.7
30 18:00 AM	.65	224	145	20.4	6.79	9	Yes	6.7
31 18:00 AM	.68	224	152	20.1	6.81	9	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf