

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 11/2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	off	off	.096	off	off	off	.096
2	off	off	.105	off	off	off	.105
3	off	off	.099	off	off	off	.099
4	off	off	.099	off	off	off	.099
5	off	off	.081	off	.092	off	.092
6	off	off	off	.095	off	off	.095
7	off	off	.100	off	off	off	.100
8	off	off	.106	off	off	off	.106
9	off	off	.106	off	off	off	.106
10	off	off	.115	off	off	off	.115
11	off	off	.115	off	off	off	.115
12	off	off	.092	off	off	off	.092
13	off	off	.092	.118	off	off	.118
14	off	off	.145	.106	off	off	.145
15	off	off	.079	off	off	off	.079
16	off	off	.081	off	off	off	.081
17	off	off	.080	off	off	off	.080
18	off	off	.083	off	off	off	.083
19	off	off	.080	off	off	off	.080
20	off	off	.069	off	off	off	.069
21	off	off	.067	off	off	off	.067
22	off	off	.071	off	off	off	.071
23	off	off	.068	off	off	off	.068
24	off	off	.063	off	off	off	.063
25	off	off	.059	off	off	off	.059
26	off	off	.058	off	off	off	.058
27	off	off	.058	off	off	off	.058
28	off	off	.068	off	off	off	.068
29	off	off	off	.120	off	off	.120
30	off	off	.074	off	off	off	.074
31							

Conventional or Direct Filtration 95% of the 4-hour turbidity readings ≤ 0.3 NTU? ☒ Yes / ☐ No All the 4-hour turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No All turbidity readings < IFC ² triggers? ☒ Yes / ☐ No ²		Monthly Summary (Answer Yes or No) CT's met everyday? ☒ Yes / ☐ No (see back) All Cl ₂ residuals at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No	
Notes:		PRINTED NAME: Robert Fowler	
		SIGNATURE: Robert Fowler	DATE: 12-3-25
		PHONE #: (521) 679-2529	CERT #: T-08679 D-08666

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indiv. Filter Eff. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program -- Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 11/2025

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00 AM	.91	224	203	19.5	6.83	13	Yes	6.7
2 8:00 AM	.91	224	203	19.4	6.87	13	Yes	6.7
3 8:00 AM	.83	224	185	19.4	6.87	12	Yes	6.7
4 8:00 AM	.67	224	150	19.4	6.93	12	Yes	6.7
5 8:00 AM	.63	224	141	19.6	6.91	12	Yes	6.7
6 8:00 AM	.51	224	114	19.7	6.95	12	Yes	6.7
7 8:00 AM	.65	224	145	19.5	6.93	12	Yes	6.7
8 8:00 AM	.70	224	156	19.1	6.97	12	Yes	6.7
9 8:00 AM	.86	224	192	19.4	7.00	12	Yes	6.7
10 8:00 AM	.75	224	168	19.4	6.98	12	Yes	6.7
11 8:00 AM	.82	224	183	19.5	7.01	12	Yes	6.7
12 8:00 AM	.79	224	176	19.5	7.00	12	Yes	6.7
13 8:00 AM	.64	224	143	19.4	7.11	12	Yes	6.7
14 8:00 AM	.62	224	138	19.2	6.96	12	Yes	6.7
15 8:00 AM	.67	224	150	19.0	7.13	12	Yes	6.7
16 8:00 AM	.58	224	129	19.1	6.95	12	Yes	6.7
17 8:00 AM	.73	224	163	19.1	7.04	12	Yes	6.7
18 8:00 AM	.53	224	118	19.0	7.08	12	Yes	6.7
19 8:00 AM	.57	224	127	19.2	7.08	12	Yes	6.7
20 8:00 AM	.67	224	150	19.4	7.04	12	Yes	6.7
21 8:00 AM	.81	224	181	19.2	6.93	12	Yes	6.7
22 8:00 AM	.82	224	183	18.8	7.10	12	Yes	6.7
23 8:00 AM	.95	224	212	19.1	6.96	13	Yes	6.7
24 8:00 AM	1.04	224	232	19.4	6.99	13	Yes	6.7
25 8:00 AM	1.08	224	241	19.4	7.02	13	Yes	6.7
26 8:00 AM	1.18	224	264	19.3	7.02	13	Yes	6.7
27 8:00 AM	1.28	224	286	18.9	7.01	13	Yes	6.7
28 8:00 AM	1.23	224	275	19.2	7.03	13	Yes	6.7
29 8:00 AM	1.09	224	244	19.0	7.00	13	Yes	6.7
30 8:00 AM	1.08	224	241	18.9	7.04	13	Yes	6.7
31 /								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf