

**OHA - Drinking Water Program -- Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 12/2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.077	off	off	off	.077
2	off	off	.070	off	off	off	.070
3	off	off	.069	off	off	off	.069
4	off	off	.067	off	off	off	.067
5	off	off	.067	off	off	off	.067
6	off	off	off	.064	off	off	.064
7	off	off	.068	off	off	off	.068
8	off	off	.065	off	off	off	.065
9	off	off	.058	off	off	off	.058
10	off	off	.061	off	off	off	.061
11	off	off	.089	.080	off	off	.089
12	off	off	.080	off	off	off	.080
13	off	off	.070	.119	off	off	.119
14	off	off	.075	off	off	off	.075
15	off	off	.067	off	off	off	.067
16	off	off	off	.081	off	off	.081
17	off	off	.076	off	off	off	.076
18	off	off	.071	off	off	off	.071
19	off	off	.069	off	off	off	.069
20	off	off	.070	off	off	off	.070
21	off	off	.072	off	off	off	.072
22	off	off	.114	off	off	off	.114
23	off	off	off	.110	off	off	.110
24	off	off	.113	off	off	off	.113
25	off	off	.128	off	off	off	.128
26	off	off	.130	off	off	off	.130
27	off	off	off	.150	off	off	.150
28	off	off	.090	off	off	off	.090
29	off	off	.090	off	off	off	.090
30	off	off	off	.074	off	off	.074
31	off	off	.068	off	off	off	.068

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
All turbidity readings < IFC ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
Notes:	PRINTED NAME: Robert Fowler		
	SIGNATURE: <i>Robert Fowler</i>	DATE: 1-2-26	
	PHONE #: 541 1679-2549	CERT #: T-08679 D-08666	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
²IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 12/2025 Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 18:00 AM	.98	224	219	19.0	7.03	13	YES	6.7
2 18:00 AM	1.03	224	230	18.8	7.07	13	YES	6.7
3 18:00 AM	.68	224	152	18.8	7.14	12	Yes	6.7
4 18:00 AM	.63	224	141	18.6	7.10	12	Yes	6.7
5 18:00 AM	.59	224	132	18.8	7.10	12	Yes	6.7
6 18:00 AM	.58	224	129	18.6	7.05	12	Yes	6.7
7 18:00 AM	.74	224	165	18.9	7.01	12	YES	6.7
8 18:00 AM	.86	224	192	19.0	7.08	12	YES	6.7
9 18:00 AM	.76	224	170	19.0	7.01	12	Yes	6.7
10 18:00 AM	.93	224	208	19.1	7.12	13	Yes	6.7
11 18:00 AM	1.06	224	237	19.1	6.89	13	Yes	6.7
12 18:00 AM	1.22	224	273	18.6	7.14	13	Yes	6.7
13 18:00 AM	1.15	224	257	18.1	7.01	13	Yes	6.7
14 18:00 AM	1.05	224	235	18.0	6.98	13	YES	6.7
15 18:00 AM	.92	224	206	18.1	7.01	13	YES	6.7
16 18:00 AM	.77	224	172	17.7	7.00	12	Yes	6.7
17 18:00 AM	.69	224	154	18.1	6.84	12	YES	6.7
18 18:00 AM	.71	224	159	18.0	7.11	12	Yes	6.7
19 18:00 AM	.72	224	161	17.7	7.07	12	Yes	6.7
20 18:00 AM	.74	224	165	17.5	7.02	12	Yes	6.7
21 18:00 AM	.76	224	170	17.7	6.97	12	YES	6.7
22 18:00 AM	.87	224	194	18.0	6.97	12	YES	6.7
23 18:00 AM	.74	224	165	17.8	6.92	12	Yes	6.7
24 18:00 AM	.94	224	210	17.6	6.86	13	YES	6.7
25 18:00 AM	1.01	224	226	17.6	6.92	13	YES	6.7
26 18:00 AM	.74	224	165	18.0	7.01	12	Yes	6.7
27 18:00 AM	.64	224	143	17.6	6.79	12	Yes	6.7
28 18:00 AM	.71	224	159	17.2	6.82	12	YES	6.7
29 18:00 AM	.65	224	145	17.1	6.78	12	YES	6.7
30 18:00 AM	.58	224	129	17.0	6.79	12	Yes	6.7
31 18:00 AM	.94	224	210	16.0	6.90	13	YES	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.