

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 1/2026

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	.065	OFF	OFF	OFF	.065
2	OFF	OFF	.063	OFF	OFF	OFF	.063
3	OFF	OFF	OFF	.087	OFF	OFF	.087
4	OFF	OFF	.081	OFF	OFF	OFF	.081
5	OFF	OFF	.085	OFF	OFF	OFF	.085
6	OFF	OFF	.089	OFF	OFF	OFF	.089
7	OFF	OFF	OFF	.085	OFF	OFF	.085
8	OFF	OFF	OFF	.085	OFF	OFF	.085
9	OFF	OFF	.076	OFF	OFF	OFF	.076
10	OFF	OFF	.075	.160	OFF	OFF	.160
11	OFF	OFF	.103	OFF	OFF	OFF	.103
12	OFF	OFF	.088	OFF	OFF	OFF	.088
13	OFF	OFF	.079	OFF	OFF	OFF	.079
14	OFF	OFF	.075	OFF	OFF	OFF	.075
15	OFF	OFF	.074	OFF	OFF	OFF	.074
16	OFF	OFF	.078	OFF	OFF	OFF	.078
17	OFF	OFF	.073	OFF	OFF	OFF	.073
18	OFF	OFF	.069	OFF	OFF	OFF	.069
19	OFF	OFF	.067	OFF	OFF	OFF	.067
20	OFF	OFF	.069	OFF	OFF	OFF	.069
21	OFF	OFF	.072	OFF	OFF	OFF	.072
22	OFF	OFF	.070	OFF	OFF	OFF	.070
23	OFF	OFF	.075	OFF	.070	OFF	.075
24	OFF	.082	OFF	.158	OFF	OFF	.158
25	OFF	OFF	.092	OFF	.078	OFF	.092
26	OFF	OFF	.087	OFF	OFF	OFF	.087
27	OFF	OFF	.079	OFF	OFF	OFF	.079
28	OFF	OFF	.086	OFF	OFF	OFF	.086
29	OFF	OFF	.081	OFF	OFF	OFF	.081
30	OFF	OFF	.080	OFF	OFF	OFF	.080
31	OFF	OFF	.084	OFF	OFF	OFF	.084

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings $<$ ITC ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: <i>ROBERT FOWLER</i>	
	SIGNATURE: <i>Robert Fowler</i>	DATE: <i>2-4-26</i>
	PHONE #: <i>(571) 1699-2549</i>	CERT #: <i>T-08679</i> <i>D-08666</i>

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 1/2006

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00 AM	.98	224	219	16.3	6.76	13	YES	6.7
2 8:00 AM	.81	224	181	16.7	6.82	12	Yes	6.7
3 8:00 AM	.93	224	208	16.8	6.73	13	Yes	6.7
4 8:00 AM	1.02	224	228	17.2	6.86	13	YES	6.7
5 8:00 AM	1.09	224	244	17.4	6.88	13	YES	6.7
6 8:00 AM	1.04	224	232	17.4	6.78	13	Yes	6.7
7 8:00 AM	1.06	224	237	17.6	6.70	13	Yes	6.7
8 8:00 AM	1.07	224	239	17.3	6.74	13	Yes	6.7
9 8:00 AM	1.03	224	230	16.9	6.80	13	Yes	6.7
10 8:00 AM	.98	224	219	16.4	6.91	13	Yes	6.7
11 8:00 AM	1.01	224	226	16.2	6.75	13	YES	6.7
12 8:00 AM	.95	224	212	16.0	6.66	13	YES	6.7
13 8:00 AM	.70	224	156	15.6	6.67	12	Yes	6.7
14 8:00 AM	.59	224	132	15.7	6.68	12	Yes	6.7
15 8:00 AM	.64	224	143	15.8	6.92	12	Yes	6.7
16 8:00 AM	.58	224	129	15.5	6.68	12	Yes	6.7
17 8:00 AM	.68	224	152	15.1	6.69	12	Yes	6.7
18 8:00 AM	.86	224	192	15.5	6.89	12	YES	6.7
19 8:00 AM	1.27	224	284	15.6	6.68	13	YES	6.7
20 8:00 AM	1.21	224	271	15.6	6.73	13	Yes	6.7
21 8:00 AM	1.22	224	273	15.7	6.72	13	Yes	6.7
22 8:00 AM	1.42	224	318	15.4	6.85	13	YES	6.7
23 8:00 AM	1.31	224	293	15.2	6.80	13	Yes	6.7
24 8:00 AM	1.38	224	309	14.8	6.96	19	Yes	6.7
25 8:00 AM	1.08	224	241	13.4	6.84	19	YES	6.7
26 8:00 AM	1.05	224	235	12.9	6.97	19	YES	6.7
27 8:00 AM	.68	224	152	12.9	6.88	18	Yes	6.7
28 8:00 AM	.60	224	134	13.1	6.88	18	Yes	6.7
29 8:00 AM	.65	224	145	13.3	6.91	18	Yes	6.7
30 8:00 AM	.96	224	215	13.5	6.78	19	Yes	6.7
31 8:00 AM	1.01	224	226	13.4	6.79	19	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.