

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Douglas  
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP: WTP-A Month/Year: 3/2026

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	off	off	off	.101	off	off	.101
2	off	off	.104	off	off	off	.104
3	off	off	.106	off	off	off	.106
4	off	off	.101	off	off	off	.101
5	off	off	.088	off	off	off	.088
6	off	off	.089	off	off	off	.089
7	off	off	.097	off	off	off	.097
8	off	off	.096	off	off	off	.096
9	off	off	.085	off	off	.081	.085
10	off	off	.076	off	off	.076	.076
11	.075	off	.076	off	.077	off	.077
12	.075	off	off	off	.122	off	.122
13	off	off	.098	off	off	off	.098
14	off	off	.089	off	off	off	.089
15	off	off	.082	off	off	off	.082
16	off	off	.082	off	off	off	.082
17	off	off	.080	off	off	off	.088
18	off	off	.076	off	off	off	.076
19	off	off	.076	off	off	off	.076
20	off	off	.074	off	off	off	.074
21	off	off	.081	off	off	off	.081
22	off	off	.078	off	off	off	.078
23	off	off	.076	off	off	off	.076
24	off	off	.087	off	off	off	.087
25	off	off	.088	off	off	off	.088
26	off	off	off	.091	off	off	.091
27	off	off	.130	off	off	off	.130
28	off	off	.093	off	off	off	.093
29	off	off	.127	off	off	off	.127
30	off	off	.100	off	off	off	.100
31	off	off	.089	off	off	off	.089

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Notes:		
All turbidity readings < 11C <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	PRINTED NAME: Jonathan Woody		
	SIGNATURE: Jonathan Woody		DATE: 4-6-26
	PHONE #: (541) 643-6137		CERT #: 7232

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP.: WTP-A Month/Year: 3/2026

Required Log Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1 18:00 Am	.92	224	206	17.2	6.79	13	yes	6.7
2 18:00 Am	.89	224	199	16.9	6.79	12	yes	6.7
3 18:00 Am	.83	224	185	17.3	6.85	12	yes	6.7
4 18:00 Am	.76	224	170	17.8	6.70	12	yes	6.7
5 18:00 Am	.63	224	141	17.9	6.82	12	yes	6.7
6 18:00 Am	.75	224	168	17.8	6.81	12	yes	6.7
7 18:00 Am	.71	224	159	18.2	6.78	12	yes	6.7
8 18:00 Am	.64	224	143	19.1	6.71	12	yes	6.7
9 18:00 Am	.70	224	156	19.2	6.84	12	yes	6.7
10 18:00 Am	1.23	224	275	18.1	6.61	11	yes	6.7
11 18:00 Am	1.58	224	353	16.3	6.79	13	yes	6.7
12 18:00 Am	1.55	224	347	14.9	6.90	20	yes	6.7
13 18:00 Am	1.45	224	324	15.1	6.67	11	yes	6.7
14 18:00 Am	1.29	224	288	16.6	6.72	11	yes	6.7
15 18:00 Am	1.18	224	264	16.8	6.71	13	yes	6.7
16 18:00 Am	1.10	224	246	16.9	6.91	13	yes	6.7
17 18:00 Am	1.06	224	237	17.8	6.92	13	yes	6.7
18 18:00 Am	.88	224	197	18.8	6.66	12	yes	6.7
19 18:00 Am	.84	224	188	19.4	6.84	12	yes	6.7
20 18:00 Am	.79	224	176	19.6	6.75	12	yes	6.7
21 18:00 Am	.81	224	181	20.2	6.75	9	yes	6.7
22 18:00 Am	.88	224	147	20.3	6.78	9	yes	6.7
23 18:00 Am	.98	224	219	20.1	6.59	9	yes	6.7
24 18:00 Am	1.08	224	241	20.5	6.57	9	yes	6.7
25 18:00 Am	.99	224	221	20.8	6.85	9	yes	6.7
26 18:00 Am	.99	224	221	20.3	6.76	9	yes	6.7
27 18:00 Am	1.06	224	237	20.2	6.66	8	yes	6.7
28 18:00 Am	1.02	224	228	20.2	6.60	8	yes	6.7
29 18:00 Am	.79	224	176	20.6	6.60	8	yes	6.7
30 18:00 Am	.72	224	165	20.5	6.65	8	yes	6.7
31 18:00 Am	.67	224	150	20.3	6.66	8	yes	6.7

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.