

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas  
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 1/2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	OFF	OFF	.081	OFF	OFF	OFF	.081
2	OFF	OFF	.081	OFF	OFF	OFF	.081
3	OFF	OFF	.065	OFF	OFF	OFF	.065
4	OFF	OFF	.061	OFF	OFF	.060	.061
5	OFF	OFF	.062	OFF	.049	OFF	.062
6	OFF	OFF	.047	OFF	OFF	.049	.049
7	OFF	OFF	.049	.175	OFF	OFF	.175
8	.091	OFF	.088	OFF	OFF	OFF	.091
9	.074	OFF	OFF	.070	OFF	OFF	.074
10	OFF	OFF	.082	OFF	OFF	OFF	.082
11	OFF	OFF	.074	OFF	OFF	.077	.077
12	OFF	OFF	.070	OFF	OFF	.060	.070
13	OFF	OFF	.060	.043	OFF	OFF	.060
14	OFF	.059	.036	OFF	OFF	OFF	.059
15	.068	OFF	.087	.185	OFF	OFF	.185
16	OFF	OFF	.099	OFF	OFF	OFF	.099
17	OFF	OFF	.070	OFF	OFF	OFF	.070
18	OFF	OFF	.067	OFF	OFF	.065	.067
19	OFF	OFF	.063	OFF	OFF	.056	.063
20	OFF	OFF	.042	OFF	OFF	.042	.042
21	OFF	OFF	.039	OFF	OFF	.046	.040
22	OFF	OFF	.039	OFF	OFF	OFF	.039
23	OFF	.040	OFF	.163	OFF	OFF	.163
24	OFF	OFF	.069	OFF	OFF	OFF	.069
25	OFF	.064	.055	OFF	OFF	OFF	.064
26	.053	OFF	.044	OFF	OFF	.050	.053
27	OFF	OFF	.053	OFF	OFF	OFF	.053
28	.051	OFF	.046	OFF	OFF	.048	.051
29	OFF	OFF	.048	OFF	OFF	OFF	.048
30	.042	OFF	OFF	.165	OFF	OFF	.165
31	OFF	OFF	.098	OFF	OFF	OFF	.098

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No		Notes:	
PRINTED NAME: Robert Fowler		SIGNATURE: Robert Fowler	
PHONE #: (541) 679-2549		DATE: 2-2-21	
		CERT #: T-08679 D-08666	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)).

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 1/2021

Required Log Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00AM	1.46	224	327	13.3	7.18	19	Yes	6.7
2 8:00AM	1.30	224	291	13.5	7.15	19	Yes	6.7
3 8:00AM	1.23	224	275	13.9	7.16	19	Yes	6.7
4 8:00AM	1.13	224	253	14.4	7.15	19	Yes	6.7
5 8:00AM	1.17	224	262	14.4	7.15	19	Yes	6.7
6 8:00AM	1.32	224	295	14.3	7.16	19	Yes	6.7
7 8:00AM	1.53	224	342	13.8	7.16	20	Yes	6.7
8 8:00AM	1.43	224	320	13.0	7.14	19	Yes	6.7
9 8:00AM	1.23	224	275	12.8	7.08	19	Yes	6.7
10 8:00AM	1.10	224	246	13.4	7.03	19	Yes	6.7
11 8:00AM	1.13	224	253	13.3	7.04	19	Yes	6.7
12 8:00AM	1.13	224	253	14.0	7.05	19	Yes	6.7
13 8:00AM	1.32	224	295	14.3	7.10	19	Yes	6.7
14 8:00AM	1.41	224	315	14.4	7.10	19	Yes	6.7
15 8:00AM	1.45	224	324	14.3	7.10	19	Yes	6.7
16 8:00AM	1.18	224	264	14.2	7.08	19	Yes	6.7
17 8:00AM	1.02	224	228	14.6	7.08	19	Yes	6.7
18 8:00AM	.95	224	212	14.5	7.09	19	Yes	6.7
19 8:00AM	1.04	224	232	14.7	7.13	19	Yes	6.7
20 8:00AM	1.19	224	266	14.5	7.11	19	Yes	6.7
21 8:00AM	1.38	224	369	14.1	7.15	19	Yes	6.7
22 8:00AM	1.43	224	320	14.3	7.14	19	Yes	6.7
23 8:00AM	1.43	224	320	14.0	7.16	19	Yes	6.7
24 8:00AM	1.30	224	291	13.6	7.19	19	Yes	6.7
25 8:00AM	1.25	224	280	13.2	7.19	19	Yes	6.7
26 8:00AM	1.20	224	268	12.9	7.21	23	Yes	6.7
27 8:00AM	1.13	224	253	12.6	7.22	22	Yes	6.7
28 8:00AM	1.15	224	257	12.2	7.23	22	Yes	6.7
29 8:00AM	1.18	224	264	12.1	7.24	22	Yes	6.7
30 8:00AM	1.21	224	271	12.1	7.26	23	Yes	6.7
31 8:00AM	1.31	224	293	12.2	7.29	23	Yes	6.7

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.