

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 3/2008

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	OFF	OFF	.070	off	off	.069	.070
2	off	off	.067	off	off	off	.067
3	.060	off	.051	off	off	off	.060
4	.058	off	off	.054	off	.071	.071
5	off	off	off	.074	off	off	.074
6	off	off	.061	off	off	off	.061
7	off	off	.049	off	off	off	.049
8	off	.050	off	.041	off	off	.050
9	off	off	.048	off	off	off	.048
10	off	.049	off	.042	off	off	.049
11	off	off	.052	off	off	off	.052
12	off	off	.198	off	off	off	.198
13	off	off	.101	off	off	off	.101
14	off	off	.082	off	off	off	.082
15	off	off	.078	off	off	off	.078
16	.070	off	off	.066	off	off	.070
17	off	off	.056	off	off	off	.056
18	off	off	.059	off	off	off	.059
19	off	.054	off	.042	off	off	.054
20	off	off	.052	off	off	off	.052
21	off	off	.049	off	off	off	.049
22	off	.048	off	.042	off	off	.048
23	off	off	.057	off	off	off	.057
24	off	off	.058	off	off	off	.058
25	off	off	.053	off	off	off	.053
26	off	.051	.170	off	off	off	.170
27	off	off	.088	off	off	off	.088
28	off	off	.079	off	off	off	.079
29	off	.072	off	.051	off	off	.072
30	off	off	.093	off	off	off	.093
31	off	off	.072	.050	off	off	.072

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / No ²		
Notes:	PRINTED NAME: Robert Fowler	
	SIGNATURE: Robert Fowler	DATE: 4-1-22
	PHONE #: (541) 679-2549	CERT #: T-08679 D-08666

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Indivd. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 3/2022

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00 AM	1.23	224	275	12.8	6.98	19	Yes	6.7
2 8:00 AM	1.08	224	241	13.0	6.93	19	Yes	6.7
3 8:00 AM	.98	224	224	13.2	6.90	19	Yes	6.7
4 8:00 AM	1.04	224	232	13.6	6.90	19	Yes	6.7
5 8:00 AM	1.16	224	259	13.9	6.87	19	Yes	6.7
6 8:00 AM	1.28	224	286	14.0	6.86	19	Yes	6.7
7 8:00 AM	1.31	224	293	14.3	6.84	19	Yes	6.7
8 8:00 AM	1.27	224	284	14.6	6.83	19	Yes	6.7
9 8:00 AM	1.24	224	277	15.2	6.81	13	Yes	6.7
10 8:00 AM	1.22	224	273	14.9	6.81	19	Yes	6.7
11 8:00 AM	1.33	224	297	15.1	6.82	13	Yes	6.7
12 8:00 AM	1.30	224	291	15.5	6.84	13	Yes	6.7
13 8:00 AM	1.31	224	293	15.6	6.84	13	Yes	6.7
14 8:00 AM	1.33	224	297	15.5	6.91	13	Yes	6.7
15 8:00 AM	1.30	224	291	15.8	6.93	13	Yes	6.7
16 8:00 AM	1.28	224	286	15.6	6.97	13	Yes	6.7
17 8:00 AM	1.25	224	280	16.0	6.96	13	Yes	6.7
18 8:00 AM	1.28	224	286	16.4	6.95	13	Yes	6.7
19 8:00 AM	1.16	224	259	16.5	6.95	13	Yes	6.7
20 8:00 AM	1.22	224	273	16.4	6.95	13	Yes	6.7
21 8:00 AM	1.22	224	273	16.6	6.93	13	Yes	6.7
22 8:00 AM	1.19	224	266	17.0	6.91	13	Yes	6.7
23 8:00 AM	1.22	224	273	17.6	6.92	13	Yes	6.7
24 8:00 AM	1.16	224	259	17.7	6.92	13	Yes	6.7
25 8:00 AM	1.17	224	262	18.2	6.88	13	Yes	6.7
26 8:00 AM	1.16	224	259	18.3	6.85	13	Yes	6.7
27 8:00 AM	1.26	224	282	18.4	6.90	13	Yes	6.7
28 8:00 AM	1.23	224	275	17.8	6.94	13	Yes	6.7
29 8:00 AM	1.16	224	259	17.7	6.95	13	Yes	6.7
30 8:00 AM	1.24	224	277	17.3	7.01	13	Yes	6.7
31 8:00 AM	1.24	224	277	17.4	6.97	13	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.