

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP:-WTP-A Month/Year: 5/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.079	off	off	off	.079
2	off	off	.066	off	off	off	.066
3	off	off	.069	off	off	off	.069
4	.058	off	off	.052	off	off	.058
5	off	off	.050	off	off	off	.050
6	off	.052	.042	off	off	off	.052
7	off	off	.048	off	off	off	.048
8	off	off	.057	off	off	off	.057
9	off	off	.045	off	off	off	.045
10	off	.042	off	.036	off	off	.042
11	off	off	.038	off	off	off	.038
12	off	.039	off	.036	off	off	.039
13	off	.040	off	.190	off	off	.190
14	off	off	off	.085	off	off	.085
15	off	off	off	.067	off	off	.067
16	off	off	.056	off	off	off	.056
17	off	.060	off	.060	off	off	.060
18	off	off	.049	off	off	off	.049
19	off	.050	off	.042	off	off	.050
20	off	off	.043	off	off	off	.043
21	off	.045	off	.036	off	off	.045
22	off	off	.040	off	off	off	.040
23	off	off	.038	off	off	off	.038
24	.038	off	off	.033	off	off	.038
25	off	off	.035	off	off	.042	.042
26	off	off	off	.037	off	off	.037
27	.042	off	off	.103	off	off	.103
28	off	off	.050	off	off	off	.050
29	off	off	.042	off	off	off	.042
30	off	off	.039	off	off	off	.039
31	off	off	.112	.104	off	off	.112

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No		Notes:	
PRINTED NAME: Robert Fowler		SIGNATURE: Robert Fowler	
PHONE #: (541) 679-2549		DATE: 6-1-22	
		CERT #: T-08679 D-08666	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

ROSEBURG FOREST PROD - DILLARD ID #: OR4194300 WTP-: WTP-A Month/Year: 5/2022

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 8:00 AM	1.42	224	318	17.1	7.50	16	Yes	6.7
2 8:00 AM	1.31	224	293	17.1	7.50	16	Yes	6.7
3 8:00 AM	1.18	224	264	17.0	7.48	15	Yes	6.7
4 8:00 AM	1.14	224	255	17.2	7.46	15	Yes	6.7
5 8:00 AM	1.05	224	235	17.5	7.44	15	Yes	6.7
6 8:00 AM	1.10	224	246	17.6	7.42	15	Yes	6.7
7 8:00 AM	1.18	224	264	17.7	7.37	15	Yes	6.7
8 8:00 AM	1.19	224	266	17.7	7.32	15	Yes	6.7
9 8:00 AM	1.25	224	280	17.6	7.34	15	Yes	6.7
10 8:00 AM	1.25	224	280	17.7	7.27	15	Yes	6.7
11 8:00 AM	1.36	224	304	17.9	7.29	15	Yes	6.7
12 8:00 AM	1.37	224	306	17.9	7.28	15	Yes	6.7
13 8:00 AM	1.44	224	322	17.7	7.24	16	Yes	6.7
14 8:00 AM	1.51	224	388	17.3	7.21	16	Yes	6.7
15 8:00 AM	1.50	224	336	17.3	7.20	16	Yes	6.7
16 8:00 AM	1.48	224	331	16.9	7.18	16	Yes	6.7
17 8:00 AM	1.37	224	306	17.5	7.14	15	Yes	6.7
18 8:00 AM	1.41	224	315	17.6	7.18	16	Yes	6.7
19 8:00 AM	1.43	224	320	17.8	7.15	16	Yes	6.7
20 8:00 AM	1.36	224	304	18.0	7.16	16	Yes	6.7
21 8:00 AM	1.32	224	295	17.9	7.14	15	Yes	6.7
22 8:00 AM	1.30	224	291	18.0	7.13	16	Yes	6.7
23 8:00 AM	1.24	224	277	18.5	7.08	13	Yes	6.7
24 8:00 AM	1.30	224	291	18.9	7.07	13	Yes	6.7
25 8:00 AM	1.20	224	268	19.0	7.05	13	Yes	6.7
26 8:00 AM	1.20	224	268	19.1	7.04	13	Yes	6.7
27 8:00 AM	1.18	224	264	19.0	6.93	13	Yes	6.7
28 8:00 AM	1.12	224	250	19.1	6.84	13	Yes	6.7
29 8:00 AM	1.11	224	248	19.0	6.74	13	Yes	6.7
30 8:00 AM	0.97	224	217	18.7	6.71	13	Yes	6.7
31 8:00 AM	1.00	224	224	19.0	6.68	13	Yes	6.7

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.