

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Jefferson

Cartridge or Bag Filtration

Month/Year: 6/2021

System Name:	Olallie Lake Resort		ID#:	41 94426	WTP ID:	TP-	A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]	
31/1	23	35	12	15.00	.51		
2							
3							
4	↑						
5							
6							
7							
8							
9	off						
10							
11							
12							
13							
14	↓						
15							
16							
17	23	25	12		.46		
18							
19	↑						
20							
21							
22							
23							
24	off						
25							
26							
27	↓						
28							
29							
30	23	35			.43		
31							

Start-up

↑

↓

↑

off

↓

<b>Cartridge &amp; Bag Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: Diane Whitfield	DATE: 7/6/2021
		SIGNATURE: <i>Diane Whitfield</i>	CERT #:
		PHONE #: (503) 853-3481	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Olallie Lake Resort ID#: 41 94426 Month/Year:

Disinfection  
Giardia Log  
Inactiv: 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.0	37.2	74.4	12°C	7.2	39	yes	
2	2.0			53°F				
3	2.2							
4	2.2							
5	2.2							
6	2.1							
7	2.1							
8	2.0							
9	2.0							
10	2.0							
11	2.0							
12	2.0							
13	1.9							
14	1.8							
15	1.8							
16	1.8							
17	1.8	37.2	66.96	12°C	7.0	35	yes	
18	1.8			53°F				
19	1.8							
20	1.6							
21	1.6							
22	1.6							
23	1.6							
24	1.5							
25	1.5							
26	1.4							
27	1.4							
28	1.5							
29	1.5							
30	1.5	37.2	55.80	18°C	7.2	24	yes	
31				64°F				

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

still not open to the public. Hope to open July 22, 2021.