

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Jefferson

Cartridge or Bag Filtration

Month/Year: 7/2021

System Name: Ofallie Lake Resort ID#: 41 94426 WTP ID: TP- A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	↑ off			15.00		
2	↓ off					
3	23	35	12		.41	
4						
5	↑					
6						
7						
8						
9						
10						
11						
12						
13	off					
14						
15						
16						
17	↓					
18						
19						
20	23	35	12		.40	
21						
22	← ↑					
23	off					
24	↓					
25						
26	22	35	13		.49	
27	↑					
28	off					
29						
30	↓					
31						

open to public →

Open to Public

7/22/21 →

<p>Cartridge & Bag Filtration</p> <p>95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No</p> <p>All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No</p>		<p>Monthly Summary (Answer Yes or No)</p> <p>CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No</p> <p>All Cl₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No</p>	
<p>Notes: PSI = pounds per square inch</p> <p>PSID = pounds per square inch difference (before filter - after filter)</p> <p>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.</p>		<p>PRINTED NAME: Diane Whitfield</p> <p>SIGNATURE: <i>Diane Whitfield</i> DATE: 8/3/21</p> <p>PHONE #: (503) 853-6348 CERT #:</p>	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: A

System Name: Olallie Lake Resort ID#: 41 94426 Month/Year: 7/2021

Disinfection
Giardia Log
Inactiv: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.5	37.2						
2	1.5							
3	1.5	37.2	55.80	18°C	7.2	24	yes	
4	1.5			64°F				
5	1.8							
6	1.8							
7	1.8							
8	1.7							
9	1.7							
10	1.5							
11	1.5							
12	1.5							
13	1.5							
14	1.5							
15	1.5							
16	1.5							
17	1.5							
18	1.4							
19	1.5							
20	1.5	37.2	55.80	18°C	7.8	31		
21	1.4			64°F				
22	1.4							
23	1.4							
24	1.5							
25	1.5							
26	1.5	37.2	55.80	18°C	7.8	31		
27	1.6			64°F				
28	1.6							
29	1.6							
30	1.6							
31	1.6							

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013