

Cartridge or Bag Filtration

Month/Year: 9/2023

System Name:	Olallie Lake Resort		ID#:	41	94426	WTP ID:	TP-	A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]		
on ①	13	23	10	15.00	.21	.33 Before filter		
2	↑				↑			
3								
4	off				off			
5	↓				↓			
6								
7								
on ⑧	13	23	10		.22	.35 Before filter		
9								
10								
11								
12								
13								
14								
on ⑮	13	24	11		.29	.47 Before filter		
16	↑				↑			
17								
18								
19								
20								
21								
22	off				off			
23								
24								
25								
26								
27								
28								
29								
30								
31								

<p><b>Cartridge &amp; Bag Filtration</b></p> <p>95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>		<p><b>Monthly Summary (Answer Yes or No)</b></p> <p>CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All Cl<sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>	
<p>Notes: PSI = pounds per square inch</p> <p>PSID = pounds per square inch difference (before filter - after filter)</p> <p>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.</p>		<p>PRINTED NAME: Diane Whitfield</p> <p>SIGNATURE: <i>Diane Whitfield</i> DATE: 10/2/23</p> <p>PHONE #: (503) 853 6348 CERT #:</p>	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: A

System Name: Olallie Lake Resort

ID#: 41 94426

Month/Year: 9/2023

Disinfection  
Giardia Log  
Inactiv:

1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	52°F [°C]		formula	Yes / No	[GPM]
ON ①	1.6	37.2	59.52	11°C	7.10	39	yes	
2	1.6							
3	1.6							
4	1.5							
5	1.5							
6	1.5							
7	1.5							
8	1.5							
9	1.6							
10	1.6							
11	1.5							
12	1.5							
13	1.5							
14	1.5			56°F				
ON ⑮	1.5	37.2	55.8	13°C	7.32	37	yes	
16	1.5							
17	1.6							
18	1.6							
19	1.6							
20	1.6							
21	1.5							
22	1.5							
23	1.5							
24	1.5							
25	1.5							
26	1.5							
27	1.4							
28	1.4							
29	1.4							
30	1.3							
31								

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.