

Cartridge or Bag Filtration

System Name: Olallie Lake Resort ID#: 41 94426 WTP ID: TP- A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	13	24	11	15.00	0.31	
2	↑					
3						
4						
5						
6	off					
7						
8						
9						
10						
11						
12	↓					
13						
14	14	25	11		0.39	Before filter .98
15	↑					
16						
17						
18						
19	off					
20						
21						
22	↓					
23						
24	14	25	11		0.27	Before filter .67
25	↑					
26						
27						
28	off					
29						
30	↓					
31						

Start up

open to public on

on

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: Diane Whitfield SIGNATURE: <i>Diane Whitfield</i> DATE: 7/1/24 PHONE #: (503) 853-3481 CERT #:	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Olallie Lake Resort ID#: 41 94426 Month/Year: 6/2024
 Disinfection Giardia Log Inactiv: 1

start-up

on

on

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp 46°F [°C]	pH	Required CT formula	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1	1.6	37.2	59.52	8°C	7.45	54	yes	
2	1.6							
3	1.5							
4	1.5							
5	1.5							
6	1.4							
7	1.4							
8	1.4							
9	1.4							
10	1.3							
11	1.3							
12	1.3							
13	1.3			49°F				
14	1.3	37.2	47.316	10°C	7.29	44	yes	
15	1.5							
16	1.4							
17	1.3							
18	1.3							
19	1.2							
20	1.2							
21	1.2							
22	1.2							
23	1.2			55°F				
24	1.2	37.2	47.316	13°C	7.18	33	yes	
25	1.2							
26	1.3							
27	1.3							
28	1.4							
29	1.4							
30	1.4							
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.