

Cartridge or Bag Filtration

System Name: Olallie Lake Resort ID#: 41 94426 WTP ID: TP- A

on

on

on

on

one

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	13	24	11	15.00	0.29	Before filter 0.65
2						
3	↑					
4						
5	off			off		
6	off			off		
7	off			off		
8	↓			↓		
9						
10	13	24	11	15.00	0.05	Before filter 0.28
11						
12	↑			↑		
13						
14	off			off		
15	off			off		
16						
17	14	24	10	15.00	0.19	Before filter 0.33
18						
19	↑			↑		
20						
21	off			off		
22	off			off		
23	↓			↓		
24	13	24	11	15.00	0.13	Before filter 0.33
25						
26	↑			↑		
27	off			off		
28	off			off		
29	↓			↓		
30						
31	13	24	11	15.00	0.18	Before filter 0.32

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Diane Whitfield
 SIGNATURE: *Diane Whitfield* DATE: 8/1/2024
 PHONE #: (503) 853-3481 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Olallie Lake Resort

ID#: 41 94426

Month/Year: 7/2024

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	50°F [°C]		formula	Yes / No	[GPM]
on (1)	1.4	37.2	52.08	10°C	7.34	45	yes	
2	1.4							
3	1.4							
4	1.4							
5	1.4							
6	1.3							
7	1.3							
8	1.3							
9	1.3			55°F				
on (10)	1.5	37.2	55.08	13°C	6.85	31	yes	
11	1.5							
12	1.5							
13	1.4							
14	1.4							
15	1.4							
16	1.3			57°F				
on (17)	1.4	37.2	52.08	15°C	7.02	27	yes	
18	1.4							
19	1.5							
20	1.5							
21	1.4							
22	1.4							
23	1.4			63°F				
on (24)	1.4	37.2	52.08	18°C	6.93	22	yes	
25	1.4							
26	1.4							
27	1.3							
28	1.3							
29	1.3							
30	1.3			60°F				
on (31)	1.4	37.2	52.08	17°C	6.81	23	yes	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013