

Cartridge or Bag Filtration

System Name: Olallie Lake Resort ID#: 41 94426 WTP ID: TP- A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1				15.00		
2	↑ off				↑ off	
3	↓ off				↓ off	
4	↑ off				↑ off	
5	↓ off				↓ off	
6	↑ off				↑ off	
7	14	24	10	15	0.13	Before filter 0.26
8	↑ off				↑ off	
9	↓ off				↓ off	
10	↑ off				↑ off	
11	↓ off				↓ off	
12	↑ off				↑ off	
13	↓ off				↓ off	
14	13	24	11	15	0.21	Before filter 0.32
15	↑ off				↑ off	
16	↓ off				↓ off	
17	↑ off				↑ off	
18	↓ off				↓ off	
19	↑ off				↑ off	
20	↓ off				↓ off	
21	↑ off				↑ off	
22	14	25	11	15	0.24	Before filter 0.39
23	↓ off				↓ off	
24	↑ off				↑ off	
25	↓ off				↓ off	
26	↑ off				↑ off	
27	↓ off				↓ off	
28	↑ off				↑ off	
29	↓ off				↓ off	
30	↑ off				↑ off	
31	14	25	11	15	0.21	Before filter 0.36

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Diane Whitfield
 SIGNATURE: Diane Whitfield DATE: 9/14/24
 PHONE #: (503) 853-3481 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: A

System Name: Olallie Lake Resort

ID#: 41 94426

Month/Year: 8/2024

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.4	37.2						
2	1.4							
3	1.5							
4	1.5							
5	1.4							
6	1.4			58°F				
7	1.4	37.2	52.08	15°C	6.98	26	yes	
8	1.5							
9	1.5							
10	1.5							
11	1.4							
12	1.4							
13	1.4			59°F				
14	1.4	37.2	52.08	15°C	6.97	26	yes	
15	1.4							
16	1.4							
17	1.4							
18	1.3							
19	1.3							
20	1.4							
21	1.4			58°F				
22	1.4	37.2	52.08	15°C	6.94	26	yes	
23	1.4							
24	1.5							
25	1.5							
26	1.4							
27	1.4							
28	1.4							
29	1.4							
30	1.4			58°F				
31	1.4	37.2	52.08	15°C	6.98	26	yes	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

50°F = 10°C
59°F = 15°C
68°F = 20°C